



MWRA: Current Information about PFAS Testing (October 2023) Test Results

PFAS Analyte	Metro Boston Result	CVA Result
PFAS6 (regulated)		
PFHxS	Not detected	Not detected
PFHpA	Trace*	Trace*
PFOA	Trace*	Trace*
PFOS	Trace*	Not detected
PFNA	Not detected	Not detected
PFDA	Not detected	Not detected
Sum of PFAS6 - compare to MassDEP MCL of 20 ng/l	0 ng/l	0 ng/l
Unregulated PFAS		
PFBS	Trace*	Not detected
PFHxA	Trace*	Not detected
NEtFOSAA	Not detected	Not detected
NMeFOSAA	Not detected	Not detected
PFDoA	Not detected	Not detected
PFTeDA or PFTA	Not detected	Not detected
PFTrDA	Not detected	Not detected
PFUnA	Not detected	Not detected
11Cl-PF3OUdS	Not detected	Not detected
9Cl-PF3ONS	Not detected	Not detected
Adona	Not detected	Not detected
HFPO-DA	Not detected	Not detected

* Trace amounts are present, but they are below the minimum concentration that can be reported as a quantified value. Categorized as not detected by MassDEP.
 MCL = Maximum Contaminant Level, highest level allowed