



MASSACHUSETTS WATER RESOURCES AUTHORITY

WATER QUALITY UPDATE An Analysis of July 2001 Sampling Data

This is a monthly report containing information about the quality of water supplied by MWRA. We hope this report is useful to you as a local water supplier, public health official, water consumer or observer of MWRA's system performance. It provides a more detailed review of water quality than the annual water quality report that is mailed each June to every customer in our service area. To view this annual report, please visit www.mwra.com/water/html/awqr.htm.

Indicators of Water Quality

MWRA routinely uses six general indicators of water quality:

- Microbial
- Corrosiveness (pH and alkalinity)
- Disinfection By-Products
- Turbidity & Algae
- Disinfectant Residual
- Mineral Analysis

Tests are conducted on water sampled at the source reservoirs (source or raw water) and also on water after treatment that is sampled from MWRA or community lines (treated water). A map on Page 2 indicates the location of reservoirs, treatment facilities, and service communities. Testing frequencies vary by parameter. The following pages contain information on all of the above indicators.

July 2001 Highlights

- **On July 16, a Federal Appeals Court unanimously upheld an earlier ruling in favor of MWRA's drinking water treatment program.** The appellate court agreed with a lower court's decision that MWRA's Integrated Water Supply Improvement Program adequately protects public health and ensures high quality drinking water without requiring filtration. See details at www.mwra.com.
- **Quabbin transfer rates increased, bringing Quabbin water to Cosgrove Intake.** The presence of this water should help to reduce DBPs in coming months. Rates increased from approximately 150 MGD to 300 MGD at month's end. Quabbin flows appeared to be travelling at a higher elevation in Wachusett's stratified waters than in past years, causing MWRA to open the upper gates at Cosgrove Intake to capture these flows for treatment. See Page 7 for details about DBPs.
- **Chlorine dose at Cosgrove Disinfection Facility (CDF) was increased on 7/20 and 7/27.** Dose increased from 1.7 mg/L to 1.8, then to 1.9 mg/L as a precaution against increasing levels of total coliform. The chlorine:ammonia ratio at Norumbega was also adjusted to lower nitrogen levels in distribution system water. Chlorine doses at Ware Disinfection Facility and Norumbega remained unchanged during the month. Fecal coliforms were at low levels at all three locations. See Page 3 for details on fecal coliforms, Page 5 for information about disinfection achievement.
- **Three towns violated the Total Coliform Rule during July.** Overall, however, only about 1% of all total coliform samples from communities that were tested in MWRA laboratories came out positive. See Page 6 for details on TCR sampling results by town.

*For more information, please contact MWRA at (617) 242-5323, or visit www.mwra.com
100 First Avenue, Charlestown Navy Yard, Boston, MA 02129.*

*For further information regarding health concerns, please contact
the Department of Public Health/Division of Epidemiology at (617) 983-6800
or Boston Public Health Commission at (617) 534-5611.*


Release Date: August 20 2001

The Water System

MWRA provides about 250 million gallons of water each day to 46 cities and towns in Massachusetts. Each municipality is responsible for distributing the water within its own community. Thirty of the customer communities are fully supplied by MWRA. The other communities use MWRA water to augment their own supplies, either on a regular basis or in times of water shortage. More than two million people are served by the MWRA water supply system.

Quabbin Reservoir is the primary source of water for our system and one of the country's largest water supply impoundments, with a capacity of 412 billion gallons. Quabbin water represents source water for the Chicopee Valley Aqueduct (CVA) system, serving South Hadley Fire District #1, Chicopee, and Wilbraham. Water is transferred from Quabbin Reservoir to the 65 billion gallon Wachusett Reservoir in Clinton via the Quabbin Aqueduct. Wachusett water represents source water for MetroWest and Metropolitan Boston communities.

The watershed areas of the Quabbin and Wachusett Reservoirs total 401 square miles. The Metropolitan District Commission (MDC), which manages the watersheds, and MWRA are committed to protection of the water supply through aggressive watershed protection as the first line of defense against water contamination. Three-quarters of the watersheds are protected lands and over 80% are either forest or wetlands.



Federal Safe Drinking Water Act (SDWA)

The SDWA sets standards for source and treated water quality. The standards relate to coliform, turbidity, watershed protection, disinfection and disinfection by-products, over 120 potential chemical contaminants, and waterborne disease outbreaks. MWRA monitors for these parameters on schedules ranging from daily to annually.

Customer communities must also meet certain standards under the SDWA concerning distribution of treated drinking water. The Total Coliform Rule (TCR) helps to alert communities to possible microbial contamination as well as the adequacy of residual disinfection within the local distribution system. MWRA provides testing services for many of the communities, and tests over 1500 samples per month. Under the SDWA, a violation of the TCR occurs when greater than 5% of the samples in a community are positive for total coliform during a month.

Source Water – Microbial Results

July 2001

Source Water - Microbial Results

Total coliform bacteria are monitored in both source and treated water to provide an indication of overall bacteriological activity. Most coliforms are harmless. Fecal coliform is a subclass of the coliform group which are identified by their growth at temperatures comparable to those in the intestinal tract of mammals. They act as indicators of possible fecal contamination. The Surface Water Treatment Rule for unfiltered supplies requires that no more than 10% of source water samples prior to disinfection over any six-month period have over 20 fecal coliforms per 100ml.

Sample Site: Quabbin Reservoir

Quabbin Reservoir water is sampled at Winsor Dam before entering the CVA system.

No samples were positive during July. MWRA met the six-month running average standard for fecal coliform continuously at this location over the last year.

Sample Site: Wachusett Reservoir




Wachusett Reservoir water is sampled at Cosgrove Intake before entering the MetroWest and Metropolitan Boston systems. Fecal coliform levels tend to increase during the winter, because, when water bodies near Wachusett ice over, waterfowl seek open water. Many roost at Wachusett, which tends to freeze later in the year than smaller ponds nearby.

7 of 21 samples taken were positive for fecal coliform, but all positive results were in single digits. MWRA met the six-month running average standard for fecal coliform continuously at this location over the last year. Levels of presumptive total coliforms have trended up since April. Additional testing is required to confirm that these are coliform bacteria. Most such test results have not proven positive. MWRA staff are monitoring levels closely.

Sample Site: Norumbega Reservoir

Norumbega Reservoir in Weston receives flows from Wachusett for temporary storage each day during low demand hours, which are then discharged during high demand. Norumbega water is sampled from the shore near the gatehouse before disinfection. Coliform levels are elevated periodically, partly because samples collected from the shore of this small reservoir are more susceptible to local disturbances. Covered storage is scheduled to replace this open reservoir in 2004.

1 of 31 samples from water taken along the shore was positive for fecal coliform during July. The single positive sample had a count of 1 CFU/ 100 mL.





Source Water – Turbidity and Algae Results July 2001

Source Water – Turbidity Results

Turbidity is a measure of suspended and colloidal particles including clay, silt, organic and inorganic matter, algae and microorganisms. The effects of turbidity depend on the nature of the matter that causes the turbidity. High levels of particulate matter may have a higher chlorine demand or may protect bacteria from the disinfectant effects of chlorine, thereby interfering with the disinfectant residual throughout the distribution system.



Since December, samples for turbidity from Quabbin Reservoir are collected at the Ware Disinfection Facility before chlorination. These samples represent reservoir water entering the CVA system. Samples are also taken at Cosgrove Intake, representing water quality before chlorination for source water serving the MetroWest and Metropolitan Boston systems. The Massachusetts Department of Environmental Protection standard for source water turbidity for unfiltered water supply systems is a maximum of 1.0 NTU; the EPA standard is a maximum of 5.0 NTU. Maximum turbidity results at Quabbin Reservoir and at Wachusett Reservoir were within DEP standards for the month. Occasional elevated turbidity levels at Wachusett Reservoir during July may have been related to work at the Cosgrove Power Station.



Source Water – Algae Results

Algal levels in reservoirs are monitored by MDC and MWRA. These results, along with taste and odor complaints, are used to make decisions on source water treatment for algae control.

Most taste and odor complaints at the tap are due to algae, which originate in source reservoirs, typically in trace amounts. Occasionally, a particular species grows rapidly, increasing its concentration in water. When *Synura*, *Anabaena*, or other nuisance algae blooms, MWRA treats the reservoirs with copper sulfate, an algacide. MWRA last treated Wachusett Reservoir for algae on 6/15/01 in order to reduce levels of *Anabaena*. *Anabaena* will continue to be monitored closely, as it typically blooms in June & July. Of 61 complaints received during July from local water departments, 7 concerned clogged filters or taste and odor that may be due to algae.



Treated Water – Disinfection and pH Results



July 2001

Treated Water - Primary Disinfection

Wachusett Reservoir at Cosgrove Disinfection Facility (MetroBoston Supply):



MWRA provides disinfection adequate to achieve EPA's requirement of 99.9% inactivation of *Giardia* cysts and 99.99% inactivation of viruses in drinking water using a calculation based on three sample points that DEP approved in June, 1999. CT achievement for *Giardia* assures CT achievement for viruses, which have a lower CT requirement. The concentration (C) of the disinfectant in the water over time (T) yields a measure of the effectiveness of disinfection, CT. The required CT varies with disinfectant type, water temperature, pH, and other factors. MWRA calculates daily CT inactivation rates at maximum flow, as specified by EPA regulations.

Chlorine dose was increased twice in late July to mitigate increasing bacterial levels, raising CT achievement percentages noticeably. CT was met each day in July, as well as every day for the last year.




Quabbin Reservoir at Ware Disinfection Facility (CVA Supply):

CT was met each day in July, as well as every day since reporting began in August, 2000.



Treated Water – pH Results

MWRA adjusts the alkalinity and pH of Wachusett water to reduce its corrosivity in order to minimize the leaching of lead and copper from service lines and home plumbing systems into the water. MWRA targets pH levels between 8.7 and 9.3 to minimize leaching of lead. In order to maintain these levels this summer, the target pH at Shaft 4 increased from 9.3 to 9.4 on 6/1 to counter a seasonal downward drift of pH levels in the distribution system. MWRA staff collects and analyzes samples for pH from 26 community locations on a biweekly schedule to measure pH levels. In July, about 97% of samples were within the target range.



Bacteria & Chlorine Residual Results for Communities in MWRA Testing Program

July 2001

Background

While all communities collect bacteria samples for the TCR, 37 cities and towns (including Westboro State Hospital) use the MWRA Laboratory for Total Coliform Rule compliance testing. These communities collect samples for bacteriological analysis and measure water temperature and chlorine residual at the time of collection. Cambridge conducts their own monitoring. The other 9 MWRA customer communities have their samples tested elsewhere and these towns should be contacted directly for their monthly results.

The SDWA requires that no more than 5% of all samples may be total coliform positive in a month (or that no more than 1 sample be positive when less than 40 samples are collected each month). Public notification is required if this standard is exceeded.

Escherichia coli (*E. coli*) is a specific coliform species that is almost always present in fecal material and whose presence indicates likely bacterial contamination of fecal origin. If *E. coli* are detected in a drinking water sample, this is considered evidence of a critical public health concern. Additional testing is conducted immediately and joint corrective action by DEP, MWRA, and the community is undertaken. Public notification is required if follow-up tests confirm the presence of *E. coli* or total coliform. MWRA considers a disinfectant residual of 0.2 mg/L a minimum target level at all points in the distribution system.

Highlights

22 of the 1890 samples (1.2% system-wide) tested positive for total coliform during the month of July. No samples tested positive for *E. coli*. Public notification was required of Northborough, Weston, and Winthrop.

All of the thirty-six communities that submitted chlorine residual data maintained an average disinfectant residual of at least 0.2 mg/L. Twelve communities had one or more samples with a disinfectant residual lower than 0.2 mg/L. Seven fully-served communities had average residuals lower than last year by 15% or more.

TCR results by Community								
Town	Samples Tested for Coliform (a)	Total Coliform # (%) Positive	E.coli % Positive	Public Notification Required?	July 2001 Minimum Chlorine Residual (mg/L)	July 2000 Minimum Chlorine Residual (mg/L)	July 2001 Average Chlorine Residual (mg/L)	July 2000 Average Chlorine Residual (mg/L)
ARLINGTON	56	0 (0%)	0.0%		0.09	0.12	0.82	1.09
BELMONT	40	0 (0%)	0.0%		0.05	0.10	0.81	1.22
BOSTON	252	0 (0%)	0.0%		0.16	0.11	1.44	1.65
BROOKLINE	85	0 (0%)	0.0%		1.10	0.90	1.62	1.86
CHELSEA	40	0 (0%)	0.0%		0.01	0.16	1.24	1.53
EVERETT	50	0 (0%)	0.0%		1.00	0.30	1.46	1.33
FRAMINGHAM (c)	81	3 (3.7%)	0.0%		0.38	0.05	1.40	1.16
LEXINGTON	45	0 (0%)	0.0%		0.60	1.15	1.69	1.77
LYNNFIELD	6	0 (0%)	0.0%		0.80	0.57	1.19	1.23
MALDEN	75	0 (0%)	0.0%		0.07	0.02	1.13	1.06
MARBLEHEAD	24	0 (0%)	0.0%		0.51	0.61	1.26	1.45
MARLBOROUGH (b)(c)	47	0 (0%)	0.0%		0.11	0.16	1.14	0.91
MEDFORD	85	0 (0%)	0.0%		0.10	0.1	1.00	1.13
MELROSE	45	0 (0%)	0.0%		0.10	0.10	1.13	1.18
MILTON	40	0 (0%)	0.0%		0.17	1.01	1.27	1.36
NAHANT	10	0 (0%)	0.0%		0.03	0.03	0.55	0.92
NEEDHAM (b)	50	0 (0%)	0.0%		0.03	0.01	0.96	0.58
NEWTON	88	0 (0%)	0.0%		0.57	1.18	1.47	1.56
NORTHBORO	48	12 (25%)	0.0%	Yes	1.06		1.93	
NORWOOD	50	0 (0%)	0.0%		0.05	0.05	0.57	0.61
QUINCY	102	0 (0%)	0.0%		0.20	0.10	1.31	1.41
REVERE	52	0 (0%)	0.0%		0.76	0.26	1.38	1.47
SAUGUS	40	0 (0%)	0.0%		1.23	1.60	1.51	1.69
SOMERVILLE	83	1 (1.2%)	0.0%		0.30	0.10	1.10	0.82
SOUTHBORO (c)	11	0 (0%)	0.0%		0.21	0.30	0.91	0.99
STONEHAM	28	0 (0%)	0.0%		0.83	1.40	1.34	1.65
SWAMPSCOTT	18	0 (0%)	0.0%		0.53	0.46	0.89	1.06
WAKEFIELD (b)	44	0 (0%)	0.0%		0.17	0.02	0.86	1.12
WALTHAM	68	0 (0%)	0.0%		0.50	0.50	1.34	1.56
WATERTOWN	40	0 (0%)	0.0%		0.50	0.20	1.28	1.11
WELLESLEY (b)	33	0 (0%)	0.0%		0.20	0.10	0.55	0.45
WESTBORO HOSPITAL	5	1 (20%)	0.0%					
WESTON (c)	24	2 (8.3%)	0.0%	Yes	0.15	0.20	1.02	0.82
WINCHESTER (b)	25	0 (0%)	0.0%		0.08	0.07	0.67	0.97
WINTHROP	30	3 (10%)	0.0%	Yes	0.40	0.40	1.10	1.43
WOBURN (b)	70	0 (0%)	0.0%		0.04	0.12	0.59	1.13
Total:	1890	22 (1.2%)						

(a) The number of samples collected depends on the population served and the number of repeat samples required.

(b) These communities are partially supplied, and may mix their chlorinated supply with MWRA chloraminated supply.

(c) These communities chloraminate

Treated Water - Disinfection By-Product (DBP) Levels in Communities

July 2001


Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAAs) are by-products of disinfection treatment with chlorine. Chlorination levels, the presence of organic precursors, pH levels, the contact time of water with chlorine used for disinfection, and temperature all affect TTHM and HAA levels. DBPs are of concern due to their potential adverse health effects at high levels. EPA recently established new running annual average standards of 80 ug/L for TTHMs and 60 ug/L for HAA 5 that take effect January 2002. DEP requires that compliance samples be collected quarterly. MWRA samples weekly at some locations, monthly and quarterly at others. **Metro Boston numbers are used for compliance purposes**; results presented below from CVA and MetroWest sites enable MWRA staff to monitor control of MWRA treatment processes. Individual CVA and MetroWest communities are responsible for their own compliance monitoring and reporting. They must be contacted directly for their results.

TTHM levels are above those of last year in Metropolitan Boston, but the running annual average for TTHMs, represented in the graph at the top left of the page, remained below both current and future standards. Average HAA 5 levels are somewhat below those of last year in all three regions. The running annual averages for HAA5 and are all below both current and future standards.

TOTAL TRIHALOMETHANES

TTHM Running Annual Averages








For CVA, MetroWest, and Metro Boston Sites



HALOACETIC ACIDS

HAA Running Annual Averages

For CVA, MetroWest, and Metro Boston Sites



MWRA Monthly Water Quality Analysis

July 2001

This page provides information on water quality at six locations in the MWRA transmission system. Results reflect a "snapshot" in time and may not represent typical conditions. Elevated levels of a particular parameter may occur from time to time. MWRA staff review these numbers carefully and follow-up unusual results by re-analyzing samples, collecting new samples, or auditing sample sites. More rigorous daily or weekly monitoring of select parameters at these and other locations provides a better overall picture of water quality and is reported for some parameters elsewhere in this document.

Component	CVA System →		Metropolitan Boston →				Standards →		
	Quabbin Reservoir at Ware Disinfection Facility (Raw)	Nash Hill Storage Tanks (Treated)	Wachusett Reservoir at Cosgrove Intake (Raw)	ICC, Marlboro (Treated)	Comm Ave., Newton (Treated)	Shaft 9A, Malden (Treated)	MCL Standard	Units	Exceedance
Alkalinity	2.8	3.3	5.2	31	30	28.8		MG/L	
Aluminum	< 15	< 15	18.4	20.4	18.3	18.3	50-200 (a)	UG/L	NO
Ammonia-N (j)	0.005	< 0.005	0.024	0.006	0.368	0.308		MG/L	
Antimony	< 0.9	< 0.9	< 0.9	< 0.9	< 0.9	< 0.9		UG/L	
Arsenic	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	50 (b)	UG/L	NO
Barium	6.28	6.09	9.6	9.49	9.31	10.1	2000 (b)	UG/L	NO
Beryllium	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	4 (b)	UG/L	NO
Bromate	< 2.5	< 2.5	< 2.5	< 2.5	< 2.5	< 2.5	10	UG/L	NO
Bromide	11.6	< 2.5	13.2	8.22	6.8	5.8		UG/L	
Cadmium	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	5 (b)	UG/L	NO
Calcium	2110	2220	4390	4330	4330	4730		UG/L	
Chloride	5.8	7.2	21.6	22.9	24.2	23.7	250 (a)	MG/L	NO
Chlorine, Free	-	0.37	-	0.25	0.08	0.16		MG/L	
Chlorine, Total	-	-	-	0.38	1.92	1.62		MG/L	
Chromium	< 0.6	< 0.6	< 0.6	< 0.6	< 0.6	< 0.6	100 (b)	UG/L	NO
Coliform, Fecal, MF Method	0 (h)	-	5	-	-	-	20 (c) 0 (d)	CFU/100 mL	NO
Coliform, Total, MF Method (g)	59	0	0	0	0	0	100 (c) 0 (d)	CFU/100 mL	NO
Color	3	3	17	12	15	18	15 (a)	C.U.	YES
Copper **	1.0	10.9	3.7	5.2	34.2	3.8	1300 (b)	UG/L	NO
Cyanide	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	0.2 (b)	MG/L	NO
Fluoride	< 0.02	< 0.02	< 0.02	1.04	0.98	1.01	4 (b)	MG/L	NO
Hardness	7.3	7.6	14.4	14.2	14.2	15.4		MG/L	
Iron **	6.1	7.2	36.8	33.5	29.2	25.3	300 (a)	UG/L	NO
Lead	< 1.2	< 1.2	< 1.2	< 1.2	< 1.2	< 1.2	15 (b)	UG/L	NO
Magnesium	500	490	834	828	814	874		UG/L	
Manganese	1.4	4.0	6.3	8.6	7.0	6.1	50 (a)	UG/L	NO
Mercury	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	2 (b)	UG/L	NO
Nickel	1.57	< 1	< 1	< 1	< 1	< 1		UG/L	
Nitrate-N (i)	< 0.005	0.006	0.103	0.124	0.114	0.126	10 (b)	MG/L	NO
Nitrite (j)	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005		MG/L	
Orthophosphate (j)	< 0.0025	< 0.0025	0.003	0.006	0.006	0.006		MG/L	
pH	7.3	7.3	6.7	8.9	9.1	9.0		S.U.	
Potassium	478	478	919	922	930	933		UG/L	
Selenium	< 0.9	< 0.9	< 0.9	< 0.9	< 0.9	< 0.9	50 (b)	UG/L	NO
Silica (SiO2)	1400	1540	2410	3120	2390	3210		UG/L	
Silver	< 0.4	< 0.4	< 0.4	< 0.4	< 0.4	< 0.4	100 (a)	UG/L	NO
Sodium	4.0	4.9	12.0	25.6	25.5	25.6		MG/L	
Specific Conductance	41	46	108	168	161	164		UMHO/C	
Standard Plate Count, HPC (48 Hrs @ 35C)	(l)	(l)	64	3	1	8	500 (d)	CFU/mL	NO
Sulfate (SO4)	5.6	5.6	7.1	7.2	7.2	7.2		MG/L	
Thallium	< 1	< 1	< 1	< 1	< 1	< 1		UG/L	
Total Dissolved Solids	29	34	72	93	95	92		MG/L	
Total Organic Carbon	2.08	1.92	2.91	2.78	2.87	3.07		MG/L	
Total Phosphorus	0.008	0.005	0.008	0.016	0.014	0.011		MG/L	
Trihalomethanes, Total (f)	-	36	-	61	77	84	100 (b) (e)	UG/L	NO
Turbidity	0.40	0.44	0.50	0.55	0.38	0.48	1 (c)	NTU	NO
UV-254	0.02	0.02	0.068	0.053	0.059	0.06		A	
Zinc **	2.3	3.4	3.2	3.2	8.7	2.5	5000 (a)	UG/L	NO

(a) = Secondary MCL standard (aesthetic related). DEP "Drinking Water Regulations", 310CMR 22.00.

(b) = Primary MCL standard (health related). DEP "Drinking Water Regulations", 310CMR 22.00.

(c) = Primary MCL standard (health related), applies to source water only. DEP "Drinking Water Regulations", 310CMR 22.00.

(d) = Primary MCL standard (health related). DEP "Drinking Water Regulations", 310CMR 22.00. Applies to samples downstream of Wachusett and Quabbin Reservoirs.

(e) = THM compliance is based on a running annual average of samples collected at DEP approved locations. A new standard of 80 UG/L goes into effect in January 2002.

(f) = Average TTHM result for weekly samples collected in the month of July 2001.

(g) - Confirmed results only are presented.

(h) Result from sample taken by MDC at Winsor Power Station. A lab accident prevents results from WDF being reported.

(i) No HPC samples taken on 7/2/01. Results from three other samples during July average 39 at WDF, 25 at Nash Hill Tanks.

(j) Results from samples taken at WDF, Nash Hill, Comm Ave., & Shaft 9A come from tests performed after short holding time had expired on July 3rd.

MCL = Maximum Contaminant Level

C.U. = Color Unit

CFU = Colony Forming Unit

NTU = Nephelometric Turbidity Unit

S.U. = Standard Units

MG/L = milligrams per liter = parts per million

HPC = Heterotrophic Plate Count

UG/L = micrograms per liter = parts per billion

< = less than method detection limit

umhos = ohms/1000

NS = No sample

** = Metal results may be elevated due to local plumbing at the sample tap.

Inv Res = Invalid sample result

Most results are based on single grab samples collected on July 2 & 3, 2001 and analyzed by MWRA and contract laboratories.