



# Deer Island Operations



## September 2021 - FY22



September's Dry Day Flow is the average of all dry weather influent flows over the previous 365 days from 10/1/2020 to 9/30/2021. The Dry Day Flow for the month was 294.7 MGD, well below the permit limit of 436 MGD. The Dry Day Flow has been increasing since July due to much-higher-than expected plant flows during the last three (3) months resulting from two-and-a-half times greater than expected rainfall.

In September, all pH measurements were fairly typical for the season and within permit limits.

pH is a measure of the acidity or basicity of the effluent. Small fluctuations in pH do not have an adverse effect on marine environments. Because pure oxygen is used in the activated sludge reactors, the effluent pH tends to be at the lower range.





In September, both the weekly and monthly concentrations of TSS were below permit limits.

In September, both the weekly and monthly concentrations of cBOD were well below permit limits.

TSS, or Total Suspended Solids, in the effluent is a measure of the amount of solids that remain suspended after treatment.

cBOD, or Carbonaceous Biochemical Oxygen Demand, is a measure of the amount of dissolved oxygen required for the decomposition of organic materials in the environment.



In September, both the maximum daily and monthly concentrations of TCR were below permit limits. The TCR Monthly Avg and the TCR Daily Max values were non-detectable at 40 ug/L for July through September. Therefore, both parameters appear to be represented by the same trendline in the above graph.

In September, all permit conditions for Fecal Coliform were met. Fecal Coliform is an indicator for the possible presence of pathogens. The levels of these bacteria after disinfection show how effectively the plant is inactivating many forms of disease-causing microorganisms.

TCR, or Total Chlorine Residual, in the effluent is a measure of the amount of chlorine that remains after the disinfection/dechlorination process. If the chlorine residual in the effluent is too high, it may threaten marine organisms.

There are four (4) conditions in the permit that must be met: daily geometric; weekly geometric; 10% of all samples in a month; and greater than three (3) consecutive samples not to exceed 14,000 colonies/100mL.