

Massachusetts
Water Resources Authority

Industrial Waste Report



October 2024

Industrial Waste Report

Number 40

October 2024

Frederick A. Laskey
Executive Director

David W. Coppes
Chief Operating Officer

Rebecca Weidman
Deputy Chief Operating Officer

Matthew Dam
Director, Toxic Reduction and Control

Tracy McGrath
Senior Program Manager, Compliance

MASSACHUSETTS WATER RESOURCES AUTHORITY

NPDES Permit Number MA0103284
State Permit Number M-44

NPDES Permit Number MAG590033
State Permit Number MAG590033



FY 2024 Annual Report

Table of Contents

	Executive Summary	i
I.	Pretreatment Program Activities and Results	1
	Industrial Users	1
	Permitting	2
	Inspections	2
	Monitoring	3
	Enforcement	4
	Information Systems	5
	Legal Support.....	5
	Local Limits	6
	Emergency Response	6
	Pass-Through and Interference	7
	Pretreatment Program Resources	7
	Budget	8
	Program Cost Recovery	8
II.	Pollutant Analysis and Comparison to Environmental Standards	9
	Priority Pollutant Scans.....	9
	Toxicity	11
	Residuals Quality	12

FY 2024 TRAC Annual Report

Table of Appendices

- A. SIU Data:
 - Permit number and date issued*
 - Sample location descriptions*
 - Reasons for SIU status*
 - SNC Status*
 - Inspection and monitoring dates*
 - Enforcement actions*
 - Deadline for compliance with schedules*
 - NOV dates*
 - Administrative order dates*
 - Dates and amounts of penalties assessed*
- B. Non-SIU Permitted Industrial Sewer Users
 - Permit category*
 - Sample location descriptions*
 - Sampling requirements*
 - Discharge violations*
 - Enforcement actions*
- C. Significant Industrial Users in Significant Noncompliance
- D. Former Significant Industrial Users
- E. Gas/Oil Separator Warning Letters
- F. Penalties Assessed and Collected
- G. TRAC Staff
- H. Priority Pollutant Scan Results and Comparison of Influent and Effluent to Established standards
Deer Island
- I. Priority Pollutant Scan Results and Comparison of Influent and Effluent to Established standards
Clinton
- J. Effluent Toxicity Test Results
- K. Comparison of Sludge Quality to EPA and State Standards
- L. Summary of EPA program statistics and EPA Industrial Pretreatment Program
Summary Report Form, *Metropolitan Boston Service Area, Clinton Service Area*
- M. Local Limits
 - Metropolitan Area: Corrected MAHLs based on DITP Recycle Stream Loadings (2001) and Discharge Limitations/Local Limits from the MWRA Sewer Use Rules and Regulations (Metropolitan Area)*
 - Clinton Area: Discharge Limitations/Local Limits from the MWRA Sewer Use Rules and Regulations (specific to Clinton)*

Executive Summary

This Industrial Pretreatment Program Annual Report is provided pursuant to 40 CFR 403.12(i) and Massachusetts Water Resources Authority's (MWRA's) National Pollutant Discharge Elimination System (NPDES) Permit numbers MA0103284 and MAG590033. It covers the reporting period of July 1, 2023 through June 30, 2024 (Fiscal Year (FY) 2024).

Executive Summary and Program Highlights

The FY24 report documents MWRA's ongoing efforts to implement the requirements of 40 CFR Part 403, General Pretreatment Regulations. Some highlights from the MWRA's Toxic Reduction and Control (TRAC) Department's FY24 activities in the Metropolitan Boston and Clinton sewerage services areas are included below.

MWRA's TRAC Department is responsible for implementing MWRA's industrial pretreatment program. Fiscal year 2024 presented similar staffing challenges as FY23. A small re-organization to address necessary staffing needs and a large turnover in FY24 led to many vacancies and promotions within the department. Although this created new opportunities for staff in the department, it meant additional resources were needed for hiring and training. Despite these resource challenges, TRAC was able to inspect all SIUs and perform all required SIU monitoring.

Significant Industrial Users: The greatest number of facilities designated as Significant Industrial Users (SIUs) in MWRA's sewer service areas during FY24 was 180, three of which discharged to the Clinton Wastewater Treatment Plant. At the end of the fiscal year, the number of SIUs was 177. TRAC staff inspected 180 SIUs and sampled 156 SIUs. In FY24, 24 SIUs were not sampled for the following reasons: five SIUs did not discharge during the year; and, the remaining 19 SIUs hold non-discharging SIU permits and therefore cannot be sampled by MWRA. The number of SIUs in Significant Noncompliance (SNC) in FY24 was 29, an increase from the 28 SIUs in SNC during FY23.

Permitting: TRAC issued or renewed a total of 452 industrial permits during FY24, including 86 permits to SIUs located in the Metropolitan Boston sewerage service area. Ninety four percent of the SIU permits were issued within 120 days of their application received dates or previous expiration dates, whichever was later, and 100 percent were issued within 180 days. One SIU and one Non-SIU permit were issued to industries in the Clinton service area during FY24. TRAC issued one of the Clinton service area permits outside the 90-day timeframe due to late payment of permit fees by the permittee.

Monitoring and Inspections: TRAC staff completed 1,453 sampling events at industrial/commercial facilities and 1,543 non-industrial sampling events (e.g., combined sewer overflow and other special projects). TRAC staff also completed a total of 1,148 inspections of industrial facilities; 403 inspections of gas/oil separators at vehicle maintenance facilities and other garages; and 118 inspections of septage haulers and septage receiving sites.

Enforcement Program: TRAC issued a total of 230 early enforcement actions (Notices of Violations and Traps Warning Letters) and 68 higher-level enforcement actions (62 Notices of Noncompliance, two Administrative Orders, three Penalty Assessment Notices, and one Demand Letter) to industrial and commercial facilities. SIUs received 95 Notices of Violation and 15 higher level enforcement actions (14 Notices of Noncompliance and one Penalty Assessment Notice). TRAC identified 17 gas/oil separators requiring Trap Warning Letters due to identified issues with maintenance or accessibility. The number of enforcement actions TRAC issues varies from year to year.

FY24 Accomplishments:

Amendments to MWRA Regulations for Sewer Use (360 CMR 10.000)

In FY24, TRAC amended MWRA's Regulations for Sewer Use (360 CMR 10.000). Changes to the regulations incorporated requirements and recommendations from a 2021 EPA audit; increases to implementation and annual charges paid by permit holders by three percent annually in FY25 through FY29; and changes to clean up minor typographical errors and unclear language. Amendments to the regulations were made available for public comment, MWRA hosted one public hearing, and the amendments were subsequently approved by the MWRA Board of Directors prior to being published in the Code of Massachusetts Regulations on July 19, 2024.

Per- and Polyfluoroalkyl Substances (PFAS) Updates

MWRA's Clinton NPDES permit requires that PFAS samples are collected quarterly from the treatment facility. It also requires annual PFAS sampling at SIUs and other industry types known or expected to contain PFAS in their wastewater. MWRA does anticipate that these requirements will be included in the next NPDES permit for the Deer Island Treatment Plant. In anticipation of these new requirement, TRAC updated the Sewer Use Discharge Permit applications to require all industries to test for Per- and Polyfluoroalkyl substances (PFAS) when submitting a permit application. This data will help to provide a better picture of industrial PFAS contributions to the sewer system. In addition to the industrial data, TRAC has collect PFAS samples throughout the collection system. This data will allow for a comprehensive Local Limits review and TRAC is exploring establishing a PFAS local limit as part of an upcoming Local Limits review for the Deer Island Treatment Plant sewerage service area.

Cross-Media Reporting Regulation Compliance

In accordance with EPA's Cross-Media Reporting Regulation (CROMERR), in FY23, TRAC successfully registered all laboratories submitting wastewater sample results on behalf of TRAC permitted industrial users with an EPA Shared CROMERR Services user account. This resulted in all data received in PIMS (MWRA's pretreatment information management system) becoming CROMERR compliant. In FY24, EPA approved the electronic receipt of self-monitoring data, making MWRA one of the first programs in the country to meet the CROMERR regulatory requirement.

TRAC Reorganization and Staffing

In FY24 TRAC completed a small reorganization. The reorganization addressed necessary succession planning related to the expected retirement of key TRAC personnel. This redistribution of personnel will better utilize existing resources by providing much needed cross-functionality and redundancy within the construction

permitting group. TRAC ended FY24 with 8 vacancies due to retirements, added positions, and promotions. All vacancies are anticipated to be filled in FY25.

Section I.

Pretreatment Program Activities and Results

Section I. Pretreatment Program Activities and Results

A detailed accounting of the pretreatment program activities and accomplishments for MWRA's Industrial Users (including Significant Industrial Users or SIUs), during FY24 is presented below.

Appendix A contains information on MWRA's SIUs, and provides, in its key, criteria for SIU status and compliance status codes. The Appendix provides information about why the facility is a SIU and whether it is in compliance with reporting requirements, categorical standards and local limits, dates of MWRA inspections and monitoring events for each facility, and what, if any, enforcement actions were taken by MWRA against the facility. Appendix B details all permitted industrial users not classified as SIUs. The information includes a description of the sampling locations and sampling requirements for each industry, any discharge violations during the year, and all enforcement actions taken against them during the year. Each SIU is inspected at least once per fiscal year and each SIU with a discharge to the sewer system is sampled at least once per fiscal year.

Statistics on MWRA's SIUs and the number of SIUs in Significant Noncompliance (SNC) for FY24 for the Clinton and the Metropolitan Boston sewerage service areas are summarized below. The list of SIUs in SNC can be found in Appendix C.

Industrial Users in FY24

Total number of permitted industrial users = 2,253

- The number of SIUs = 180 (3 in Clinton)
- The number of SIUs on June 30, 2024 = 177 (3 in Clinton)
- The number of SIUs that were Categorical Industrial Users (CIUs) = 69 (1 in Clinton)
- Industries categorized as SIUs because of process flows of at least 25,000 gallons per day (gpd) = 49 (0 in Clinton)
- Industries categorized as SIUs for Potential To Violate (PTV) = 97 (2 in Clinton)
The number of SIUs in SNC = 29 (0 in Clinton)
- The number of industries in SNC for reporting violations only = 6 (0 in Clinton)
- The number of SIUs in SNC for discharge violations = 24 (0 in Clinton)
- The number of SIUs in SNC in the 4th Quarter = 10

The EPA Pretreatment Annual Report Summary forms are attached to the end of this report as Appendix L. A list of permitted users that were SIUs in FY23 but not in FY24 is attached as Appendix D.

Permitting

Appendix A provides permit issuance and expiration dates for all SIUs. In FY24, 86 SIU permits were issued in the Metropolitan Boston sewerage service area. TRAC issued 94 percent of these SIU permits (81 permits) within 120 days of their application received dates or previous expiration dates, whichever was later, and 100 percent (86 permits) within 180 days of their application received dates or previous expiration dates, whichever was later. One SIU and one Non-SIU permits were issued to industries in the Clinton sewerage service area during FY24. TRAC issued one SIU permit outside the 90-day timeframe due to late payment of permit fees by the permittee.

During FY24, TRAC completed the following permitting activities:

- Total industrial permits issued = 452
- Total industrial permit renewals = 349, including:
 - 104 Group Permits for Food Processing
- Industrial permit renewals or issued to SIUs = 87
- Industrial permits issued to new dischargers = 103, including:
 - 22 Group Permits for Dental Discharges
 - 4 Group Permits for Food Processing
- Industrial permits revised = 23
- Municipal permit renewals = 45
- Temporary Construction Dewatering permits issued or renewed = 18
- Permits issued to municipal drinking water treatment plants = 4



Figure 1: Annual Significant Industrial User Inspection (large amalgam separator system)

Inspections

Appendix A provides dates of inspections for all SIUs. During FY24, TRAC completed the following inspection activities:



Figure 2: Annual Inspection of a landfill

Total Industrial Facility visits = 1,148

- Annual inspections of SIUs = 180
- Other SIU inspections¹ = 171
- Non-SIU inspections = 797
- Audits of G1 (photodevelopers and printers) facilities = 1
- Audits of G2 (food processors) facilities conducted = 22
- Industrial Survey inspections² = 56
- Visits with no inspections³ = 10

Septage facility inspections = 118

- Septage receiving site inspections = 113
- Septage hauler inspections = 5

Gas/oil separator (trap) inspections = 403

- Full trap inspections = 157
- New trap inspections = 199
- Trap visits with no inspection⁴ = 47

Monitoring

During FY24, TRAC's sampling staff conducted routine and emergency sampling activities for the pretreatment program as well as for other MWRA programs. Appendix A provides information on the dates of all MWRA sampling events for each SIU.



Figure 3: Monitoring of a Significant Industrial User

¹ Other SIU inspections include those conducted for permitting, follow-up to a prior inspection, enforcement/compliance inspections, sample location inspections, spot inspections and/or to gather additional information from facility contacts.

² Industrial Survey inspections include visits to newly identified addresses with potential industrial or commercial sewer discharges and visits to addresses confirmed at one time to have had only sanitary discharges for re-confirmation of status.

³ These visits include visits to deliver documents and/or confirm address/contact information.

⁴ Trap visits with no inspections result from facilities that had traps in the past but have since had them removed, visits when the trap was inaccessible or a knowledgeable contact was unavailable, or visits when the facility was found closed at the time of the visit.

A summary of sampling activities completed by the staff follows:

- SIUs with flow sampled at least once⁵= 156
- Number of sample locations (connections) at SIUs sampled at least once = 375
- Number of sample locations at SIUs that were sampled more than once = 180
- Total number of sampling events at SIUs = 1,116
- Non-SIUs sampled once = 138
- Number of sample locations at Non-SIUs sampled = 182
- Total number of sampling events at Non-SIUs = 337
- Total number of industries sampled = 294
- Total number of sampling events at all industries = 1,453
- Sampling events in support of NPDES permits = 332
- Sampling events in response to emergencies= 4⁶
- Sampling events for the MWRA Local Limits program = 230
- Sampling events for special projects = 855
- Total number of non-industrial events = 1,543

Enforcement

In FY24, TRAC issued a total of 230 early enforcement actions (Notices of Violations) to industrial and commercial users of the sewer system and 68 higher level enforcement actions to regulated facilities. TRAC assessed a total of \$70,100 in penalties to permitted industrial users (\$30,100 to an SIU) and collected a total of \$130,100 in penalties during the fiscal year, (\$90,100 from 2 SIUS). Penalties assessed are not always collected during the same fiscal year. Some reasons may be that the penalty was assessed late in the fiscal year and paid in the following fiscal year or the penalty assessment was appealed and is working through the adjudicatory process.

In FY24, TRAC identified 17 gas/oil separators requiring Trap Warning Letters due to identified issues with maintenance or accessibility. In all of these cases, the facility was notified verbally at the time of the inspection that maintenance was required to be performed. The list of recipients that received follow up warning letters have been included in Appendix E to demonstrate that they have since been issued. The types of actions and the number of each type are listed below. Appendices A and B explain the various types of enforcement actions, provide information on which facilities received enforcement actions, and when and what type(s) of actions. Appendix F provides a list of penalties assessed and collected in FY24.

⁵ Five facilities were not sampled during FY24; Emergent Biosolutions, Inc. and MBTA Wellington were not sampled because they did not discharge in FY24, Tritown and City of Newton were not sampled because they are still under construction, MBTA Codman was not sampled because it did not discharge and changed categories from category 1 to category 4.

⁶ Columbus Park HW odor 1/26/24, Chelsea facility catch basin suspected bacteria 2/12/24, Metro Operations Arlington water sample 6/14/24, WW Operations Delauri PS odor 6/26/24

- Notices of Violation issued = 230 (95 to SIUs; 0 in Clinton)
- Warning letters about gas/oil separator maintenance and accessibility = 17 (Appendix E)
- Notices of Noncompliance issued = 62 (14 to SIUs)
- Administrative Orders = 2 (0 to SIU)
- Demand Letters = 1 (0 to an SIU)
- Ruling on Request for Reconsideration = 3 (2 to SIUs)
- Return to Permit Letters = 8 (7 to SIUs)
- Penalty Assessment Notice = 3 (1 to a SIU)
- Total amount of penalties assessed = \$ 70,100 (\$30,100 to 1 to a SIU)
- Total amount of penalties collected = \$130,100 (\$90,100 from 2 SIUs)

Information Systems

MWRA continues to utilize its Pretreatment Information Management System (PIMS) software to manage its pretreatment program. The system continues to be adapted to accommodate pretreatment program requirements. TRAC's in-house information systems staff are responsible for supporting system design and implementation, data entry, quality assurance, and project management and coordination.

EPA's Cross-Media Electronic Reporting (CROMERR) Regulations, promulgated in 2005, provide a legal framework for electronic reporting under Title 40 of the Code of Federal Regulations to EPA and state, tribal and local governments, including MWRA, that are authorized to administer federal programs. The regulation authorizes electronic reporting for environmental programs while creating a level of corporate and individual accountability for those submitting environmental data.

MWRA completed the final stages of implementing its CROMERR compliant WebSMR application for accepting electronic data from laboratories submitting wastewater sampling results on behalf of TRAC permitted industrial users. TRAC successfully registered all laboratories submitting wastewater sample results on behalf of TRAC permitted industrial users with an EPA Shared CROMERR Services user account. This makes all data received in MWRA's Pre-treatment Information Management System CROMERR compliant. In FY24 TRAC requested and received EPA approval for the proposed process of electronic receipt of self-monitoring data.

Legal Support

MWRA's Law Division provides legal and policy advice and counsel to TRAC managers and staff, and represents MWRA in pretreatment-related matters.

In FY24, Law Division work for TRAC included:

- Providing counsel and reviewing and commenting on TRAC penalty assessment notices, and on enforcement orders, notices of noncompliance, and rulings;

- Representing MWRA in requests for reconsideration/administrative appeals of penalty assessment notices, enforcement orders, notices of noncompliance and permits;
- Representing MWRA in settlement negotiations; and
- Tracking bankruptcy filings by MWRA permittees.

Local Limits

In May 2023 the draft Deer Island Treatment Plant (DITP) NPDES Permit was issued. A renewal application for the DITP NPDES permit was submitted in 2005, 6 months in advance of its expiration date. MWRA has provided updated application information to EPA as requested throughout the permitting process. In anticipation of renewal of the DITP NPDES permit, MWRA staff have been sampling since 2005 to support an evaluation of existing Metropolitan Boston sewerage service area local limits. Those limits will be evaluated per EPA requirements established in the Deer Island NPDES Permit upon its renewal.

Emergency Response

TRAC field staff are responsible for responding to emergency events, toxics releases, and spills to the sewer system. These releases may result in Interference (disabling of the treatment plant's facilities/processes), or Pass-Through (discharge of toxics through the treatment works into the receiving waters). Due to the abrupt and often hazardous nature of these events, they generally take precedence over normal monitoring and inspection activities. Chemical and oil spills also pose significant concerns to the collection and treatment systems, due to the possibility of explosion, toxic fumes, and facility damage.

TRAC staff respond to these types of events to assess their potential to affect the sewerage system and downstream facilities. TRAC staff are an integral part of MWRA's emergency response organization and are trained to respond immediately to emergencies posing a threat to public health, worker safety, and facility operation. A TRAC manager and two sampling associates, as well as a fully equipped sampling van are on-call 24 hours a day to respond to reported emergencies.

TRAC emergency responses may be initiated for both short-term, episodic releases and continuing events, which may potentially impact the Authority's collection and treatment system. During FY24 TRAC staff responded to two odor complaints at MWRA facilities, one observed sheen at an MWRA catch basin and one observed sheen in a water chamber. The reports include:

1. On January 26, 2024, TRAC staff responded to an odor complaint at Columbus Park Headworks. TRAC Monitoring staff were dispatched to collect wastewater samples after Wastewater Operations reported a foul odor of an industrial cleaning product. Air monitoring was conducted while in the headworks with no observable readings. Wastewater samples were collected from influent channel #3. All odors subsequently diminished and there were no further reports of odors.

2. On February 12, 2024, Wastewater Operations requested that TRAC staff collect a sample for bacteria from a catch basin from the parking lot at MWRA's Chelsea facility. The sample results were reported to be within normal limits for stormwater.
3. On June 14, 2024, Metro Operations asked TRAC to collect a sample from a valve chamber located in the parking lot of the Ed Burns Arena and Skating Rink. A member of a MWRA valve crew observed a slight sheen on the surface water within the chamber. Samples were collected by TRAC staff and submitted for analysis.
4. On June 26, 2024, TRAC responded to an odor complaint at Delauri Pump station. TRAC staff collected samples after testing the atmosphere within the facility. All odors subsequently diminished.

Pass-Through and Interference

There were no investigations of, nor were there any instances of, Pass-Through or Interference at the Deer Island Wastewater Treatment Plant or the Clinton Wastewater Treatment Plant in FY24.

Pretreatment Program Resources

MWRA's TRAC Department is organized along a functional alignment. During FY24 TRAC completed a small reorganization. The reorganization addresses necessary succession planning related to the expected retirement of key TRAC personnel. This redistribution of personnel will better utilize existing resources by providing much needed cross-functionality and redundancy by creating a construction permitting group. For this reorganization, the Sr. Program Manager, Field Operations will oversee the construction permitting group, the inspections and permitting group and the monitoring group. The Program Manager, Inspection and Permitting will focus on industrial permitting and inspections. The septage and gas/oil separator programs will move to a newly created Program Manager, Construction Permitting which will also have direct supervision over the 8M program. Adding this layer of direct supervision to the 8M program allows the Sr. Program Manager, Field Operations to focus on bigger picture program goals. For FY24 the restructuring had not been complete and the organizational structure prior to the reorganization is below.

Sr. Program Manager for Field Operations and Permitting oversees two Program Managers, one for Monitoring and one for Inspections and Permitting. The Senior Program Manager directly oversees the 8M and Direct Connections Group.

The Inspections Program Manager supervises 9 Industrial Coordinators and 2 Project Managers who conduct inspections and draft industrial permits. In addition three staff who are responsible for implementing MWRA's septage and gas/oil separator

programs. The Monitoring Program Manager oversees 13 monitoring staff who collect industrial and other wastewater samples.

A Sr. Program Manager for Compliance and Enforcement manages four Compliance Coordinators as well as staff dedicated to file and data management. This group is primarily responsible for TRAC's enforcement proceedings. They review sampling data for permit compliance and draft Notices of Violations, Notices of Non-Compliance, calculate the dollar amounts of penalties, as well as oversee higher levels of enforcement in concert with the Legal Department. The Senior Program Manager is also responsible for TRAC's information management system, PIMS.

TRAC has 48 full-time permanent positions (see Appendix G). In FY24, there was significant turnover due to retirements, departures, and promotions, with a total of seven positions successfully backfilled. There are eight vacant positions at this time with plans to fill all vacancies during this fiscal year.

Budget

In FY24, the TRAC Department recovered \$2,991,000 or 57.5% of the Department's actual Current Expense Budget (CEB) spending of \$5,206,000 through permit and monitoring charges.

Program Cost Recovery

MWRA's Incentive and Other Charges Program continues to recover a substantial portion of MWRA's costs of inspecting, monitoring, and permitting industrial sewer users. The total adjusted amount billed under the program in FY24 was \$2,896,431, an increase from \$2,802,082 in FY23. As of September 2024, collections for FY24 bills were at \$2,991,000 (compared to \$2,826,930 in FY23), an approximate 103% recovery of the adjusted amount invoiced. The additional revenue is the result of payment of interest, payment of outstanding permitting and monitoring charges, and new industries opening in the service area. TRAC's revised Sewer Use Regulations (360 CMR 10.000), promulgated September 6, 2019, included a 3 percent increase in all permitting and monitoring charges in FY24. TRAC again revised Sewer Use Regulations (360 CMR 10.000), promulgated July 19, 2024 for the upcoming fiscal year (2025), permitting and monitoring charges will increase by an additional 3 percent.

Section II.

Pollutant Analyses and Comparison to Environmental Standards

Section II. Pollutant Analyses and Comparison to Environmental Standards

The Environmental Quality Department (ENQUAL) evaluates the water quality and biological health of Massachusetts Bay to ensure that the Deer Island discharge does not harm the marine environment. ENQUAL monitors water quality data from Boston Harbor, and the rivers tributary to the harbor, to assess the impacts of Combined Sewer Overflows (CSOs), and to track the effects of the Boston Harbor Project and the long-term CSO control plan on the harbor.

MWRA measures pollutant concentrations in the plant influent to determine if pollutants are present in quantities that could inhibit the proper operation of the treatment facilities, in the effluent to determine the effectiveness of its pollutant control measures and compliance with water quality standards, and in the sludge to ensure it meets beneficial reuse criteria. This section discusses the results of these analyses.

Priority Pollutants Scans

Metropolitan Boston Service Area

MWRA regularly performs scans for priority pollutants on Deer Island Treatment Plant (DITP) influent and effluent samples. Additional non-priority pollutants are analyzed in support of meeting receiving water quality goals and the beneficial reuse standards for plant biosolids.

Appendix H presents the analyses of influent and effluent samples from DITP using both EPA-approved methods and for some organic contaminants, non-EPA-approved ultra-low detection methods. Results are presented as flow-weighted monthly averages of all the samples analyzed during the fiscal year. For levels below reporting limits, one-half of the reporting limit for inorganic compounds or one-tenth of the quantitation limit for organic compounds was substituted to calculate concentrations. This allows the data to be used without the less conservative assumption that non-detect values are zero. Analyses performed using non-EPA-approved ultra-low detection methods generally confirm that this methodology for handling non-detects is a conservative way to estimate the concentrations of otherwise non-detected pollutants.

Influent: As would be expected for a large urban system, food residues (fats, oils and grease), petroleum hydrocarbons, nutrients, cyanide, and most metals are detected regularly. Of the samples analyzed using EPA-approved detection methods for volatile and semi-volatile organic compounds, acetone (used in paints, varnishes, and lacquers manufacturing) and benzoic acid (used primarily as a food preservative and in pharmaceutical and cosmetic preparations) were detected regularly. 2-butanone (methyl ethyl ketone; widely used as a solvent and intermediate product in the manufacture of ketones and amines) and benzyl alcohol (used as a general solvent for inks, paints, perfumes, and waxes) and were detected in 31 and 34 percent of the samples analyzed, respectively. 4-methylphenol (*p*-cresol) (an intermediate in the manufacture of chemicals, dyes, plastics, and antioxidants) was detected in 16 percent of samples. Tetrachloroethene (used in removing grease from metals and in the production of some textiles) and phenol (used in plastics synthesis) were detected at frequencies of three out of 48 samples and three out of 44 samples respectively. Chloroform (disinfection byproduct) and toluene (a solvent

and a chemical used in the manufacture of benzene derivatives, dyes, and perfumes) were each detected in one of 48 samples.

Of the pesticides and PCBs in tests with EPA-approved methods, total AMP (Ambient Monitoring Plan) PCBs (20 PCB congeners specific to the Ambient Monitoring Plan in the DITP NPDES permit) were detected in 100 percent of the samples tested. Alpha-chlordane and gamma-chlordane were detected in 32 and 14 percent of the samples analyzed respectively.

When characteristics of DITP influent are compared to literature inhibition values, analysis shows that none of the parameters exceeded the thresholds in FY24. DITP did not experience any problems with process inhibition in either the sludge digestion or the activated sludge process during FY24. Appendix H includes a table comparing DITP's influent monthly average concentrations to inhibition values.

Effluent: The activated sludge secondary process removes most of the organic pollutants, pesticides and PCBs from the effluent. Of the samples analyzed with EPA-approved methods, total AMP PCBs were detected regularly. The activated sludge process also effectively removes metals. Metals removed at a rate of 75 percent or greater included mercury, aluminum, copper, iron, zinc, lead, cadmium, chromium, and silver. Nickel and arsenic were removed at rates of 35 percent and 18 percent respectively. Cyanide was not detected in any of the collected effluent samples.

The DITP NPDES permit has no numerical permit limits for any priority pollutants except for arochlors because of the low concentrations in the effluent and high available dilution. Toxic contaminants generally meet water quality criteria in the effluent even before dilution. Copper is the only parameter that requires the use of a dilution factor to meet water quality criteria. MWRA's NPDES permit allows for a 50:1 dilution for determining compliance with acute water quality standards and a 70:1 dilution for chronic water quality standards. Appendix H includes tables comparing DITP's effluent to both acute and chronic water quality standards.

Clinton and Lancaster Service Area

MWRA also samples the Clinton Treatment Plant (CLTP) influent and effluent for conventional parameters, nutrients, and certain metals. Appendix I presents the results of these analyses.

Influent: Arsenic and zinc were detected each quarter. Copper was detected three out of four quarters. Aluminum, lead, mercury, and nickel were each detected in one of the quarterly samples analyzed. No other tested metals were detected. Appendix I-2 compares CLTP influent samples to literature inhibition values for its treatment processes. No parameters exceeded the published acute inhibition level for the activated sludge or the sludge digestion processes in FY24.

Effluent: The advanced treatment process at Clinton effectively removes metals as well as phosphorus and ammonia.

Appendix I also includes tables comparing effluent concentrations with both acute and chronic water quality criteria. The CLTP NPDES permit allows for a 1.6:1 dilution for determining compliance with acute and chronic water quality criteria. To be conservative, half the reporting

limit is used when determining compliance with water quality standards for those parameters that were below detection levels. This resulted in four instances when the calculated value was above the cyanide standard, but these were not actual exceedances. Therefore, the CLTP effluent met all of the acute and chronic water quality standards for the Nashua River in FY24.

Before 2011, aluminum levels in the CLTP effluent had the potential to exceed water quality standards when the plant was using aluminum sulfate (alum) for phosphorus removal. In early May 2011, CLTP replaced alum with ferric chloride, which has been as effective at phosphorus removal as aluminum sulfate. Since that time, the effluent concentrations have been well below the water quality criteria of 200 µg/L and 368 µg/L for chronic and acute water quality standards respectively. The 2023 authorization to discharge under the Medium Wastewater Treatment Facilities General Permit requires stringent permit limits on phosphorus year-round and does not include a reporting requirement for aluminum.

The current permit has effluent limits for copper of 11.6 µg/L (average monthly) and 14.0 µg/L (maximum daily). These are more stringent than the site-specific water quality standards, because of anti-backsliding rules. There were no copper concentration exceedances of the effluent limit in FY24.

Toxicity

MWRA tests the acute and chronic toxicity of the DITP effluent every month and the CLTP effluent quarterly. Effluent toxicity provides an overall view of effluent quality, ensuring that the effluent does not adversely affect the receiving waters. The results of the Deer Island and Clinton toxicity tests for FY24 can be found in Appendix J.

Acute toxicity, or LC-50 (lethal concentration 50%), is the concentration of effluent in a sample that kills half of the test organisms over the duration of the test. Acute toxicity tests involve preparing a series of test concentrations by diluting effluent with control water. Groups of test organisms are exposed to each effluent concentration and a control for a specified period. Chronic toxicity, or NOEC (no observed effect concentration), measures the highest effluent concentration at which no observed chronic effects will occur at continuous exposure to test organisms (in a life cycle or partial life cycle). For example, a NOEC limit of 1.5% means that there should be no effect when 1.5% of the sample is effluent and the remainder is dilution water. Chronic tests evaluate toxicity based on sub-lethal effects (growth, reproduction, mortality), exposing test organisms to samples during a sensitive period in the life cycle.

The MWRA DITP permit requires four tests for effluent toxicity testing each month. Two 48-hour acute static toxicity tests using the mysid shrimp (*Americamysis bahia*) and the inland silverside fish (*Menidia beryllina*) measure the short-term lethal effects caused by the effluent. A chronic survival and growth test using *Menidia* and a chronic fertilization test using the sea urchin (*Arbacia punctulata*) both measure subtle toxic impacts over a longer period. Any acute LC-50 below 50% (i.e. less than 50% concentration) or chronic NOEC below 1.5% (i.e. less than 1.5% effluent concentration) would violate the NPDES limit. There were no toxicity permit violations for DITP effluent in FY24.

The CLTP permit requires two tests for effluent toxicity using freshwater daphnid shrimp (*Ceriodaphnia dubia*) each quarter. The first, a 48-hour acute toxicity test, measures potential short-term lethal effects caused by the effluent. The second test includes a chronic survival and reproduction test that measures subtle toxic impacts over a longer period. Any acute LC-50 below 100 percent or chronic NOEC below 62.5 percent (i.e. less than 62.5 percent concentration) would violate the NPDES limit. There were two toxicity permit violations for CLTP effluent in FY24. Both violations occurred in April 2024, one acute and one chronic. Investigations did not yield anything unusual that would explain the toxicities.

Residuals Quality

EPA and the MassDEP regulate the quality of sewage biosolids intended for beneficial use. At the federal level, these products are governed by the Clean Water Act. These regulations establish quality criteria for several metals and for the degree of pathogen reduction. Federal and state regulations have adopted a two-tiered approach to biosolids regulation. Products meeting the strictest standards for all parameters (MassDEP Type I) may be distributed or marketed with few restrictions. Products meeting only the less- prohibitive Type II standards may be used as fertilizer, but additional distribution, use restrictions and management practices apply. FY24, MWRA's biosolids met all state and federal limits.

Federal and state limits for the distribution of biosolids as a MassDEP Type I Sludge with no limitations for land application are outlined in the tables found Appendix K.

Town

Industry name Permit Number, Date last permit issued/expiration date*

Industry Address

National Pretreatment Categorical Standard: *See description below*

MWRA Category: *See description of MWRA categories below*

Sample locations: *Sample location number and description of sampling location. Sample locations coded as “Unregulated” are only subject to MWRA limits. Sample locations coded as “Regulated” are subject to both Federal Categorical standards and MWRA limits.*

Reason for SIU status: *See descriptions of reasons for SIU status below*

SNC: *Yes, if industry was in significant noncompliance. See descriptions of SNC status below. Please note that the SNC quarters listed in Appendix A are inaccurate due to a database problem. Refer to Appendix C for the correct information.*

Inspections: *Dates the MWRA inspected the facility*

Monitoring: *Dates the MWRA took wastewater samples for analysis from the industry’s Sampling locations*

Enforcement Actions: *Dates and type of enforcement actions in the last two fiscal years (see description of enforcement actions below).*

- * No permit issued date indicates that a permit application has been received and is currently in process. If the permit expired date is more than a month or two in the future, the industry is currently permitted but has recently been identified as an SIU and the permit is being reevaluated. If there is no permit expired date, it is a newly identified discharger to the sewer system.

National Pretreatment Categorical Standards:

The number refers to a section and subsection of 40 CFR in which EPA has specified limits on the quantities or concentrations of pollutants that may be discharged. The name after the number is the EPA description of the industrial subcategory to which the specified limits apply. This identification is made by individual sample location. Therefore, an industry may be regulated by more than one subsection. If no number appears here, but the reason for SIU status is CIU, it indicates that the industry has a regulated process, but that there is no flow to the sewer system.

PSes: *Pretreatment Standards for Existing Sources -Existing sources refers to a building, structure, facility or installation whose construction began prior to the date that the standards were proposed.*

PSNs: *Pretreatment Standards for New Sources -New Sources refers to a building, structure, facility or installation whose construction began after the standards were proposed.*

MWRA Category:

- | | |
|-------------|--|
| Category 1: | A sewer user whose process results in a discharge containing one or more substances in a concentration or quantity requiring pretreatment to meet the requirements of federal and local discharge limits. |
| Category 2: | A sewer user whose process results in a discharge containing one or more substances regulated by the MWRA at a concentration and quantity not requiring pretreatment to meet the requirements of federal and local discharge limits. |
| Category 3: | A sewer user whose process results in a discharge not containing a substance regulated by the MWRA or photoprocessors who can meet federal and local discharge limits with silver recovery units. |
| Category 4: | A sewer user without an industrial discharge to the sewer system. |

Reasons for SIU Status:

Possible reasons for an industry to be designated a Significant Industrial User:

- CIU-# An industrial user subject to Categorical Pretreatment Standards under 40 CFR, 403.6 and 40 CFR, Chapter I, subchapter N. Any industry that falls under these categories is considered an SIU whether or not they have flow. These industries are Categorical Industrial Users (CIUs).
- 25K or >25,000 gpd An industry which discharges an average of 25,000 gallons per day or more of process wastewater to the sewer system (excluding sanitary, noncontact cooling and boiler blowdown wastewater;)
- PTV An industry which is designated as such by the MWRA on the basis that the industrial user has a reasonable potential for adversely affecting the operation of the collection system or treatment plant, or violating any pretreatment requirement.

Significant Noncompliance:

Possible reasons for an industry to be in Significant Noncompliance:

- A. Chronic violations of wastewater discharge limits, defined here as those in which 66% or more of all of the measurements taken during a six month period exceed (by any magnitude) the daily maximum limit or the average limit for the same pollutant parameter;
- B. Technical Review Criteria (TRC) violations, defined here as those in which 33% or more of all of the measurements for each pollutant parameter taken during a six month period equal or exceed the product of the daily maximum limit or the average limit times the applicable TRC (TRC=1.4 for BOD, TSS, fats, oil and grease, and 1.2 for all other pollutants except for pH);
- C. Any other violation of a pretreatment effluent limit (daily maximum or longer term average) that the MWRA determines has caused, alone or in combination with other discharges, interference or pass through (including endangering the health of treatment plant personnel or the general public);
- D. Any discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment or has resulted in the MWRA's exercise of its emergency Authority to halt or prevent such discharge;
- E1. Failure to meet, within 90 days after the schedule date, a permit milestone for starting construction.
- E2. Failure to meet, within 90 days after the schedule date, a permit milestone for completing construction.
- E3. Failure to meet, within 90 days after the schedule date, a permit milestone for attaining final compliance.
- E4. Failure to meet, within 90 days after the schedule date, an enforcement milestone contained in a permit or enforcement order for starting construction.
- E5. Failure to meet, within ninety days after the schedule date, a compliance milestone contained in an enforcement order for completing construction.
- E6. Failure to meet, within ninety days after the schedule date, a compliance milestone contained in an enforcement order for attaining final compliance.

- F1. Failure to provide, within 45 days after the due date, required baseline monitoring reports.
- F2. Failure to provide, within 45 days after the due date, required 90 day compliance reports.
- F3. Failure to provide, within 45 days after the due date, required self-monitoring reports.
- F4. Failure to provide, within 45 days after the due date, required compliance schedule reports.
- G. Failure to accurately report noncompliance;
- H. Any other violation or group of violations which the MWRA determines will adversely affect the operation or implementation of the pretreatment program. The MWRA has used this description for those industries that failed to submit permit applications in accordance with the regulations.

Enforcement Actions:

The type of enforcement action selected to respond to a violation depends on a variety of factors including, but not necessarily limited to: magnitude of the violations, duration of the violations, compliance history of the sewer user, perceived good faith of the user, clarity of the user's responsibility, and, where such issues arise, the effects of the violation on the receiving waters and/or the treatment works.

TRAC's enforcement options found in this report include:

Notice of Violation (NOV)

This enforcement action is a letter to the user describing the violation and asking the user to identify the reason for the violation and what steps it will take to ensure that the violation will not recur.

Notice of Noncompliance/Order to Take Corrective Action (NON/OTCA):

This formal, written notice and order identifies which requirements the user has violated and specifies deadlines by which the user must come into compliance. It requires increased sampling and reporting of discharges by the user and the submission of a detailed report by the user on how and when it intends to achieve and maintain compliance with MWRA regulations.

Enforcement Order (EO):

Issued by the MWRA to an industry outlining violations and the actions the violator must take.

Penalty Assessment Notice (PAN):

Formal, written notice to an industry assessing civil monetary penalties.

Supplemental Order to Comply (SOC):

A further order, usually issued after a previous order fails to bring an industry into compliance. Often issued with a Penalty Assessment Notice (PAN).

Administrative Orders (AO):

These formal written orders include Enforcement Orders, Supplemental Orders, Orders to Take Corrective Action, Orders to Comply, and Cease and Desist Orders. They are sent as follow-ups to *NON/OTCA*'s as new information is obtained, or are sent in other instances where violations of MWRA regulations are taking place or threaten to take place. They often require increased sampling and reporting of discharges by the user and detailed schedules to achieve or maintain compliance with MWRA requirements. They may contain an order to stop a discharge or a violation.

Notice of Proposed Permit Revocation (NPPR):

Issued to an industry when violations are so severe or repetitive, that the MWRA must resort to revoking the industry's permit.

Ruling on Request for Reconsideration of NON/OTCA/EO/SOC/NPPR:

In response to an industry's appeal of an order or permit revocation, the Authority will issue its decision in the form of a Ruling on Request for Reconsideration of the order or permit revocation.

Amended Ruling:

An amendment to a ruling or order which modifies the original ruling.

Compliance Schedule:

Issued by the MWRA in a permit or a settlement agreement. It lists dates and milestones that an industry must meet to achieve compliance.

Settlement Agreement:

A formal document resolving violations and enforcement actions.

Returned to Permit Letter:

Notice to an industry that the industry has been relieved, in part or in full, of the sampling and reporting requirements of a prior enforcement action and can, therefore, return to those of its permit.

Stipulated Penalties Under Agreement:

Penalties which the settling parties agreed to pay for certain types of violations during the period of a settlement agreement.

Interim Ruling on Req. for Reconsideration:

These rulings resolve some but not all, issues appealed by an industry. A formal ruling will be issued later.

Extension of NON/OTCA/EO/SOC/NPPR Letter:

Extends dates in compliance order.

TRAC has the power to take other types of actions for violations, some of which are described below:

Emergency Suspension:

Sewer service may be immediately suspended after informal notice to the user if the discharge reasonably appears to present an imminent danger to health, public welfare or the environment, or if it threatens to interfere with the operation of the sewer system.

Civil Court Action:

TRAC may refer a case to the Attorney general for action in civil court, including injunctive relief, the collection of penalties, and the recovery of expenses. Referrals are seldom made because TRAC can issue and enforce administrative orders and financial penalties without court action.

Criminal Action:

TRAC may refer a case to the Attorney General's Office and the Environmental Crimes Strike Force for criminal charges to be brought against a user. Referrals are made for serious and intentional violations.

Appendix A

Significant Industrial Users

Includes:

- Permit # and Date
- Sample Location Description
 - Reason for SIU Status
 - SNC Status
 - Inspection Dates
 - Monitoring Dates
- Enforcement Actions

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Allston

Resilience US, Inc.	Facility ID: 44100358
500 Soldiers Field Road Allston, MA 02134	

Permit: Issued: 11/14/2023 Expires: 11/15/2027
Issued: 12/12/2019 Expires: 11/15/2023 Amended: 04/21/2023 Termination: 11/13/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated
0102 Boiler/Tower Blowdown Cogeneration Plant

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 18-Oct-2023
08-Mar-2024

Monitoring: 0101 19-Dec-2023
0101 18-Jun-2024
0102 19-Dec-2023

Enforcement Actions: 25-Oct-2022 Notice of Violation
24-Oct-2023 Notice of Violation
13-May-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Ashland

<i>Nyacol Nano Technologies Inc.</i>	Facility ID: 02003625
230 Megunko Road Ashland, MA 01721-0349	

Permit: Issued: 09/15/2022 Expires: 08/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated antimony pentoxide and silica oxide colloid production

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Jul-2023
17-Jan-2024

Monitoring: 0101 14-Nov-2023
0101 17-Nov-2023
0101 06-Feb-2024

Enforcement Actions: 15-Nov-2022 Notice of Violation
09-Dec-2022 Notice of Violation
24-Jul-2023 Notice of Violation
20-Oct-2023 Notice of Noncompliance
02-Nov-2023 Extension of NON/OTCA/EO/SOC/NPPR Letter
22-Mar-2024 Returned to Permit Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Bedford

Anika Therapeutics, Inc.

Facility ID: 03103603

32 Wiggins Avenue
Bedford, MA 01730

Permit: Issued: 09/21/2023 Expires: 10/15/2027
Issued: 11/18/2019 Expires: 10/15/2023 Amended: 11/23/2022 Termination: 09/20/2023

National Pretreatment Categorical Standards: 17-Aug-2015 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated mfg. and R&D of HA-based products

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 08-Sep-2023
18-Dec-2023
22-May-2024

Monitoring: 0101 03-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Cubic PV, Inc.

Facility ID: 03103701

6 -8 Preston Court
Bedford, MA 01730

Permit: Issued: 09/30/2022 Expires: 09/15/2026 Amended: 10/20/2023
Issued: 09/30/2022 Expires: 09/15/2026 Amended: 11/23/2022 Termination: 10/19/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated solar cell R&D wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 4
B Quarter: 4

Inspections: 09-Aug-2023
18-Jun-2024

Monitoring: 0101 15-Nov-2023

Enforcement Actions: 06-Feb-2023 Notice of Violation
12-Jan-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Entegris, Inc.	Facility ID: 03403799
9 Crosby Drive Bedford, MA 01730	

Permit: Issued: 03/19/2024 Expires: 03/15/2028
Issued: 05/26/2022 Expires: 05/25/2024 Amended: 11/23/2022 Termination: 03/18/2024

National Pretreatment Categorical Standards: 01-Sep-2013 to 433.17 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Wastewater from specialty coatings manufacturing and a new membra
0102 Process Wastewater - Regulated Wet Process Lab discharge

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES B Quarter: 1
B Quarter: 2

Inspections: 14-Sep-2023
30-Jan-2024

Monitoring: 0101 26-Sep-2023
0101 21-Dec-2023
0101 15-Feb-2024
0102 26-Sep-2023
0102 20-Dec-2023
0102 29-Feb-2024

Enforcement Actions: 02-Aug-2022 Notice of Violation
01-Jun-2023 Returned to Permit Letter
01-Nov-2023 Notice of Violation
23-Feb-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Instrumentation Laboratory

Facility ID: 03403233

180 Hartwell Road
Bedford, MA 01730

Permit: Issued: 03/21/2023 Expires: 03/15/2025

National Pretreatment Categorical Standards: 05-Dec-2008 to 433.17 A Metal Finishing

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	RO reject water
		Process Wastewater - Unregulated	laboratory wastewater
		Process Wastewater - Unregulated	laboratory wastewater
	0102	Process Wastewater - Unregulated	R&D of medical devices
	0103	Process Wastewater - Regulated	platinizing line
	0104	Process Wastewater - Unregulated	batch discharge from glass-cleaning unit

Reason for SIU Status: Is a CIU without flow., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Aug-2023
16-May-2024

<u>Monitoring:</u>	0101	24-Aug-2023
	0102	24-Aug-2023
	0104	24-Aug-2023

Enforcement Actions: 25-Aug-2022 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Ocular Therapeutix Inc.

Facility ID: 03403390

36 Crosby Drive Suite 101
Bedford, MA 01730

Permit: Issued: 11/02/2023 Expires: 11/15/2027
Issued: 12/18/2019 Expires: 11/15/2023 Amended: 11/23/2022 Termination: 11/01/2023

National Pretreatment Categorical Standards: 17-Jan-2019 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated
0102 Process Wastewater - Unregulated
0103 Process Wastewater - Regulated Non-discharging Fed Cat 439

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 10-Oct-2023
18-Dec-2023

Monitoring: 0101 03-Aug-2023
0102 03-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Thermo Fisher Scientific

Facility ID: 03103123

2 Preston Court
Bedford, MA 01730

Permit: Issued: 07/10/2024 Expires: 09/15/2026
Issued: 09/30/2022 Expires: 09/15/2024 Amended: 11/23/2022 Termination: 07/09/2024

National Pretreatment Categorical Standards: 31-Jul-2003 to 414.45 D Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated OCPSF wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES A Quarter: 1
B Quarter: 1
B Quarter: 2

Inspections: 19-Mar-2024
07-Jun-2024

Monitoring: 0101 22-Aug-2023
0101 23-Aug-2023
0101 18-Mar-2024
0101 19-Mar-2024

Enforcement Actions: 25-Mar-2024 Notice of Violation
26-Mar-2024 Notice of Violation
02-May-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Belmont

Purecoat North, LLC	Facility ID: 04001403
39 Hittinger Street Belmont, MA 02478	

Permit: Issued: 06/24/2024 Expires: 06/15/2026
Issued: 06/06/2022 Expires: 06/15/2024 Amended: 11/23/2022 Termination: 06/23/2024

National Pretreatment Categorical Standards: 02-May-2009 to 433.17 A Metal Finishing

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Regulated	Metal Finishing Operations
		OTHER_DESC	Metal Finishing Operations
	0103	OTHER_DESC	Cyanide Destruct Operations

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 06-Dec-2023
02-May-2024

<u>Monitoring:</u>	0101	23-Aug-2023
	0101	14-Dec-2023
	0101	21-Feb-2024
	0103	22-Aug-2023

Enforcement Actions: 19-Apr-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Boston (Dwntn)

Beth Israel Deaconess Medical Center

Facility ID: 45005703

330 Brookline Avenue
Boston, MA 02215

Permit: Issued: 06/28/2024
Issued: 06/06/2022

Expires: 02/15/2026
Expires: 02/15/2024

Termination: 06/27/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0112	Process Wastewater - Unregulated	cage wash effluent
	0113	Process Wastewater - Unregulated	Laboratory wastewater
	0114	Process Wastewater - Unregulated	Laboratory effluent
	0301	Process Wastewater - Unregulated	Lab & cagewashing wastewater
	0303	Process Wastewater - Unregulated	clinical lab wastewater
	0901	Process Wastewater - Unregulated	Lab wastewater
	1001	Process Wastewater - Unregulated	CPD wastewater
	1101	Process Wastewater - Unregulated	CPD wastewater
	1201	Process Wastewater - Unregulated	CPD wastewater

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 4

Inspections: 17-Jul-2023
23-Jan-2024

<u>Monitoring:</u>	0112	30-Nov-2023
	0113	27-Nov-2023
	0113	28-Nov-2023
	0114	27-Nov-2023
	0114	28-Nov-2023
	0114	13-Mar-2024
	0114	14-Mar-2024
	0301	29-Nov-2023
	0301	30-Nov-2023
	0301	13-Mar-2024
	0301	14-Mar-2024
	0301	29-Apr-2024
	0301	30-Apr-2024
	0303	29-Nov-2023
	0303	30-Nov-2023
	0303	14-Mar-2024
	0303	15-Mar-2024
	0901	27-Nov-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Beth Israel Deaconess Medical Center

Facility ID: 45005703

330 Brookline Avenue
Boston, MA 02215

0901	28-Nov-2023
0901	12-Mar-2024
0901	13-Mar-2024
1001	01-May-2024
1101	11-Mar-2024
1101	12-Mar-2024
1201	12-Mar-2024

<u>Enforcement Actions:</u>	01-Nov-2022	Returned to Permit Letter
	27-Mar-2023	Notice of Violation
	07-Jun-2023	Notice of Noncompliance
	19-Oct-2023	Notice of Violation
	23-Jan-2024	Returned to Permit Letter
	23-Jan-2024	Notice of Violation
	10-Apr-2024	Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Boston Children's Hospital

Facility ID: 45005920

300 Longwood Avenue
Boston, MA 02115

Permit: Issued: 06/26/2023 Expires: 05/15/2027

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0102	Process Wastewater - Unregulated	Research laboratory wastewater
	0201	Process Wastewater - Unregulated	clinical labs and SPD wastewater
	0301	Process Wastewater - Unregulated	
	0501	Process Wastewater - Unregulated	Research labs & animal care labs
	0601	Process Wastewater - Unregulated	Research laboratory wastewater

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 21-Sep-2023
22-Feb-2024

<u>Monitoring:</u>	0102	17-Jul-2023
	0102	18-Jul-2023
	0102	12-Feb-2024
	0102	13-Feb-2024
	0201	19-Jul-2023
	0201	20-Jul-2023
	0301	19-Jul-2023
	0301	12-Feb-2024
	0501	17-Jul-2023
	0501	18-Jul-2023
	0501	23-Jan-2024
	0501	24-Jan-2024
	0601	17-Jul-2023
	0601	18-Jul-2023
	0601	23-Jan-2024
	0601	24-Jan-2024

Enforcement Actions: 28-Feb-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Boston University - National Emerging Infectious Disease Lab

Facility ID: 45403758

620 Albany Street
Boston, MA 02118

Permit: Issued: 04/25/2024
Issued: 03/29/2022

Expires: 03/15/2026
Expires: 03/15/2024

Termination: 04/24/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated research lab wastewater
0102 Process Wastewater - Unregulated tissue digester wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 25-Oct-2023
26-Feb-2024

Monitoring: 0101 19-Jul-2023
0101 20-Jul-2023
0101 29-Nov-2023
0101 30-Nov-2023
0101 14-Feb-2024
0101 15-Feb-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Boston University Medical Campus

Facility ID: 45006015

715 Albany Street
Boston, MA 02118-2526

Permit: Issued: 03/15/2023 Expires: 02/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	Laboratory wastewater
	0301	Process Wastewater - Unregulated	wastewater from R&D lab & cage washers
	0401	Process Wastewater - Unregulated	laboratory wastewater
	0601	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	
	0801	Process Wastewater - Unregulated	research laboratory wastewater
	1001	Process Wastewater - Unregulated	
	1201	Process Wastewater - Unregulated	dental instrument wash water

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 2
B Quarter: 2
A Quarter: 3
B Quarter: 3
B Quarter: 4

Inspections: 26-Feb-2024
13-Jun-2024

<u>Monitoring:</u>	0101	29-Nov-2023
	0101	30-Nov-2023
	0301	28-Nov-2023
	0301	29-Nov-2023
	0301	12-Feb-2024
	0301	13-Feb-2024
	0401	30-May-2024
	0601	28-Nov-2023
	0601	29-Nov-2023
	0601	12-Feb-2024
	0601	13-Feb-2024
	0701	28-Nov-2023
	0801	29-Nov-2023
	0801	30-Nov-2023
	1001	28-Nov-2023
	1001	29-Nov-2023
	1001	12-Feb-2024
	1001	13-Feb-2024

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Boston University Medical Campus		Facility ID:	45006015
715 Albany Street Boston, MA 02118-2526			

1201	18-Jun-2024
1201	19-Jun-2024

<u>Enforcement Actions:</u>	19-Sep-2023	Notice of Violation
	05-Mar-2024	Notice of Noncompliance
	25-Jun-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Brigham & Women's Hospital	Facility ID: 45005731
75 Francis Street Boston, MA 02115	

<u>Permit:</u>	Issued: 10/13/2023	Expires: 08/15/2025	Amended: 09/23/2024	
	Issued: 10/13/2023	Expires: 08/15/2025		Termination: 09/22/2024
	Issued: 02/25/2022	Expires: 08/15/2023		Termination: 10/12/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0105	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	research laboratory effluent
	1001	Process Wastewater - Unregulated	
	1301	Process Wastewater - Unregulated	
	1401	Process Wastewater - Unregulated	
	1402	Process Wastewater - Unregulated	co-gen plant discharge
	1501	Process Wastewater - Unregulated	Tunnel washer effluent
	1502	Process Wastewater - Unregulated	rack washer effluent

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 11-Jul-2023
22-Dec-2023

<u>Monitoring:</u>	0105	17-Jul-2023
	0105	18-Jul-2023
	0105	20-Dec-2023
	0701	17-Jul-2023
	0701	18-Jul-2023
	0701	20-Dec-2023
	0701	25-Mar-2024
	0701	26-Mar-2024
	1001	06-Sep-2023
	1001	07-Sep-2023
	1301	07-Sep-2023
	1401	17-Jul-2023
	1401	18-Jul-2023
	1401	20-Dec-2023
	1401	25-Mar-2024
	1401	26-Mar-2024
	1402	07-Sep-2023
	1402	20-Dec-2023
	1501	07-Sep-2023
	1502	07-Sep-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Brigham & Women's Hospital

Facility ID: 45005731

75 Francis Street
Boston, MA 02115

<u>Enforcement Actions:</u>	28-Nov-2022	Notice of Violation
	14-Feb-2023	Notice of Violation
	14-Apr-2023	Notice of Violation
	12-Jun-2023	Notice of Violation
	27-Jul-2023	Notice of Noncompliance
	22-Aug-2023	Notice of Violation
	19-Sep-2023	Extension of NON/OTCA/EO/SOC/NPPR Letter
	14-Feb-2024	Returned to Permit Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Dana-Farber Cancer Institute

Facility ID: 45005701

450 Brookline Avenue
Boston, MA 02215

<u>Permit:</u>	Issued: 08/23/2023	Expires: 07/15/2025	Amended: 09/24/2024	
	Issued: 08/23/2023	Expires: 07/15/2025		Termination: 09/23/2024
	Issued: 10/19/2021	Expires: 07/15/2023	Amended: 09/07/2022	Termination: 08/22/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0201	Process Wastewater - Unregulated	
	0203	Process Wastewater - Unregulated	
	0304	Process Wastewater - Unregulated	
	0403	Process Wastewater - Unregulated	
	0501	Process Wastewater - Unregulated	
	0503	Process Wastewater - Unregulated	
	0601	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	
	0801	Process Wastewater - Unregulated	
	0802	Process Wastewater - Unregulated	
	0803	Process Wastewater - Unregulated	Research lab effluent

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 01-Sep-2023
19-Mar-2024

<u>Monitoring:</u>	0201	29-Aug-2023
	0201	31-Aug-2023
	0201	30-Jan-2024
	0201	02-Feb-2024
	0203	30-Jan-2024
	0203	26-Feb-2024
	0304	29-Aug-2023
	0304	31-Aug-2023
	0304	29-Jan-2024
	0304	30-Jan-2024
	0403	29-Nov-2023
	0403	30-Nov-2023
	0403	01-Feb-2024
	0403	02-Feb-2024
	0501	29-Aug-2023
	0501	31-Aug-2023
	0501	30-Nov-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

<i>Dana-Farber Cancer Institute</i>	Facility ID: 45005701
450 Brookline Avenue Boston, MA 02215	

0503	29-Aug-2023
0503	31-Aug-2023
0601	01-Feb-2024
0601	02-Feb-2024
0701	20-Jul-2023
0701	21-Jul-2023
0801	27-Nov-2023
0801	28-Nov-2023
0802	28-Nov-2023
0802	01-Feb-2024
0802	02-Feb-2024
0803	19-Jul-2023
0803	20-Jul-2023
0803	27-Nov-2023
0803	28-Nov-2023

<u>Enforcement Actions:</u>	07-Jun-2023	Notice of Noncompliance
	09-Jun-2023	Notice of Violation
	14-Aug-2023	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Harvard University - Longwood Campus

Facility ID: 45005962

200 Longwood Avenue
Boston, MA 02115

Permit: Issued: 01/20/2023 Expires: 01/15/2025 Amended: 05/14/2024
Issued: 01/20/2023 Expires: 01/15/2025 Termination: 05/13/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	
	0201	Process Wastewater - Unregulated	
	0301	Process Wastewater - Unregulated	
	0401	Process Wastewater - Unregulated	laboratory & cagewash effluent
	0503	Process Wastewater - Unregulated	
	0601	Process Wastewater - Unregulated	
	0702	Process Wastewater - Unregulated	
	0703	Process Wastewater - Unregulated	
	0802	Process Wastewater - Unregulated	
	1101	Process Wastewater - Unregulated	

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: YES B Quarter: 3

Inspections: 14-Aug-2023
14-Feb-2024

<u>Monitoring:</u>	0101	01-Nov-2023
	0101	21-Dec-2023
	0201	31-Oct-2023
	0201	25-Jan-2024
	0201	28-Mar-2024
	0301	31-Oct-2023
	0301	01-Nov-2023
	0301	27-Feb-2024
	0301	28-Feb-2024
	0401	30-Oct-2023
	0401	31-Oct-2023
	0401	11-Jan-2024
	0401	12-Jan-2024
	0401	27-Feb-2024
	0401	28-Feb-2024
	0503	01-Nov-2023
	0503	02-Nov-2023
	0601	30-Oct-2023
	0601	31-Oct-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Harvard University - Longwood Campus

Facility ID: 45005962

200 Longwood Avenue
Boston, MA 02115

0601	08-Jan-2024
0601	09-Jan-2024
0702	09-Jan-2024
0703	21-Dec-2023
0802	09-Jan-2024
0802	28-Mar-2024
0802	02-May-2024
1101	11-Jan-2024
1101	12-Jan-2024
1101	27-Feb-2024
1101	28-Feb-2024

<u>Enforcement Actions:</u>	01-Aug-2022	Notice of Violation
	21-Mar-2023	Notice of Violation
	09-Jun-2023	Notice of Violation
	27-Sep-2023	Notice of Noncompliance
	21-Mar-2024	Returned to Permit Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MATEP, LP

Facility ID: 45005964

474 Brookline Avenue
Boston, MA 02215

Permit: Issued: 10/04/2022 Expires: 08/15/2024 Amended: 01/18/2023

National Pretreatment Categorical Standards: 04-May-2007 to 423.16 A Steam Electric Power Generating

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	Low Volume Waste Sources
	0202	Process Wastewater - Regulated	Cooling tower blowdown & overflow
	0301	Process Wastewater - Unregulated	Low Volume Waste Sources

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 17-Oct-2023
27-Mar-2024

<u>Monitoring:</u>	0101	02-Oct-2023
	0101	04-Oct-2023
	0101	09-Jan-2024
	0202	02-Oct-2023
	0202	03-Oct-2023
	0202	20-Feb-2024
	0202	22-Feb-2024
	0301	02-Oct-2023
	0301	03-Oct-2023
	0301	04-Oct-2023
	0301	08-Jan-2024
	0301	09-Jan-2024
	0301	20-Feb-2024
	0301	21-Feb-2024
	0301	29-May-2024
	0301	30-May-2024
	9100	04-Oct-2023

<u>Enforcement Actions:</u>	17-Aug-2022	Notice of Violation
	14-Oct-2022	Notice of Violation
	10-Nov-2022	Notice of Violation
	30-Nov-2022	Notice of Noncompliance
	12-Jan-2023	Extension of NON/OTCA/EO/SOC/NPPR Letter
	07-Mar-2023	Notice of Violation
	19-Sep-2023	Returned to Permit Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA - Albany Street Bus Garage

Facility ID: 45102178

421 Albany Street
Boston, MA 02116

Permit: Issued: 03/07/2023 Expires: 03/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated bus wash water & steam clean

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 27-Sep-2023
24-Apr-2024

<u>Monitoring:</u>	0101	12-Sep-2023
	0101	13-Sep-2023
	0101	19-Mar-2024
	0101	20-Mar-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Massachusetts Department of Transportation, I-93 Tunnel

Facility ID: 45103098

I-93 Central Artery Tunnel
Boston, MA 02111

Permit: Issued: 02/07/2022 Expires: 12/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	Tunnel wash water, ground water, storm water runoff and air handling
	0201	OTHER_DESC	Wash water, ground water, storm water runoff and air handling plenum
	0301	OTHER_DESC	Wash water, ground water, storm water runoff and air handling plenum
	0401	OTHER_DESC	Tunnel wash water, ground water, storm water runoff and air handling
	0501	OTHER_DESC	Tunnel wash water, ground water, storm water runoff and air handling
	0601	OTHER_DESC	Tunnel wash water, ground water, storm water runoff and air handling

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 16-Aug-2023
25-Mar-2024

<u>Monitoring:</u>	0101	19-Jul-2023
	0101	12-Oct-2023
	0101	02-Nov-2023
	0201	12-Oct-2023
	0201	03-Nov-2023
	0201	07-Dec-2023
	0301	02-Nov-2023
	0301	05-Dec-2023
	0301	03-Jan-2024
	0401	02-Nov-2023
	0401	05-Dec-2023
	0401	03-Jan-2024
	0501	02-Nov-2023
	0501	05-Dec-2023
	0501	03-Jan-2024
	0601	02-Nov-2023
	0601	05-Dec-2023
	0601	03-Jan-2024

<u>Enforcement Actions:</u>	08-Sep-2022	Notice of Violation
	08-Dec-2022	Notice of Violation
	30-Jan-2023	Notice of Violation
	14-Dec-2023	Notice of Violation
	14-May-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Massachusetts General Hospital

Facility ID: 45005712

55 Fruit Street
Boston, MA 02114

Permit: Issued: 03/25/2024 Expires: 01/15/2026
Issued: 03/16/2022 Expires: 01/15/2024 Termination: 03/24/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	Laboratory effluent
	0104	Process Wastewater - Unregulated	Laboratory effluent
	0105	Process Wastewater - Unregulated	
	0301	Process Wastewater - Unregulated	
	0401	Process Wastewater - Unregulated	
	0402	Process Wastewater - Unregulated	
	0601	Process Wastewater - Unregulated	CPD effluent

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Jul-2023
20-Dec-2023

<u>Monitoring:</u>	0101	16-Aug-2023
	0101	17-Aug-2023
	0101	31-Oct-2023
	0101	23-Jan-2024
	0101	24-Jan-2024
	0101	29-Apr-2024
	0101	30-Apr-2024
	0104	16-Aug-2023
	0104	17-Aug-2023
	0104	22-Jan-2024
	0104	23-Jan-2024
	0104	29-Apr-2024
	0104	30-Apr-2024
	0105	16-Aug-2023
	0105	17-Aug-2023
	0105	22-Jan-2024
	0105	23-Jan-2024
	0105	01-May-2024
	0105	02-May-2024
	0301	16-Aug-2023
	0301	25-Jan-2024
	0401	20-Sep-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Massachusetts General Hospital	Facility ID:	45005712
55 Fruit Street Boston, MA 02114		

0402	20-Sep-2023
0601	21-Sep-2023
9100	31-Oct-2023

<u>Enforcement Actions:</u>	05-Sep-2023	Notice of Violation
	08-Feb-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Northeastern University

Facility ID: 45004837

360 Huntington Avenue
Boston, MA 02115

Permit: Issued: 05/25/2023 Expires: 04/15/2027 Amended: 10/13/2023
Issued: 05/25/2023 Expires: 04/15/2027 Termination: 10/12/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	laboratory wastewater
	0201	Process Wastewater - Unregulated	
	0301	Process Wastewater - Unregulated	
	0501	Process Wastewater - Unregulated	laboratory wastewater
	0602	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	
	0801	Process Wastewater - Unregulated	
	1101	Process Wastewater - Unregulated	laundry wastewater
	1301	Process Wastewater - Unregulated	Laboratory wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 31-Oct-2023
18-Apr-2024

<u>Monitoring:</u>	0101	07-Nov-2023
	0201	09-Nov-2023
	0201	22-Feb-2024
	0201	21-Mar-2024
	0201	22-Mar-2024
	0301	28-Aug-2023
	0301	06-Nov-2023
	0301	07-Nov-2023
	0301	20-Feb-2024
	0301	21-Feb-2024
	0501	01-Nov-2023
	0501	02-Nov-2023
	0602	08-Nov-2023
	0602	09-Nov-2023
	0701	08-Nov-2023
	0701	22-Feb-2024
	0701	21-Mar-2024
	0701	22-Mar-2024
	0801	07-Nov-2023
	1101	06-Nov-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Northeastern University		Facility ID:	45004837
360 Huntington Avenue Boston, MA 02115			

1101	22-Feb-2024
1301	23-Jan-2024
1301	14-Feb-2024
9100	28-Aug-2023

<u>Enforcement Actions:</u>	20-Nov-2023	Notice of Violation
-----------------------------	-------------	---------------------

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Revvity, Inc.

Facility ID: 45006727

549 Albany Street
Boston, MA 02118

<u>Permit:</u>	Issued: 06/24/2024	Expires: 06/15/2026		
	Issued: 06/28/2022	Expires: 06/15/2024	Amended: 09/22/2023	Termination: 06/23/2024
	Issued: 06/28/2022	Expires: 06/15/2024		Termination: 09/21/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0202 Process Wastewater - Unregulated Laboratory wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 20-Dec-2023
22-Apr-2024

<u>Monitoring:</u>	0202	23-Aug-2023
	0202	06-Sep-2023
	0202	22-Feb-2024
	9100	06-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Trustees of Boston University-Charles River Campus

Facility ID: 45004825

704 Commonwealth Avenue
Boston, MA 02215

<u>Permit:</u>	Issued: 09/22/2023	Expires: 09/15/2025	Amended: 05/01/2024	
	Issued: 09/22/2023	Expires: 09/15/2025		Termination: 04/30/2024
	Issued: 03/16/2022	Expires: 09/15/2023		Termination: 09/21/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	
	0201	Process Wastewater - Unregulated	
	0301	Process Wastewater - Unregulated	
	0303	Process Wastewater - Unregulated	
	0401	Process Wastewater - Unregulated	
	0501	Process Wastewater - Unregulated	
	0601	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	
	0801	Process Wastewater - Unregulated	
	0901	Process Wastewater - Unregulated	
	1001	Process Wastewater - Unregulated	
	1101	Process Wastewater - Unregulated	lab wastewater
1201	Process Wastewater - Unregulated	Laboratory wastewater	

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

<u>SNC:</u>	YES A	Quarter: 1
	A	Quarter: 2

Inspections: 22-Aug-2023
31-Jan-2024

<u>Monitoring:</u>	0101	18-Sep-2023
	0101	19-Sep-2023
	0201	21-Sep-2023
	0201	15-Feb-2024
	0301	19-Sep-2023
	0303	20-Sep-2023
	0303	21-Sep-2023
	0303	23-Jan-2024
	0303	24-Jan-2024
	0401	25-Jan-2024
	0501	15-Feb-2024
	0501	26-Mar-2024
	0601	24-Jan-2024
	0701	18-Sep-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Trustees of Boston University-Charles River Campus

Facility ID: 45004825

704 Commonwealth Avenue
Boston, MA 02215

0801	18-Sep-2023
0801	19-Sep-2023
0901	24-Jan-2024
1001	21-Sep-2023
1101	24-Jan-2024
1101	25-Jan-2024
1201	19-Sep-2023

<u>Enforcement Actions:</u>	06-Jul-2022	Notice of Violation
	07-Mar-2023	Notice of Violation
	27-Mar-2023	Notice of Violation
	31-Mar-2023	Notice of Noncompliance
	22-Aug-2023	Notice of Violation
	14-Feb-2024	Notice of Violation
	20- May-2024	Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Tufts Medical Center

Facility ID: 45005753

800 Washington Street
Boston, MA 02111

Permit: Issued: 09/07/2023 Expires: 05/15/2025
Issued: 07/19/2021 Expires: 05/15/2023 Amended: 08/19/2021 Termination: 09/06/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0203 Process Wastewater - Unregulated clinical laboratory wastewater
0204 Process Wastewater - Unregulated CPD wastewater
0301 Process Wastewater - Unregulated research laboratory wastewater
0802 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 14-Nov-2023
14-May-2024
20-May-2024

Monitoring: 0203 01-Nov-2023
0204 05-Oct-2023
0204 01-Nov-2023
0204 25-Mar-2024
0301 31-Oct-2023
0301 01-Nov-2023
0301 25-Mar-2024
0301 26-Mar-2024
0301 29-May-2024
0301 31-May-2024
0802 31-Oct-2023
0802 01-Nov-2023
0802 25-Mar-2024
0802 26-Mar-2024
9100 05-Oct-2023

Enforcement Actions: 22-Mar-2023 Notice of Violation
14-Nov-2023 Notice of Violation
07-May-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Tufts University, Boston Campus

Facility ID: 45004793

136 Harrison Avenue 75K950
Boston, MA 02111

Permit: Issued: 11/09/2023 Expires: 11/15/2027
Issued: 03/12/2020 Expires: 11/15/2023 Amended: 08/19/2021 Termination: 11/08/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0102 Process Wastewater - Unregulated Laboratory wastewater
0202 Process Wastewater - Unregulated Laboratory wastewater

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 05-Oct-2023
21-Mar-2024

Monitoring: 0102 28-Aug-2023
0102 02-Nov-2023
0102 03-Nov-2023
0102 12-Mar-2024
0202 05-Oct-2023
0202 03-Nov-2023
0202 12-Mar-2024
9100 28-Aug-2023
9100 05-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Vicinity Energy, Inc. - Kneeland Station

Facility ID: 45004707

165 Kneeland Street
Boston, MA 02111

Permit: Issued: 11/08/2023 Expires: 10/15/2025
Issued: 03/17/2022 Expires: 10/15/2023 Termination: 11/07/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated miscellaneous steam plant discharges
0201 Process Wastewater - Unregulated condensate from pumps & turbines

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Sep-2023
16-Feb-2024

Monitoring: 0101 22-Aug-2023
0101 23-Aug-2023
0101 29-Jan-2024
0101 30-Jan-2024
0101 28-Mar-2024
0101 29-Mar-2024
0201 29-Jan-2024

Enforcement Actions: 22-Feb-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Braintree

Channel Fish Processing, Inc.	Facility ID:	06405423
200 Commerce Drive Braintree, MA 02184		

Permit: Issued: 01/25/2022 Expires: 01/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Fish processing wastewater

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 12-Sep-2023
26-Mar-2024

Monitoring: 0101 11-Dec-2023
0101 12-Dec-2023
0101 26-Mar-2024
0101 27-Mar-2024

Enforcement Actions: 09-Dec-2022 Notice of Violation
09-May-2023 Notice of Violation
21-Dec-2023 Notice of Violation
01-Feb-2024 Notice of Violation
10-Apr-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Citra Labs (Zimmer-Biomet Co.)	Facility ID: 06001611
55 Messina Drive Braintree, MA 02184	

Permit: Issued: 07/12/2021 Expires: 03/15/2025 Amended: 11/23/2022

National Pretreatment Categorical Standards: 21-Sep-2001 to 439.46 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0103 Process Wastewater - Regulated pharmaceutical & medical device mfg. wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 04-Jan-2024
29-Apr-2024

Monitoring: 0103 20-Feb-2024
0103 21-Feb-2024

Enforcement Actions: 02-Nov-2022 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Life Instruments Corporation	Facility ID:	06409245
91 French Avenue Braintree, MA 02184		

Permit: Issued: 07/05/2022 Expires: 03/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards: 01-Oct-2021 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101 Process Wastewater - Regulated passivation wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES F3 Quarter: 3

Inspections: 07-Aug-2023

Monitoring:

Enforcement Actions: 09-May-2023 Notice of Violation
08-Nov-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

River Street Metal Finishing, Inc.

Facility ID: 06101856

35 Johnson Lane
Braintree, MA 02184

Permit: Issued: 01/26/2023 Expires: 01/15/2028

National Pretreatment Categorical Standards: 12-Mar-1997 to 433.15 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 25-Aug-2023

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Ryder Transportation Services

Facility ID: 06102545

285 Wood Road
Braintree, MA 02184

Permit: Issued: 07/09/2024 Expires: 05/15/2026
Issued: 05/26/2022 Expires: 05/15/2024 Termination: 07/08/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Truck washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 2

Inspections: 15-Dec-2023
25-Apr-2024

Monitoring: 0101 12-Sep-2023
0101 13-Jun-2024

Enforcement Actions: 14-Jun-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Symmons Industries, Inc.

Facility ID: 06000958

31 Brooks Drive
Braintree, MA 02184

Permit: Issued: 03/26/2024 Expires: 12/15/2025
Issued: 01/25/2022 Expires: 12/15/2023 Amended: 11/23/2022 Termination: 03/25/2024

National Pretreatment Categorical Standards: 07-Oct-2003 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated metal plating operation
0201 Process Wastewater - Regulated valve testing water and parts cleaning baths

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 05-Dec-2023
26-Mar-2024

Monitoring: 0101 12-Dec-2023
0101 13-Dec-2023
0101 21-Feb-2024
0101 22-Feb-2024
0201 12-Dec-2023
0201 21-Feb-2024
0201 08-May-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Tri-Town Regional Water Treatment Plant

Facility ID: 06408882

300 King Hill Road
Braintree, MA 02184

Permit: Issued: 04/14/2022 Expires: 04/15/2024 Amended: 08/03/2023
Issued: 04/14/2022 Expires: 03/15/2024 Amended: 11/23/2022 Termination: 08/02/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated 01water treatment plant residuals

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: YES H1 Quarter: 1

Inspections: 17-Apr-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Brighton

Steward St. Elizabeth's Medical Center

Facility ID: 46005935

736 Cambridge Street
Brighton, MA 02135

Permit: Issued: 03/09/2023 Expires: 11/15/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0201	OTHER_DESC	Hospital Laboratory Effluent
	0402	Process Wastewater - Unregulated	Medical cart washer.
	0403	Process Wastewater - Unregulated	Endoscope washing
	0404		
	0405		
	0406		

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

<u>SNC:</u>	YES B	Quarter: 1
	F3	Quarter: 1
	B	Quarter: 2

Inspections: 11-Aug-2023
09-Feb-2024

<u>Monitoring:</u>	0201	10-Oct-2023
	0201	11-Oct-2023
	0402	06-Sep-2023
	0402	11-Oct-2023
	0404	11-Oct-2023
	0405	11-Oct-2023
	0406	14-Feb-2024
	0406	27-Mar-2024
	9100	06-Sep-2023

<u>Enforcement Actions:</u>	12-Oct-2022	Notice of Noncompliance
	07-Mar-2023	Notice of Violation
	16- Aug-2023	Notice of Violation
	17- Oct-2023	Notice of Violation
	13-Feb-2024	Notice of Violation
	06-May-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Brookline

MBTA Reservoir Carhouse	Facility ID: 07101154
400 Chestnut Hill Avenue Brookline, MA 02146	

Permit: Issued: 03/28/2024 Expires: 01/15/2026
Issued: 05/26/2022 Expires: 01/15/2024 Amended: 11/23/2022 Termination: 03/27/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Jan-2024
01-Apr-2024

Monitoring: 0101 09-Aug-2023
0101 25-Apr-2024

Enforcement Actions: 14-Sep-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Burlington

Curia Massachusetts, Inc. (formerly AMRI - Burlington)

Facility ID: 08103431

99 S Bedford Street Suite 2
Burlington, MA 01803

Permit: Issued: 06/14/2021 Expires: 03/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards: 03-Jan-2006 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	laboratory wastewater
	0102	Process Wastewater - Unregulated	wash water from vial washer and sink in clean room
	0103		
	0104	Process Wastewater - Unregulated	Clean room sink

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 12-Jul-2023
05-Jun-2024

<u>Monitoring:</u>	0101	03-Aug-2023
	0102	12-Dec-2023
	0104	07-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Lahey Hospital & Medical Center	Facility ID: 08002766
41 Mall Road Burlington, MA 01805	

Permit: Issued: 09/12/2023 Expires: 09/15/2025
Issued: 03/08/2022 Expires: 09/15/2023 Amended: 11/23/2022 Termination: 09/11/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	medical labs
	0104	Process Wastewater - Unregulated	medical cart washer
	0105	Process Wastewater - Unregulated	01washer/sterilizer in CPD
	0201	Process Wastewater - Unregulated	medical R&D lab

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 23-Aug-2023
14-Dec-2023

<u>Monitoring:</u>	0101	20-Jul-2023
	0101	27-Nov-2023
	0101	28-Nov-2023
	0104	19-Jul-2023
	0105	19-Jul-2023
	0201	19-Jul-2023
	0201	28-Nov-2023

Enforcement Actions: 02-Aug-2023 Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Phoenix Tailings (Burlington)

Facility ID: 08409791

20 North Avenue
Burlington, MA 01803

Permit: Issued: 03/25/2024 Expires: 01/15/2029

National Pretreatment Categorical Standards: 28-Sep-2023 to 421.276 Y Nonferrous Metals Manufacturing

MWRA Category: 04

Sample Locations: 0201 Process Wastewater - Regulated Separation Area wastewater from metal extraction

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 28-Dec-2023
23-Jan-2024
14-May-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Vine Brook Water Treatment Plant

Facility ID: 08101677

171 Middlesex Turnpike
Burlington, MA 01803

Permit: Issued: 06/16/2021 Expires: 06/15/2025 Amended: 11/23/2022

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated water treatment backwash
Uncontaminated Cooling Water lab sample tap water - dilution

Reason for SIU Status:

SNC: NO

Inspections: 30-Jan-2024
24-May-2024

Monitoring: 0101 17-Jul-2023
0101 16-Oct-2023
0101 06-Nov-2023
9100 06-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Cambridge

ARE - 300 TechSquare

Facility ID: 09101756

300 Technology Square
Cambridge, MA 02139

Permit: Issued: 11/09/2023 Expires: 12/15/2025
Issued: 05/04/2022 Expires: 12/15/2023 Amended: 11/23/2022 Termination: 11/08/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Lab sink and glassware washing effluent
	0103	Process Wastewater - Unregulated	Bomedical reserach waste water
	0401	Process Wastewater - Unregulated	Biomedical research waste water
	0501	Process Wastewater - Unregulated	biomedical research

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 30-Oct-2023
11-Apr-2024

<u>Monitoring:</u>	0101	19-Jul-2023
	0101	21-Aug-2023
	0101	28-Nov-2023
	0101	29-Nov-2023
	0103	20-Sep-2023
	0103	21-Sep-2023
	0401	03-Oct-2023
	0401	03-Jan-2024
	0401	11-Jan-2024
	0501	18-Jul-2023
	0501	19-Jul-2023
	0501	28-Nov-2023
	9100	21-Aug-2023

<u>Enforcement Actions:</u>	07-Feb-2023	Notice of Violation
	23-Aug-2023	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Alnylam Pharmaceuticals, Inc.

Facility ID: 09403820

665 Concord Avenue
Cambridge, MA 02138

Permit: Issued: 12/21/2022 Expires: 12/15/2024

National Pretreatment Categorical Standards: 08-Nov-2022 to 439.46 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Categorical Process- Pharm. manufacturing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES B Quarter: 3
A Quarter: 4
B Quarter: 4

Inspections: 09-Nov-2023
01-Apr-2024

Monitoring: 0101 10-Aug-2023

Enforcement Actions: 31-Aug-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Biogen, Inc.

Facility ID: 09101193

115 Broadway
Cambridge, MA 02142

Permit: Issued: 03/28/2024 Expires: 02/15/2028
Issued: 02/21/2020 Expires: 02/15/2024 Amended: 11/23/2022 Termination: 03/27/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 OTHER_DESC Lab sinks, glassware washing and cage washing
0102 OTHER_DESC wastewater produced during cogen plant water treatment including car

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 12-Jul-2023
08-Jan-2024

Monitoring: 0101 18-Jul-2023
0101 28-Nov-2023
0101 29-Nov-2023
0102 18-Jul-2023
0102 19-Jul-2023

Enforcement Actions: 10-Aug-2022 Notice of Violation
04-Nov-2022 Returned to Permit Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Cambridge Brands, Inc.	Facility ID: 09007168
810 Main Street Cambridge, MA 02139	

Permit: Issued: 04/21/2023 Expires: 04/15/2025 Amended: 09/29/2023
Issued: 04/21/2023 Expires: 04/15/2025 Termination: 09/28/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Candy manufacture
0401 Process Wastewater - Unregulated candy manufacture

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Aug-2023
07-Feb-2024

Monitoring: 0101 30-Jan-2024
0101 31-Jan-2024
0101 09-Apr-2024
0101 10-Apr-2024
0401 30-Jan-2024
0401 31-Jan-2024
0401 27-Feb-2024

Enforcement Actions: 04-Aug-2022 Notice of Violation
16-Nov-2022 Notice of Violation
06-Mar-2023 Notice of Noncompliance
27-Mar-2023 Notice of Violation
06-Dec-2023 Notice of Noncompliance
01-Mar-2024 Ruling on Req for recon of NON/OTCA/EO/SOC/NPPR
03-Apr-2024 Extension of NON/OTCA/EO/SOC/NPPR Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Harvard University - Blackstone Street Station

Facility ID: 09003701

46 Blackstone Street
Cambridge, MA 02139

Permit: Issued: 10/23/2023 Expires: 08/15/2025
Issued: 05/04/2022 Expires: 08/15/2023 Amended: 11/23/2022 Termination: 10/22/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Boiler blowdown, zeolite regen., floor drains.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 12-Jul-2023
07-Dec-2023

Monitoring: 0101 05-Sep-2023
0101 06-Sep-2023
0101 02-Jan-2024
0101 03-Jan-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Harvard University - Cambridge Campus

Facility ID: 09003755

46 Blackstone Street
Cambridge, MA 02139

Permit: Issued: 11/20/2023 Expires: 12/15/2025
Issued: 03/29/2022 Expires: 12/15/2023 Amended: 11/23/2022 Termination: 11/19/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Effluent from research chemistry labs
	0201	OTHER_DESC	Effluent from research chemistry laboratories
	0801	OTHER_DESC	Effluent from research lab sinks, photoprocessing glassware washing
	0901	OTHER_DESC	Chemistry, physics, organic chemistry and biology teaching lab sink an
	1001	OTHER_DESC	Effluent from the Geology Laboratory
	1301	OTHER_DESC	Bioengineering research lab effluent
	1401	OTHER_DESC	Anthropology research labs
	1502	OTHER_DESC	Plastic animal cage washing.
	1503	OTHER_DESC	Animal cage washing.
	1504	OTHER_DESC	Animal cage rack washing.
	1701	OTHER_DESC	Engineering research in materials technology research on a nano scal
	2001	OTHER_DESC	R&D science labs - Northwest Building
	2002	OTHER_DESC	Mouse cage washing
	2401	Process Wastewater - Unregulated	laundry

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 01-Nov-2023
29-Apr-2024

<u>Monitoring:</u>	0101	25-Sep-2023
	0101	26-Sep-2023
	0101	27-Nov-2023
	0101	28-Nov-2023
	0101	14-Feb-2024
	0201	25-Sep-2023
	0201	26-Sep-2023
	0201	27-Nov-2023
	0201	28-Nov-2023
	0201	14-Feb-2024
	0801	21-Aug-2023
	0801	26-Sep-2023
	0801	27-Sep-2023
	0801	29-Nov-2023
	0901	18-Sep-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Harvard University - Cambridge Campus

Facility ID: 09003755

46 Blackstone Street
Cambridge, MA 02139

0901	19-Sep-2023
0901	11-Jan-2024
0901	12-Jan-2024
1001	18-Sep-2023
1001	09-Jan-2024
1301	28-Sep-2023
1502	19-Sep-2023
1503	19-Sep-2023
1504	19-Sep-2023
1701	20-Sep-2023
1701	21-Sep-2023
1701	11-Jan-2024
1701	12-Jan-2024
2001	27-Sep-2023
2001	28-Nov-2023
2001	29-Nov-2023
2001	30-Nov-2023
2002	21-Sep-2023
2401	21-Sep-2023
9100	21-Aug-2023

<u>Enforcement Actions:</u>	27-Jul-2022	Extension of NON/OTCA/EO/SOC/NPPR Letter
	12-Aug-2022	Notice of Violation
	06-Sep-2022	Notice of Violation
	09-Sep-2022	Notice of Violation
	22-Feb-2023	Notice of Violation
	11-Sep-2023	Returned to Permit Letter
	11-Oct-2023	Penalty Assessment Notice

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Ipsen Bioscience, Inc.

Facility ID: 09405507

One Kendall Square
Cambridge, MA 02139

Permit: Issued: 01/18/2023 Expires: 12/15/2026

National Pretreatment Categorical Standards: 03-Apr-2017 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated drug manufacturing and support

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 26-Oct-2023
12-Mar-2024

Monitoring: 0101 10-Aug-2023
0101 21-Aug-2023
9100 21-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Massachusetts Institute of Technology (MIT)

Facility ID: 09003259

77 Massachusetts Avenue
Cambridge, MA 02139

Permit: Issued: 10/23/2023 Expires: 09/15/2025
Issued: 05/04/2022 Expires: 09/15/2023 Amended: 11/23/2022 Termination: 10/22/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0201	OTHER_DESC	Microbiology Research & Development Labs
	0301	OTHER_DESC	Research & development Laboratories
	0401	OTHER_DESC	Biological R&D labs
	0502	OTHER_DESC	R&D lab sinks, photo processing, cage washing operations, glassware
	0701	OTHER_DESC	Institute for Soldier Nanotech/Bioengineering R&D Labs
	0702	OTHER_DESC	biomedical research waste water
	0801	OTHER_DESC	R & D lab
	0901	OTHER_DESC	Bldgs NW13 & NW14 R&D Labs
	1001	Process Wastewater - Unregulated	chemistry and nanotech
	1101	Process Wastewater - Unregulated	laundry
	1201	Process Wastewater - Unregulated	laundry

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 07-Aug-2023
12-Jan-2024

<u>Monitoring:</u>	0201	21-Aug-2023
	0201	18-Sep-2023
	0201	19-Sep-2023
	0201	10-Jan-2024
	0201	11-Jan-2024
	0201	29-Jan-2024
	0201	30-Jan-2024
	0301	19-Sep-2023
	0401	25-Sep-2023
	0401	26-Sep-2023
	0401	30-Oct-2023
	0401	31-Oct-2023
	0401	14-Mar-2024
	0502	25-Sep-2023
	0502	26-Sep-2023
	0502	30-Oct-2023
	0502	31-Oct-2023
	0701	07-Sep-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Massachusetts Institute of Technology (MIT)

Facility ID: 09003259

77 Massachusetts Avenue
Cambridge, MA 02139

0701	08-Sep-2023
0702	27-Sep-2023
0801	06-Sep-2023
0801	07-Sep-2023
0801	08-Jan-2024
0801	09-Jan-2024
0901	05-Sep-2023
0901	06-Sep-2023
0901	10-Jan-2024
0901	31-Jan-2024
1001	30-Oct-2023
1001	31-Oct-2023
1001	14-Mar-2024
1101	06-Sep-2023
1201	06-Sep-2023
1201	11-Jan-2024
9100	21-Aug-2023

<u>Enforcement Actions:</u>	13-Oct-2022	Returned to Permit Letter
	24-Oct-2022	Notice of Violation
	24-Jul-2023	Notice of Violation
	05-Dec-2023	Notice of Violation
	05-Dec-2023	Notice of Violation
	07-Dec-2023	Notice of Violation
	18-Jan-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Massachusetts Institute of Technology-Central Utility Plant

Facility ID: 09101084

50 Albany Street Building 42
Cambridge, MA 02139

Permit: Issued: 11/28/2023 Expires: 11/15/2025
Issued: 05/04/2022 Expires: 11/15/2023 Amended: 11/23/2022 Termination: 11/27/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Cogeneration plant effluent and lab sinks from Building 5, Building 7, B

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 20-Oct-2023
22-Mar-2024

Monitoring: 0101 08-Aug-2023
0101 09-Aug-2023
0101 02-Jan-2024
0101 03-Jan-2024
0101 06-Mar-2024

Enforcement Actions: 22-Nov-2022 Extension of NON/OTCA/EO/SOC/NPPR Letter
10-Jul-2023 Returned to Permit Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

The Charles Stark Draper Laboratory, Inc.

Facility ID: 09001132

555 Technology Square
Cambridge, MA 02139

Permit: Issued: 04/26/2024 Expires: 04/15/2026
Issued: 03/29/2022 Expires: 04/15/2024 Amended: 11/23/2022 Termination: 04/25/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0102	OTHER_DESC	Bio lab effluent & Metal finishing for R&D labs and prototype fabricatio
	0104	OTHER_DESC	Biolab effluent & Silicon wafer etching and metal coating for R&D labs
	0105	OTHER_DESC	Glassware washing and acid cleaning effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 04-Oct-2023
04-Mar-2024

<u>Monitoring:</u>	0102	09-Aug-2023
	0102	07-Sep-2023
	0104	09-Aug-2023
	0105	09-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Vicinity Energy Boston, Inc.

Facility ID: 09002256

265 First Street
Cambridge, MA 02142

Permit: Issued: 06/17/2024 Expires: 06/15/2026
Issued: 05/19/2022 Expires: 06/15/2024 Amended: 11/23/2022 Termination: 06/16/2024

National Pretreatment Categorical Standards: 01-Sep-2003 to 423.16 A Steam Electric Power Generating

MWRA Category: 01

Sample Locations: 0202 Process Wastewater - Regulated boiler blowdown, condensate reclaim tank overflow, city water reclaim
0301 OTHER_DESC Carriage House and Main Building pH neutralization syste.; RO & UF s

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 05-Dec-2023
01-May-2024

Monitoring: 0202 09-Aug-2023
0202 14-Dec-2023
0301 09-Aug-2023
0301 21-Aug-2023
0301 14-Dec-2023
9100 21-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Walter J Sullivan Water Purification Facility

Facility ID: 09101863

250 Fresh Pond Parkway
Cambridge, MA 02138

Permit: Issued: 05/04/2023 Expires: 05/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Effluent generated from sludge and filter backwash.
	0102	OTHER_DESC	Effluent generated from water quality laboratory.

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 26-Sep-2023
15-Feb-2024

<u>Monitoring:</u>	0101	07-Jul-2023
	0101	17-Oct-2023
	0101	06-Nov-2023
	0101	05-Jan-2024
	0102	16-Oct-2023
	0102	06-Nov-2023
	0102	04-Jan-2024
	9100	06-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Canton

<i>Emergent BioSolutions, Inc.</i>	Facility ID:	10102853
90 Shawmut Road Canton, MA 02021		

Permit: Issued: 01/20/2023 Expires: 11/15/2026

National Pretreatment Categorical Standards: 17-Jan-2002 to 439.17 A Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Pharmaceuticals mfg. by fermentation

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 16-Oct-2023
06-Mar-2024

Monitoring: 0101 07-Jul-2023

Enforcement Actions: 05-Oct-2022 Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Interpolymer Corporation	Facility ID: 10100536
200 Dan Road Canton, MA 02021	

<u>Permit:</u>	Issued: 08/16/2018	Amended: 08/21/2023	Termination: 08/21/2023
	Issued: 08/16/2018	Expires: 08/15/2023	Amended: 11/23/2022
			Termination: 08/20/2023

National Pretreatment Categorical Standards:

MWRA Category: 04

Sample Locations:

Reason for SIU Status:

SNC: NO

Inspections: 20-Jul-2023

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Neponset Street Water Treatment Facility

Facility ID: 10103713

480 Neponset Street
Canton, MA 02021

Permit: Issued: 09/21/2023 Expires: 06/15/2027
Issued: 06/17/2021 Expires: 06/15/2023 Amended: 11/23/2022 Termination: 09/20/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated water treatment plant residuals

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 20-Sep-2023
06-Feb-2024

Monitoring: 0101 15-Nov-2023
0101 10-Apr-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Charlestown

Boston Sand & Gravel Company

Facility ID: 47005927

180 New Rutherford Avenue
Charlestown, MA 02129

Permit: Issued: 11/01/2023
Issued: 03/16/2022

Expires: 10/15/2025
Expires: 10/15/2023

Termination: 10/31/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Sep-2023
05-Feb-2024

Monitoring: 0101 28-Sep-2023
0101 30-Apr-2024
0101 22-May-2024

Enforcement Actions: 28-Apr-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Diversified Automotive, Inc.

Facility ID: 47403474

100 Terminal Street
Charlestown, MA 02129

Permit: Issued: 09/18/2023 Expires: 07/15/2025
Issued: 08/04/2022 Expires: 07/15/2023 Termination: 09/17/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0201 Process Wastewater - Unregulated Car wash effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 10-Jan-2024
18-Jun-2024

Monitoring: 0201 12-Jul-2023
0201 03-Jan-2024
0201 19-Mar-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA - Charlestown Yard Complex

Facility ID: 47006019

21 Arlington Avenue
Charlestown, MA 02129

Permit: Issued: 12/12/2023 Expires: 01/15/2026
Issued: 05/16/2022 Expires: 01/15/2024 Termination: 12/11/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Bus washing effluent.
	0102	OTHER_DESC	Steam cleaning effluent.
	0201	OTHER_DESC	Truck/car washing effluent
	0301	OTHER_DESC	Truck & heavy equipment washing effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 10-Jul-2023
01-Dec-2023

<u>Monitoring:</u>	0101	28-Aug-2023
	0101	03-May-2024
	0201	26-Jun-2024
	0301	11-Sep-2023
	0301	21-Mar-2024
	9100	11-Sep-2023

Enforcement Actions: 08-Nov-2022 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MGH - Lawrence C. Martin Laboratory

Facility ID: 47007025

13th Street Building 149
Charlestown, MA 02129

Permit: Issued: 11/09/2023 Expires: 12/15/2025
Issued: 04/26/2022 Expires: 12/15/2023 Termination: 11/08/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Laboratory wastewater.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 01-Nov-2023
25-Apr-2024

Monitoring: 0101 28-Sep-2023
0101 29-Sep-2023
0101 19-Dec-2023
0101 20-Dec-2023
0101 28-Mar-2024
0101 29-Mar-2024

Enforcement Actions: 09-May-2023 Notice of Violation
13-May-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Chelsea

Catalent	Facility ID: 11403573
190 Everett Avenue Chelsea, MA 02150	

Permit: Issued: 03/07/2024 Expires: 02/15/2028
Issued: 04/14/2020 Expires: 02/15/2024 Amended: 11/23/2022 Termination: 03/06/2024

National Pretreatment Categorical Standards: 28-Mar-2019 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated CIP skid cleaning, glass washer and laboratory cleaning wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 05-Jul-2023
05-Jan-2024
08-Apr-2024

Monitoring: 0101 07-Jul-2023
0101 07-Nov-2023
0101 08-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Kayem Foods, Inc.

Facility ID: 11000611

75 Arlington Street
Chelsea, MA 02150

Permit: Issued: 06/26/2023 Expires: 05/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Meat processing

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 11-Jan-2024
06-May-2024

Monitoring: 0101 07-Jul-2023
0101 22-Aug-2023
0101 23-Aug-2023

Enforcement Actions: 28-Mar-2023 Notice of Noncompliance
17-Jan-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

State Garden Inc.

Facility ID: 11403376

300 Third Street
Chelsea, MA 02150

Permit: Issued: 11/23/2020 Expires: 09/15/2024 Amended: 05/08/2024
Issued: 11/23/2020 Expires: 09/15/2024 Amended: 08/18/2021 Termination: 05/07/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0103 Process Wastewater - Unregulated Vegetable washing and equipment sanitizing wastewater
0203 Process Wastewater - Unregulated Vegetable washing and equipment sanitizing

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 27-Oct-2023
14-Feb-2024
06-May-2024

Monitoring: 0103 22-Aug-2023
0103 23-Aug-2023
0201 22-Aug-2023
0201 23-Aug-2023
0201 30-Nov-2023
0202 22-Aug-2023
0202 23-Aug-2023
0202 30-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Clinton

Central Mass Powder Coating

Facility ID: 57102782

32 Greeley Street
Clinton, MA 01510

Permit: Issued: 06/25/2021 Expires: 04/15/2026 Amended: 08/20/2021

National Pretreatment Categorical Standards: 01-Mar-2003 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 19-Oct-2023

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Darmann Abrasive Products, Inc.

Facility ID: 57006959

100 Sterling Street
Clinton, MA 01510

Permit: Issued: 03/10/2023 Expires: 03/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated equipment discharge

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Dec-2023
26-Apr-2024

<u>Monitoring:</u>	0101	22-Aug-2023
	0101	02-Jan-2024
	0101	17-Jan-2024
	0101	28-May-2024
	9100	28-May-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Sterling Precision, Inc. dba Vitesse Systems

Facility ID: 57103051

90 Parker Street
Clinton, MA 01510

Permit: Issued: 11/01/2023 Expires: 07/15/2025
Issued: 06/25/2021 Expires: 07/15/2023 Amended: 08/20/2021 Termination: 10/31/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated aluminum brazing rinsewater
0102 Process Wastewater - Unregulated de-salt baths

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 14-Nov-2023
30-Apr-2024

Monitoring: 0101 22-Aug-2023
0101 23-Aug-2023
0101 03-Jan-2024
0101 06-May-2024
0101 07-May-2024
0102 22-Aug-2023
0102 02-Jan-2024
0102 06-May-2024
9100 06-May-2024

Enforcement Actions: 25-Jan-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Dorchester

Dutch Maid Bakery, Inc.

Facility ID: 48101125

50 Park Street
Dorchester, MA 02122

<u>Permit:</u>	Issued: 11/14/2023	Expires: 12/15/2025	Amended: 05/23/2024	
	Issued: 11/14/2023	Expires: 12/15/2025		Termination: 05/22/2024
	Issued: 04/26/2022	Expires: 12/15/2023		Termination: 11/13/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0103	OTHER_DESC	Cleaning bakery equipment
	0201	OTHER_DESC	washing cake decorating utensils and containers

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 03-Nov-2023
11-Apr-2024

<u>Monitoring:</u>	0103	28-Aug-2023
	0201	28-Aug-2023
	9100	28-Aug-2023

<u>Enforcement Actions:</u>	13-Mar-2024	Notice of Violation
	10-Jun-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA - Codman Yard

Facility ID: 48102660

375 Gallivan Boulevard
Dorchester, MA 02124

Permit: Issued: 06/10/2022

Expires: 06/15/2024

Termination: 05/06/2024

National Pretreatment Categorical Standards:

MWRA Category: 04

Sample Locations: 0101 OTHER_DESC Train washing effluent

Reason for SIU Status:

SNC: NO

Inspections: 05-Dec-2023
11-Apr-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Unifirst Corporation

Facility ID: 48003934

78 -80 East Cottage Street
Dorchester, MA 02125

Permit: Issued: 12/06/2022 Expires: 10/15/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Laundry effluent

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 04-Jan-2024
26-Jun-2024

Monitoring: 0101 13-Dec-2023
0101 23-Apr-2024
0101 30-May-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

University of Massachusetts, Boston

Facility ID: 48100569

100 Morrissey Boulevard
Dorchester, MA 02125-3393

Permit: Issued: 10/26/2022 Expires: 11/15/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Lab wastewater
	0102	OTHER_DESC	Lab wastewater
	0103	Process Wastewater - Unregulated	Lab wastewater, cu & zn etch
	0204	Process Wastewater - Unregulated	Lab wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 1
B Quarter: 3
A Quarter: 4
B Quarter: 4

Inspections: 18-Sep-2023
15-May-2024

<u>Monitoring:</u>	0101	07-Nov-2023
	0101	08-Nov-2023
	0101	10-Apr-2024
	0101	11-Apr-2024
	0102	07-Nov-2023
	0102	08-Nov-2023
	0102	11-Apr-2024
	0103	08-Nov-2023
	0103	09-Nov-2023
	0103	11-Apr-2024
	0204	04-Oct-2023
	0204	07-Nov-2023
	0204	08-Nov-2023
	0204	09-Apr-2024
	0204	10-Apr-2024
	9100	04-Oct-2023

<u>Enforcement Actions:</u>	01-Dec-2023	Notice of Violation
	07-Mar-2024	Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

East Boston

MBTA - Orient Heights Maintenance Facility

Facility ID: 49003659

34 Barnes Avenue
East Boston, MA 02128

Permit: Issued: 05/01/2024
Issued: 06/01/2022

Expires: 05/15/2026
Expires: 05/15/2024

Termination: 04/30/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0102 Process Wastewater - Unregulated Railroad car washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Nov-2023
09-Apr-2024

Monitoring: 0102 22-Aug-2023
0102 23-Aug-2023
0102 11-Sep-2023
0102 30-May-2024
9100 11-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MassPort - Green Bus Depot

Facility ID: 49403923

23 Lovell Street
East Boston, MA 02128

Permit: Issued: 01/20/2023 Expires: 11/15/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated bus washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 26-Sep-2023
12-Mar-2024

Monitoring: 0101 04-Mar-2024
0101 05-Mar-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Everett

Cambridge Health Alliance-Everett Hospital

Facility ID: 13006521

96 -103 Garland Street
Everett, MA 02149

Permit: Issued: 05/03/2024 Expires: 04/15/2028
Issued: 05/04/2020 Expires: 04/15/2024 Amended: 11/23/2022 Termination: 05/02/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0202 Process Wastewater - Unregulated Clinical Labs
0601 Process Wastewater - Unregulated Central Processing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 16-Oct-2023
04-Mar-2024

Monitoring: 0202 19-Jul-2023
0202 20-Jul-2023
0202 17-Oct-2023
0202 01-Nov-2023
0202 02-Nov-2023
0601 19-Jul-2023
0601 20-Jul-2023
0601 01-Nov-2023
0601 02-Nov-2023
9100 17-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Constellation Mystic Power, LLC (Units 8 & 9)

Facility ID: 13102507

39 Rover Street
Everett, MA 02149

Permit: Issued: 05/28/2024 Expires: 05/15/2026
Issued: 06/09/2022 Expires: 05/15/2024 Amended: 11/23/2022 Termination: 05/27/2024

National Pretreatment Categorical Standards: 06-Aug-2007 to 423.17 N/A Steam Electric Power Generating

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated Wastewater from steam electric power generation

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 30-Nov-2023
10-Apr-2024

Monitoring: 0101 17-Oct-2023
0101 06-Nov-2023
0101 07-Nov-2023
9100 17-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Duncan Galvanizing Corporation

Facility ID: 13000624

69 Norman Street
Everett, MA 02149

Permit: Issued: 12/01/2022

Expires: 12/15/2026

National Pretreatment Categorical Standards:

17-Dec-1991 to
17-Dec-1991 to
17-Dec-1991 to

420.115 K Iron and Steel Manufacturing
420.125 L Iron and Steel Manufacturing
420.95 I Iron and Steel Manufacturing

MWRA Category: 04

Sample Locations: 0103

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 12-Jul-2023

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Hi-Tech Plating/The Tinning Company

Facility ID: 13006291

69 Norman Street
Everett, MA 02149

Permit: Issued: 08/07/2024 Expires: 10/15/2024
Issued: 04/03/2024 Expires: 07/15/2024 Termination: 08/06/2024
Issued: 05/17/2022 Expires: 03/15/2024 Amended: 11/23/2022 Termination: 04/02/2024

National Pretreatment Categorical Standards: 04-Apr-2019 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0201 Process Wastewater - Regulated 413 Wastestream - Tinning Co.
Process Wastewater - Regulated 433 Wastestream - Hi-Tech Plating
0202 Cyanide Waste Stream

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES A Quarter: 2
B Quarter: 2

Inspections: 12-Sep-2023
11-Mar-2024
13-Jun-2024

Monitoring: 0201 07-Dec-2023
0201 08-Dec-2023
0201 30-Jan-2024
0201 06-Mar-2024
0202 03-Oct-2023
0202 20-Feb-2024

Enforcement Actions: 26-Jan-2024 Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA Everett Shops

Facility ID: 13006006

80 Broadway
Everett, MA 02149

Permit: Issued: 11/28/2023 Expires: 12/15/2025
Issued: 05/04/2022 Expires: 12/15/2023 Amended: 11/23/2022 Termination: 11/27/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 16-Nov-2023
12-Apr-2024

Monitoring: 0101 03-Aug-2023
0101 21-Nov-2023

Enforcement Actions: 06-Jul-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Prolerized New England Company, LLC (PNE)

Facility ID: 13000150

69 Rover Street
Everett, MA 02149

Permit: Issued: 09/18/2023 Expires: 07/15/2025
Issued: 08/09/2019 Expires: 07/15/2023 Amended: 11/23/2022 Termination: 09/17/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Air Pollution Control Wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 19-Mar-2024
07-Jun-2024

Monitoring: 0101 07-Dec-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

The Leavitt Corporation

Facility ID: 13000351

100 Santilli Highway
Everett, MA 02149

Permit: Issued: 04/04/2024 Expires: 03/15/2026
Issued: 06/09/2022 Expires: 03/15/2024 Amended: 11/23/2022 Termination: 04/03/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0201 Process Wastewater - Unregulated Cleaning water from peanut butter making & nut roasting

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 4
B Quarter: 4

Inspections: 18-Oct-2023
06-Feb-2024

Monitoring: 0201 17-Oct-2023
0201 08-Jan-2024
0201 09-Jan-2024
0201 20-Mar-2024
0201 21-Mar-2024
9100 17-Oct-2023

Enforcement Actions: 03-Jan-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Framingham

ADESA Boston	Facility ID:	14101472
63 Western Avenue Framingham, MA 01702		

Permit: Issued: 01/27/2023 Expires: 02/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Car reconditioning wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 23-Aug-2023
06-Jun-2024

Monitoring: 0101 29-Aug-2023
0101 07-Dec-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

BlueTriton Brands, Inc.

Facility ID: 14101520

105 Pennsylvania Avenue
Framingham, MA 01701

Permit: Issued: 05/02/2024 Expires: 05/15/2028
Issued: 06/05/2020 Expires: 05/15/2024 Amended: 11/23/2022 Termination: 05/01/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 OTHER_DESC RO Reject/Softener
Process Wastewater - Unregulated Bottling processes

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 03-Nov-2023
22-Mar-2024

Monitoring: 0101 19-Oct-2023
0101 23-Oct-2023
9100 19-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Boston HeartDiagnostics

Facility ID: 14404606

200 Crossing Boulevard
Framingham, MA 01702

Permit: Issued: 09/08/2023 Expires: 09/15/2025
Issued: 02/14/2022 Expires: 09/15/2023 Amended: 11/23/2022 Termination: 09/07/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 17-Aug-2023
19-Jan-2024

Monitoring: 0101 29-Nov-2023

Enforcement Actions: 17-May-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Metrowest Medical Center - Framingham Union Hospital

Facility ID: 14005736

115 Lincoln Street
Framingham, MA 01702

Permit: Issued: 06/06/2022 Expires: 06/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0201	OTHER_DESC	wastewater from medical laboratory
	0301	Process Wastewater - Unregulated	wastewater from cleaning of medical instruments

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES F3 Quarter: 1

Inspections: 25-Aug-2023
09-Feb-2024

<u>Monitoring:</u>	0201	16-Aug-2023
	0201	17-Aug-2023
	0201	18-Oct-2023
	0301	17-Aug-2023
	9100	18-Oct-2023

Enforcement Actions: 29-May-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

P.P. Manufacturing Corporation

Facility ID: 14102115

175 Crossing Boulevard Suite 200
Framingham, MA 01702

Permit: Issued: 11/15/2022 Expires: 08/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards: 26-Oct-2012 to 439.17 A Pharmaceutical Manufacturing
26-Oct-2012 to 439.27 B Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Manufacturing of veterinary biologics (PPM)
Process Wastewater - Unregulated Wastewater from LFB-USA

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES F3 Quarter: 1

Inspections: 14-Sep-2023
29-Feb-2024

Monitoring: 0101 18-Oct-2023
0101 29-Nov-2023
9100 18-Oct-2023

Enforcement Actions: 29-May-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Sanofi-Genzyme

Facility ID: 14100249

76 New York Avenue
Framingham, MA 01701

Permit: Issued: 05/01/2024 Expires: 06/15/2026
Issued: 06/06/2022 Expires: 06/15/2024 Amended: 11/23/2022 Termination: 04/30/2024

National Pretreatment Categorical Standards: 17-Jun-2005 to 439.16 A Pharmaceutical Manufacturing

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	R&D lab and HA fermentation wastewater
	0102	Process Wastewater - Regulated	HA fermentation wastewater
	0104	Process Wastewater - Unregulated	Cell Culture Expansion process wastewater & High BOD waste from 8
	0105	Process Wastewater - Unregulated	passivation wastewater
	0106	Process Wastewater - Unregulated	laboratory wastewater

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 25-Jan-2024
03-Apr-2024

<u>Monitoring:</u>	0101	28-Aug-2023
	0101	30-Aug-2023
	0101	20-Nov-2023
	0101	21-Nov-2023
	0102	26-Oct-2023
	0104	28-Aug-2023
	0104	30-Aug-2023
	0104	18-Oct-2023
	0105	07-Aug-2023
	0106	29-Aug-2023
	9100	18-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Thermo Fisher Scientific	Facility ID:	14102417
1455 Concord Street Framingham, MA 01701		

Permit: Issued: 08/17/2022 Expires: 03/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards: 15-Mar-2002 to 414.85 H Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Mfg. of gene sequencing polymers

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 12-Oct-2023
03-May-2024

Monitoring: 0101 19-Oct-2023
0101 14-Nov-2023
9100 19-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Holbrook

Braintree Laboratories, Part of Sebelo Pharmaceuticals

Facility ID: 16101023

270 Centre Street
Holbrook, MA 02343

Permit: Issued: 01/28/2021 Expires: 11/15/2024 Amended: 11/23/2022

National Pretreatment Categorical Standards: 06-Jun-2008 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Pharmaceutical rinses

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 05-Dec-2023

Monitoring: 0101 07-Sep-2023
0101 03-Jan-2024
9100 07-Sep-2023

Enforcement Actions: 18-Oct-2022 Notice of Violation
31-May-2023 Notice of Violation
18-Jan-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Jamaica Plain

Brigham & Women's Faulkner Hospital

Facility ID: 51005715

1153 Centre Street
Jamaica Plain, MA 02130

Permit: Issued: 11/20/2023 Expires: 12/15/2025
Issued: 03/30/2022 Expires: 12/15/2023 Termination: 11/19/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	hospital clinical laboratory
	0201	OTHER_DESC	Washers and sterilizer for hospital surgical instruments
	0203	OTHER_DESC	Cleaning of medical tools prior to sterilization

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 1

Inspections: 09-Nov-2023
07-Feb-2024
13-May-2024

<u>Monitoring:</u>	0101	05-Sep-2023
	0101	10-Oct-2023
	0101	11-Oct-2023
	0201	11-Oct-2023
	0201	08-Feb-2024
	0203	11-Oct-2023
	0203	08-Feb-2024
	9100	05-Sep-2023

<u>Enforcement Actions:</u>	16-Mar-2023	Notice of Violation
	20-Mar-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Commonwealth of Massachusetts Department of Public Health

Facility ID: 51006016

305 South Street
Jamaica Plain, MA 02130

Permit: Issued: 06/01/2021 Expires: 05/15/2025 Amended: 08/23/2023
Issued: 06/01/2021 Expires: 05/15/2025 Amended: 08/20/2021 Termination: 08/22/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0104 OTHER_DESC Laboratory glassware washer and laboratory sinks.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 24-Jul-2023
29-Nov-2023
16-Jan-2024

Monitoring: 0104 05-Sep-2023
0104 14-Sep-2023
0104 05-Mar-2024
0201 11-Jan-2024
0201 12-Jan-2024
9100 05-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA - Arborway Maintenance

Facility ID: 51102177

3550 Washington Street
Jamaica Plain, MA 02130

Permit: Issued: 05/23/2024 Expires: 06/15/2026
Issued: 06/10/2022 Expires: 06/15/2024 Termination: 05/22/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Bus washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 3

Inspections: 05-Dec-2023
01-May-2024

Monitoring: 0101 13-Sep-2023
0101 04-Jun-2024

Enforcement Actions: 22-Sep-2023 Notice of Violation
06-Oct-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

VA Boston Healthcare System - Jamaica Plain

Facility ID: 51005733

150 S. Huntington Avenue S-138
Jamaica Plain, MA 02130

<u>Permit:</u>	Issued: 09/09/2024	Expires: 08/15/2026		
	Issued: 01/23/2023	Expires: 08/15/2024	Amended: 05/20/2024	Termination: 09/08/2024
	Issued: 01/23/2023	Expires: 08/15/2024		Termination: 05/19/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0103	Process Wastewater - Unregulated	Waterwater from surgical tool cleaning in the SPD area
	0104	Process Wastewater - Unregulated	Cage washer in Building 1A
	0105	Process Wastewater - Unregulated	Steam sterilizer in Building 1A
	0107	Process Wastewater - Unregulated	Wastewater from the spigot situated in Room E4-112 on the fourth floor
	0108	Process Wastewater - Regulated	
	0109	Process Wastewater - Regulated	

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 12-Jul-2023
08-Jan-2024

<u>Monitoring:</u>	0103	14-Dec-2023
	0103	03-Jan-2024
	0103	04-Jan-2024
	0103	05-Mar-2024
	0103	06-Mar-2024
	0103	07-Mar-2024
	0103	08-May-2024
	0103	09-May-2024
	0104	03-Jan-2024
	0105	03-Jan-2024
	0107	04-Jan-2024

<u>Enforcement Actions:</u>	13-Jan-2023	Notice of Violation
	07-Apr-2023	Notice of Noncompliance
	15-May-2023	Extension of NON/OTCA/EO/SOC/NPPR Letter
	04-Oct-2023	Extension of NON/OTCA/EO/SOC/NPPR Letter
	02-Jan-2024	Extension of NON/OTCA/EO/SOC/NPPR Letter
	02-Jan-2024	Extension of NON/OTCA/EO/SOC/NPPR Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Lexington

BAE Systems Information & Electronic Systems Integration

Facility ID: 17001160

2 Forbes Road
Lexington, MA 02421

Permit: Issued: 06/28/2023 Expires: 06/15/2027

National Pretreatment Categorical Standards: 24-May-2007 to 469.18 A Electrical and Electronic Components

MWRA Category: 02

Sample Locations: 0115 Process Wastewater - Regulated Semiconductor manufacturing, research, and development wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 13-Jul-2023
04-Dec-2023

Monitoring: 0115 07-Sep-2023
0115 11-Sep-2023
9100 11-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

M.I.T. Lincoln Laboratory

Facility ID: 17100088

244 Wood Street
Lexington, MA 02421

<u>Permit:</u>	Issued: 09/08/2023	Expires: 07/15/2025	Amended: 07/18/2024	
	Issued: 09/08/2023	Expires: 07/15/2025		Termination: 07/17/2024
	Issued: 05/17/2022	Expires: 07/15/2023	Amended: 11/23/2022	Termination: 09/07/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Microelectronics research and development laboratories
	0102	OTHER_DESC	Microelectronics research and development laboratories
	0103	OTHER_DESC	Microelectronics research and development & biological research labo
	0104	OTHER_DESC	Microelectronics research and development laboratories

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 3

Inspections: 27-Mar-2024
27-Jun-2024

<u>Monitoring:</u>	0101	06-Sep-2023
	0101	07-Sep-2023
	0101	11-Sep-2023
	0102	06-Sep-2023
	0102	07-Sep-2023
	0102	20-Nov-2023
	0102	07-Feb-2024
	0102	08-Feb-2024
	0103	05-Sep-2023
	0103	06-Sep-2023
	0103	18-Jan-2024
	0103	08-Feb-2024
	0104	05-Sep-2023
	0104	06-Sep-2023
	9100	11-Sep-2023

<u>Enforcement Actions:</u>	02-Oct-2023	Notice of Violation
	11-Jun-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Shire Human Genetic Therapies, Inc.

Facility ID: 17403364

300 Shire Way
Lexington, MA 02421

Permit: Issued: 05/18/2022 Expires: 03/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	Process wastewater from biopharmaceutical manufacturing facility
	0201	Process Wastewater - Unregulated	biomedical tech waste water
	0301	Process Wastewater - Unregulated	biomedical tech waste water
	0501	Process Wastewater - Unregulated	biomedical tech waste water

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 13-Oct-2023
16-Apr-2024

<u>Monitoring:</u>	0101	14-Aug-2023
	0101	15-Aug-2023
	0101	11-Sep-2023
	0101	13-Oct-2023
	0201	14-Aug-2023
	0301	14-Aug-2023
	0301	15-Aug-2023
	0301	04-Oct-2023
	0501	15-Aug-2023
	0501	12-Oct-2023
	9100	11-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Malden

F.M. Callahan & Sons, Inc.

Facility ID: 18005023

22 Sharon Street
Malden, MA 02148

Permit: Issued: 07/06/2023 Expires: 06/15/2025
Issued: 01/11/2022 Expires: 06/15/2023 Amended: 11/23/2022 Termination: 07/05/2023

National Pretreatment Categorical Standards: 23-Apr-2013 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Metal plating and finishing
0102 OTHER_DESC 433 cyanide destruct

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 08-Nov-2023
30-Apr-2024

Monitoring: 0101 13-Sep-2023
0101 12-Dec-2023
0101 13-Dec-2023
0101 29-Jan-2024
0101 30-Jan-2024
0102 31-Jan-2024

Enforcement Actions: 14-Jun-2023 Notice of Violation
27-Oct-2023 Notice of Violation
19-Jan-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Mattapan

UMass Medical School - MassBiologics

Facility ID: 52103302

458 460 Walk Hill Street
Mattapan, MA 02126

Permit: Issued: 03/16/2022 Expires: 10/15/2025

National Pretreatment Categorical Standards: 24-Jun-2008 to 439.26 B Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 OTHER_DESC Production of Monoclonal Antibodies
0201 OTHER_DESC R&D and Manufacturing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 20-Oct-2023
06-Mar-2024

Monitoring: 0101 26-Sep-2023
0101 28-Sep-2023
0101 05-Oct-2023
0201 25-Sep-2023
0201 26-Sep-2023
9100 05-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Medford

MBTA Fellsbury Bus Garage	Facility ID:	19007805
447 Salem Street Medford, MA 02155		

Permit: Issued: 05/17/2023 Expires: 04/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Aug-2023
15-Feb-2024

Monitoring: 0101 05-Mar-2024
0101 08-Apr-2024
0101 09-Apr-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA WellingtonCarhouse	Facility ID: 19101411
37 Revere Beach Parkway Medford, MA 02155	

Permit: Issued: 06/17/2024 Expires: 06/15/2026
Issued: 05/19/2022 Expires: 06/15/2024 Amended: 11/23/2022 Termination: 06/16/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Automated rail vehicle washer

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 01-Dec-2023
01-May-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Monogram Gourmet Foods LLC

Facility ID: 19409246

300 Middlesex Avenue
Medford, MA 02155

Permit: Issued: 04/12/2022 Expires: 02/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Equipment washing, sanitation, and plant wash down

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 16-Oct-2023
04-Mar-2024

Monitoring: 0101 14-Sep-2023

Enforcement Actions: 20-Jan-2023 Notice of Violation
06-Apr-2023 Notice of Violation
17-Jul-2023 Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Tufts University, Somerville_Medford Campus

Facility ID: 19003634

419 Boston Avenue
Medford, MA 02155

Permit: Issued: 05/06/2024 Expires: 05/15/2026
Issued: 06/10/2022 Expires: 05/15/2024 Amended: 11/23/2022 Termination: 05/05/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0201	OTHER_DESC	Lab wastewater from Pearson & Michaels Building's discharge.
	0601	OTHER_DESC	Chemical engineering and optics lab wastewater discharge.
	0702	Process Wastewater - Unregulated	Wastewater from labs of SEC Building.
	0801	Process Wastewater - Unregulated	Physics labs

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 17-Nov-2023
03-Apr-2024

<u>Monitoring:</u>	0201	11-Sep-2023
	0201	12-Sep-2023
	0201	30-Jan-2024
	0601	12-Sep-2023
	0601	29-Jan-2024
	0601	14-May-2024
	0702	31-Oct-2023
	0702	01-Nov-2023
	0702	24-Jan-2024
	0702	25-Jan-2024
	0801	12-Sep-2023
	0801	29-Jan-2024
	9100	11-Sep-2023

<u>Enforcement Actions:</u>	02-Dec-2022	Notice of Violation
	01-Mar-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Melrose

Churchill Corporation	Facility ID: 20000775
344 Franklin Street Melrose, MA 02176	

Permit: Issued: 03/18/2024 Expires: 03/15/2028
Issued: 06/28/2022 Expires: 03/15/2024 Amended: 11/23/2022 Termination: 03/17/2024

National Pretreatment Categorical Standards: 01-Apr-1991 to 433.15 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 OTHER_DESC Chromating / iridite line

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 12-Sep-2023
30-Jan-2024

Monitoring: 0101 13-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Tufts Medicine Melrose Wakefield Hospital Inc.

Facility ID: 20005760

585 Lebanon Street
Melrose, MA 02176

Permit: Issued: 08/29/2023 Expires: 06/15/2027
Issued: 06/28/2019 Expires: 06/15/2023 Amended: 11/23/2022 Termination: 08/28/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 24-Jul-2023
21-Mar-2024

Monitoring: 0101 19-Jul-2023
0101 20-Jul-2023
0101 01-Nov-2023
0101 02-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Milton

Beth Israel Deaconess Hospital-Milton Inc.

Facility ID: 21006031

199 Reedsdale Road
Milton, MA 02186

Permit: Issued: 03/28/2024 Expires: 01/15/2028
Issued: 06/03/2020 Expires: 01/15/2024 Amended: 01/10/2023 Termination: 03/27/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0202	Process Wastewater - Unregulated	Clinical laboratory wastewater
	0301	Process Wastewater - Unregulated	
	0302	Process Wastewater - Unregulated	
	0303	Process Wastewater - Unregulated	
	0304	Process Wastewater - Unregulated	
	0305	Process Wastewater - Unregulated	
	0306	Process Wastewater - Unregulated	
	0307	Process Wastewater - Unregulated	disinfected body fluids from Neptune cart

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 2
B Quarter: 2
B Quarter: 3
F3 Quarter: 3

Inspections: 12-Dec-2023
24-May-2024

<u>Monitoring:</u>	0202	07-Sep-2023
	0202	25-Sep-2023
	0202	26-Sep-2023
	0301	25-Sep-2023
	0302	30-Jan-2024
	0303	25-Sep-2023
	0303	20-Nov-2023
	0304	25-Sep-2023
	0305	25-Sep-2023
	0305	20-Nov-2023
	0306	25-Sep-2023
	9100	07-Sep-2023

<u>Enforcement Actions:</u>	24-May-2023	Notice of Violation
	08-Aug-2023	Notice of Violation
	19-Oct-2023	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Natick

U.S. Army Soldier Systems Center

Facility ID: 22001808

10 General Greene Avenue
Natick, MA 01760

Permit: Issued: 01/26/2023 Expires: 01/15/2025 Amended: 03/08/2024
Issued: 01/26/2023 Expires: 01/15/2025 Termination: 03/07/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0501 Process Wastewater - Unregulated
0601 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 15-Nov-2023
18-Jan-2024

Monitoring: 0501 12-Sep-2023
0501 13-Sep-2023
0601 12-Sep-2023
0601 13-Sep-2023
0801 12-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Needham

Fortune Metal Finishing Corp.

Facility ID: 23002853

95 Hampton Street
Needham, MA 02494

Permit: Issued: 01/24/2023 Expires: 01/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Tumbling & deburring effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 2

Inspections: 05-Sep-2023
16-Feb-2024

Monitoring: 0101 27-Sep-2023
0101 31-Oct-2023
0101 23-Jan-2024
0101 18-Apr-2024
0101 21-May-2024
9100 31-Oct-2023

Enforcement Actions: 14-Feb-2023 Notice of Violation
12-Feb-2024 Notice of Violation
06-Jun-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Microwave Development Labs, Inc.

Facility ID: 23002892

135 Crescent Road
Needham, MA 02494

Permit: Issued: 10/03/2023 Expires: 08/15/2025
Issued: 02/28/2022 Expires: 08/15/2023 Amended: 11/23/2022 Termination: 10/02/2023

National Pretreatment Categorical Standards: 01-Apr-1991 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated metal finishing of aluminum and copper

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES B Quarter: 2

Inspections: 07-Jul-2023
14-Dec-2023

Monitoring: 0101 05-Oct-2023
0101 13-Dec-2023
0101 14-Dec-2023
0101 17-Apr-2024
0101 18-Apr-2024
0101 21-May-2024
9100 05-Oct-2023

Enforcement Actions: 13-May-2024 Notice of Violation
26-Jun-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Newton

City of Newton DPW - Fleet Services	Facility ID:	24409450
110 Crafts Street Newton, MA 02458		

Permit: Issued: 12/27/2022 Expires: 10/15/2024 Amended: 08/28/2024
Issued: 12/27/2022 Expires: 10/15/2024 Termination: 08/27/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Vehilce washing effluent.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Nov-2023
09-May-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA Riverside Carhouse

Facility ID: 24003508

325 Grove Street
Newton, MA 02165

Permit: Issued: 10/11/2023 Expires: 09/15/2025
Issued: 02/07/2022 Expires: 09/15/2023 Amended: 11/23/2022 Termination: 10/10/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated wastewater from washing of trolleys

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Aug-2023
29-Dec-2023

Monitoring: 0101 15-Nov-2023
0101 20-Nov-2023
0101 18-Mar-2024

Enforcement Actions: 25-Aug-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Materion Newton, Inc.

Facility ID: 24003511

45 Industrial Place
Newton, MA 02461

Permit: Issued: 09/08/2023 Expires: 08/15/2025
Issued: 03/17/2022 Expires: 08/15/2023 Amended: 11/23/2022 Termination: 09/07/2023

National Pretreatment Categorical Standards: 26-Jun-2007 to 421.115 K Nonferrous Metals Manufacturing
26-Jun-2007 to 471.54 E Nonferrous Metals Forming and Metal Powders

MWRA Category: 01

<u>Sample Locations:</u>	0102	Process Wastewater - Unregulated	Ta powder washing operations
	0301	Process Wastewater - Unregulated	Lab (glassware/cleaning bath) sink discharge
	0401	Process Wastewater - Regulated	leaching of tantalum powder with hydrogen peroxide and H2SO4
	0602	Process Wastewater - Regulated	(n) large, medium, small Billcos washing units, intermediate mill ultras
		Process Wastewater - Regulated	(t) water jet cutter
		Process Wastewater - Regulated	(w) tubing ultrasonic test, tubing hydrostatic test, disc ultrasonic test
		Process Wastewater - Regulated	(o) large, medium, small Billcos, intermediate mill ultrasonic rinsing uni
	0603	Process Wastewater - Unregulated	wastewater from Ta milled products
	0901		

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 15-Aug-2023
19-Dec-2023

<u>Monitoring:</u>	0102	23-Oct-2023
	0301	25-Jul-2023
	0401	23-Oct-2023
	0401	18-Mar-2024
	0602	25-Jul-2023
	0602	13-Dec-2023
	0602	14-Dec-2023
	0603	25-Jul-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Newton-Wellesley Hospital

Facility ID: 24005761

2014 Washington Street
Newton, MA 02462

Permit: Issued: 06/28/2024 Expires: 04/15/2026
Issued: 05/31/2022 Expires: 04/15/2024 Amended: 11/23/2022 Termination: 06/27/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	Hospital laboratory wastewater
	0102	Process Wastewater - Unregulated	
	0133	Process Wastewater - Unregulated	
	0136	Process Wastewater - Unregulated	A steam sterilizer
	0137	Process Wastewater - Unregulated	
	0140	Process Wastewater - Unregulated	bank of 3 sinks
	0141	Process Wastewater - Unregulated	bank of 3 sinks
	0142	Process Wastewater - Unregulated	
	0143	Process Wastewater - Unregulated	
	0144	Process Wastewater - Unregulated	
	0145	Process Wastewater - Unregulated	
	0146	Process Wastewater - Unregulated	
	0147	Process Wastewater - Unregulated	
	0153	Process Wastewater - Unregulated	Endoscope scope washing and rinsing wastewater
	0154	Process Wastewater - Unregulated	Ultrasonic, Endoscope, and Irrigator effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 18-Oct-2023
05-Apr-2024

<u>Monitoring:</u>	0101	14-Aug-2023
	0101	15-Aug-2023
	0102	16-Aug-2023
	0133	14-Aug-2023
	0133	22-Dec-2023
	0136	15-Aug-2023
	0137	14-Aug-2023
	0137	15-Aug-2023
	0140	15-Aug-2023
	0141	15-Aug-2023
	0142	15-Aug-2023
	0143	15-Aug-2023
	0144	15-Aug-2023
	0145	14-Aug-2023

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

<i>Newton-Wellesley Hospital</i>		Facility ID:	24005761
2014 Washington Street Newton, MA 02462			

0146	14-Aug-2023
0147	14-Aug-2023
0153	21-Dec-2023
0154	16-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Norwood

<i>Absolute Metal Finishing, Inc.</i>	Facility ID:	25100244
90 Morse Street Norwood, MA 02062		

Permit: Issued: 10/23/2023 Expires: 09/15/2025
Issued: 12/30/2021 Expires: 09/15/2023 Amended: 11/23/2022 Termination: 10/22/2023

National Pretreatment Categorical Standards: 03-Aug-2007 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Metal finishing operations
0102 OTHER_DESC cyanide treatment

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Aug-2023
18-Jan-2024

Monitoring: 0101 14-Sep-2023
0101 07-Dec-2023
0101 31-Jan-2024
0102 14-Sep-2023

Enforcement Actions: 31-Jan-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Goldman Kolber, LLC (GK Jewelry Inc.)

Facility ID: 25101050

185 Dean Street
Norwood, MA 02062

Permit: Issued: 10/03/2019 Expires: 10/15/2023 Amended: 11/23/2022

National Pretreatment Categorical Standards: 02-Jan-1996 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations:

Reason for SIU Status: Is a CIU without flow.

SNC: YES F3 Quarter: 1
F3 Quarter: 3

Inspections: 01-Nov-2023
23-Feb-2024

Monitoring:

Enforcement Actions: 26-Aug-2022 Notice of Violation
03-Mar-2023 Notice of Violation
14-Sep-2023 Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Home Market Foods, Inc.

Facility ID: 25103149

140 Morgan Drive
Norwood, MA 02062

Permit: Issued: 05/13/2024 Expires: 11/15/2025
Issued: 03/16/2022 Expires: 11/15/2023 Amended: 11/23/2022 Termination: 05/12/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Food processing wastewater

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 13-Dec-2023
11-Apr-2024

Monitoring: 0101 25-Mar-2024
0101 26-Mar-2024

Enforcement Actions: 01-Sep-2022 Notice of Violation
12-Sep-2023 Notice of Violation
29-Dec-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Organogenesis Inc.

Facility ID: 25407804

333 Providence Highway
Norwood, MA 02062

Permit: Issued: 03/25/2024 Expires: 01/15/2028
Issued: 03/03/2020 Expires: 01/15/2024 Amended: 11/23/2022 Termination: 03/24/2024

National Pretreatment Categorical Standards: 02-Jul-2019 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated pharmaceutical wastewater
0102 Process Wastewater - Unregulated Lab sinks and parts washer

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 10-Jan-2024
07-May-2024

Monitoring: 0101 04-Apr-2024
0102 16-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Steel Art Co., Inc.

Facility ID: 25403864

189 Dean Street
Norwood, MA 02062

Permit: Issued: 06/25/2021 Expires: 06/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards: 01-Jul-2012 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations:

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 09-Aug-2023

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

TecMark Plating

Facility ID: 25003993

61 Endicott Street Building #5
Norwood, MA 02062

Permit: Issued: 10/23/2023 Expires: 08/15/2025
Issued: 10/19/2021 Expires: 08/15/2023 Amended: 11/23/2022 Termination: 10/22/2023

National Pretreatment Categorical Standards: 02-Apr-1991 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Circuit manufacturing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 10-Jul-2023
16-Jan-2024

Monitoring: 0101 08-Nov-2023
0101 01-Feb-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Quincy

City of Quincy DPW (Truck Wash Facility)	Facility ID:	26404189
55 -R Sea Street Quincy, MA 02169		

Permit: Issued: 10/03/2023 Expires: 10/15/2025
Issued: 03/17/2022 Expires: 10/15/2023 Amended: 11/23/2022 Termination: 10/02/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Vehicle wash

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Sep-2023
29-Feb-2024

Monitoring: 0101 04-Oct-2023
0101 31-Oct-2023
0101 16-Apr-2024
9100 04-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA - Quincy Bus Garage

Facility ID: 26101131

954 Hancock Street
Quincy, MA 02169

Permit: Issued: 11/15/2023 Expires: 07/15/2025
Issued: 06/17/2021 Expires: 07/15/2023 Amended: 11/23/2022 Termination: 11/14/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 22-Sep-2023
04-Mar-2024

Monitoring: 0101 26-Sep-2023
0101 20-May-2024
0101 17-Jun-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Quincy AutoAuction

Facility ID: 26103080

196 Ricciuti Drive
Quincy, MA 02169

Permit: Issued: 05/18/2023 Expires: 04/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Vehicle Washing with detergent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 15-Dec-2023
09-May-2024

Monitoring: 0101 07-Sep-2023
0101 13-Dec-2023
0101 17-Apr-2024
9100 07-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

South Shore Plating Co., Inc.

Facility ID: 26005040

28 Forest Avenue
Quincy, MA 02169

Permit: Issued: 03/20/2023 Expires: 02/15/2025

National Pretreatment Categorical Standards: 10-Jul-1992 to 413.14 A Electroplating

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Metal Finishing Operation

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 23-Aug-2023
30-Jan-2024

Monitoring: 0101 12-Sep-2023
0101 17-Jan-2024

Enforcement Actions: 22-Dec-2022 Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Twin Rivers Technologies Manufacturing Corporation

Facility ID: 26101157

780 Washington Street
Quincy, MA 02169

Permit: Issued: 03/14/2024 Expires: 11/15/2025
Issued: 03/17/2022 Expires: 11/15/2023 Amended: 11/23/2022 Termination: 03/13/2024

National Pretreatment Categorical Standards: 23-Jul-1999 to 417.24 B Soap and Detergent Manufacturing

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC fatty acids and glycerin

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 29-Nov-2023
31-May-2024

Monitoring: 0101 07-Sep-2023
0101 26-Sep-2023
0101 27-Sep-2023
0101 11-Mar-2024
0101 12-Mar-2024
0101 20-May-2024
0101 21-May-2024
9100 07-Sep-2023

Enforcement Actions: 02-Jun-2023 Notice of Violation
10-Jul-2023 Notice of Violation
28-Sep-2023 Notice of Noncompliance
03-May-2024 Notice of Violation
11-Jun-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Randolph

Accurate Metal Finishing, LLC

Facility ID: 27001200

414 South Street
Randolph, MA 02368

Permit: Issued: 01/10/2023 Expires: 10/15/2024

National Pretreatment Categorical Standards: 14-Jun-2002 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Metal Finishing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 15-Mar-2024
25-Jun-2024

Monitoring: 0101 13-Sep-2023
0101 07-Dec-2023
0101 06-Mar-2024

Enforcement Actions: 14-Feb-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

BFI Waste Systems of North America, Inc.

Facility ID: 27007148

62 Johnson Drive
Randolph, MA 02368

Permit: Issued: 04/12/2023 Expires: 05/15/2027

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 14-Jul-2023
02-Feb-2024

<u>Monitoring:</u>	0101	13-Sep-2023
	0101	14-Sep-2023
	0101	07-Dec-2023
	0101	08-Dec-2023
	0101	06-Mar-2024
	0101	07-Mar-2024
	0101	20-Mar-2024
	0101	21-Mar-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Flexcon Industries

Facility ID: 27007231

300 Pond Street
Randolph, MA 02368

Permit: Issued: 06/25/2021 Expires: 03/15/2025 Amended: 12/01/2023
Issued: 06/25/2021 Expires: 03/15/2025 Amended: 08/19/2021 Termination: 11/30/2023

National Pretreatment Categorical Standards: 01-Jul-1990 to 433.17 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 OTHER_DESC Phosphating Line

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 06-Nov-2023
16-May-2024

Monitoring: 0101 13-Sep-2023
0101 07-Dec-2023
0101 05-Mar-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Trelleborg Offshore Boston Inc. (fka TrelleborgAppliedTech)

Facility ID: 27101860

24 Teed Drive
Randolph, MA 02368

Permit: Issued: 12/04/2023 Expires: 10/15/2025
Issued: 03/24/2022 Expires: 10/15/2023 Amended: 11/23/2022 Termination: 12/03/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Nov-2023
08-May-2024

Monitoring: 0101 13-Sep-2023
0101 14-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Roxbury

BWSC Truck Wash Facility	Facility ID: 54404742
980 Harrison Avenue Roxbury, MA 02119	

Permit: Issued: 03/08/2024 Expires: 02/15/2026
Issued: 06/10/2022 Expires: 02/15/2024 Termination: 03/07/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated truck washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 19-Jul-2023
03-Jan-2024

Monitoring: 0101 04-Oct-2023
0101 31-Oct-2023
0101 24-Apr-2024
9100 04-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA Southhampton Street Maintenance Facility

Facility ID: 54103220

240 Southhampton Street
Roxbury, MA 02118

Permit: Issued: 08/23/2023 Expires: 06/15/2025
Issued: 06/17/2021 Expires: 06/15/2023 Amended: 08/20/2021 Termination: 08/22/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC bus washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 27-Sep-2023
21-Mar-2024

Monitoring: 0101 29-Aug-2023
0101 30-Aug-2023
0101 23-Apr-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

New England Baptist Hospital

Facility ID: 54101786

125 Parker Hill Avenue
Roxbury, MA 02120

Permit: Issued: 08/31/2023 Expires: 06/15/2027
Issued: 05/23/2019 Expires: 06/15/2023 Amended: 08/20/2021 Termination: 08/30/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	Surgical Training and Histology
	0103	Process Wastewater - Unregulated	surgical instrument cleaning
	0201	OTHER_DESC	Medical laboratories

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 13-Oct-2023
19-Mar-2024

<u>Monitoring:</u>	0101	08-Jan-2024
	0103	30-Aug-2023
	0103	31-Aug-2023
	0103	08-Jan-2024
	0103	09-Jan-2024
	0201	30-Aug-2023

Enforcement Actions: 06-Jul-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

United Rentals (North America), Inc.

Facility ID: 54102393

133 Southamptton Street
Roxbury, MA 02118

Permit: Issued: 05/29/2024
Issued: 06/06/2022

Expires: 06/15/2026
Expires: 06/15/2024

Termination: 05/28/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0201 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Dec-2023
02-May-2024

Monitoring: 0201 12-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Somerville

Century Linen East LLC	Facility ID:	30103290
30 Innerbelt Road Somerville, MA 02143		

Permit: Issued: 01/27/2023 Expires: 02/15/2027

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: YES F3 Quarter: 3

Inspections: 02-Jan-2024
04-Jun-2024

Monitoring: 0101 26-Oct-2023
0101 12-Dec-2023
0101 13-Dec-2023

Enforcement Actions: 22-Dec-2022 Notice of Noncompliance
17-Mar-2023 Notice of Violation
18-May-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Keolis Commuter Services, LLC

Facility ID: 30102003

70 Rear Third Avenue
Somerville, MA 02143

Permit: Issued: 03/07/2023 Expires: 03/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Train maintenance wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 31-Aug-2023
08-Mar-2024

Monitoring: 0101 30-Nov-2023
0101 13-Dec-2023
0101 29-Feb-2024

<u>Enforcement Actions:</u>	20-Jan-2023	Returned to Permit Letter
	18-May-2023	Notice of Violation
	14-Jun-2023	Notice of Violation
	09-Nov-2023	Notice of Violation
	07-Dec-2023	Notice of Violation
	21-Mar-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Royal Hospitality Services, Inc.

Facility ID: 30007496

520 Columbia Street
Somerville, MA 02143

Permit: Issued: 06/06/2022 Expires: 04/15/2026 Amended: 11/23/2022

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Laundry effluent

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 17-Nov-2023
11-Apr-2024

Monitoring: 0101 26-Oct-2023
0101 27-Oct-2023
0101 12-Dec-2023
0101 13-Dec-2023
0101 30-Jan-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Tracer Technologies, Inc.

Facility ID: 30006705

20 Assembly Square Drive
Somerville, MA 02145

Permit: Issued: 03/19/2024 Expires: 03/15/2028
Issued: 03/16/2019 Expires: 03/15/2024 Amended: 11/23/2022 Termination: 03/18/2024

National Pretreatment Categorical Standards: 15-May-1992 to 461.55 E Battery Manufacturing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 22-Sep-2023
08-Feb-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

South Boston

Great Eastern Seafood	Facility ID: 55002326
88 Black Falcon Avenue Suite 160 South Boston, MA 02210	

Permit: Issued: 08/30/2022 Expires: 08/15/2026

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0201 Process Wastewater - Unregulated fresh and frozen fish processing

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 08-Dec-2023
16-May-2024

Monitoring: 0201 05-Jun-2024
0201 07-Jun-2024

Enforcement Actions: 06-Dec-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

MBTA - Cabot Yard

Facility ID: 55100009

275 Dorchester Avenue
South Boston, MA 02127

Permit: Issued: 10/31/2023 Expires: 11/15/2025
Issued: 03/16/2022 Expires: 11/15/2023 Termination: 10/30/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Bus wash wastewater
0201 Process Wastewater - Unregulated Train wash wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 11-Oct-2023
13-Mar-2024

Monitoring: 0101 03-Oct-2023
0101 04-Oct-2023
0101 14-May-2024
0101 15-May-2024
0101 05-Jun-2024
0101 06-Jun-2024
0201 24-Oct-2023
0201 16-May-2024
0201 13-Jun-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Mass Bay Brewing Company Inc.

Facility ID: 55006785

306 Northern Avenue
South Boston, MA 02210

Permit: Issued: 02/25/2022 Expires: 02/15/2026

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Cleaning and Sterilizing Ops.

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 27-Jul-2023
11-Jan-2024

Monitoring: 0101 29-Jan-2024
0101 30-Jan-2024
0101 28-Feb-2024
0101 29-Feb-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Massachusetts Department of Transportation (S.Bos VB #1&5)

Facility ID: 55103065

55 Dorchester Avenue Building 1
South Boston, MA 02127

Permit: Issued: 06/10/2022 Expires: 04/15/2026 Amended: 05/08/2024
Issued: 06/10/2022 Expires: 04/15/2024 Termination: 05/07/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated
0201 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES F3 Quarter: 3

Inspections: 31-Oct-2023
14-May-2024

Monitoring: 0101 19-Jul-2023
0201 19-Jul-2023

Enforcement Actions: 14-Dec-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Massachusetts Department of Transportation (Ted W VB #6)

Facility ID: 55008794

2 FID Kennedy Avenue VB #6
South Boston, MA 02210

Permit: Issued: 06/09/2022 Expires: 04/15/2026

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 23-Jan-2024
14-May-2024

Monitoring: 0101 02-Nov-2023
0101 05-Dec-2023

Enforcement Actions: 15-Nov-2022 Notice of Violation
07-Jul-2023 Notice of Violation
14-Dec-2023 Notice of Violation
17-Jun-2024 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

National Railroad Passenger Corporation (Amtrak)

Facility ID: 55007691

2 Frontage Road
South Boston, MA 02118

Permit: Issued: 06/28/2024
Issued: 06/06/2022

Expires: 05/15/2026
Expires: 05/15/2024

Termination: 06/27/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 28-Nov-2023
04-Apr-2024

Monitoring: 0101 23-Aug-2023
0101 18-Mar-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

North Coast Seafoods

Facility ID: 55002026

5 Drydock Avenue
South Boston, MA 02210

Permit: Issued: 10/31/2023 Expires: 11/15/2025
Issued: 03/16/2022 Expires: 11/15/2023 Termination: 10/30/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 19-Oct-2023
11-Mar-2024

Monitoring: 0101 15-Feb-2024
0101 16-Feb-2024

Enforcement Actions: 03-Mar-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

TEI Biosciences, Inc.

Facility ID: 55101116

7 Elkins Street
South Boston, MA 02127

Permit: Issued: 08/11/2023 Expires: 06/15/2025
Issued: 07/16/2021 Expires: 06/15/2023 Amended: 08/20/2021 Termination: 08/10/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Operations, lab sinks

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 30-Aug-2023
19-Jan-2024

Monitoring: 0101 05-Feb-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

The Gillette Company, LLC

Facility ID: 55001985

One Gillette Park
South Boston, MA 02127

Permit: Issued: 08/02/2024 Expires: 08/15/2026
Issued: 12/20/2022 Expires: 08/15/2024 Termination: 08/01/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0105 Process Wastewater - Unregulated Automatic blade washer effluent
1201 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Sep-2023
16-Feb-2024

Monitoring: 0105 06-Dec-2023
0105 03-May-2024
1201 06-Dec-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Vertex Pharmaceuticals, Inc.

Facility ID: 55404075

1 Harbor Street
South Boston, MA 02210

Permit: Issued: 06/06/2022 Expires: 10/15/2025

National Pretreatment Categorical Standards: 01-Oct-2013 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Pharmaceutical R&D lab wastewater
0102 Process Wastewater - Regulated

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 28-Aug-2023
18-Apr-2024

Monitoring: 0101 03-Jan-2024
0101 04-Jan-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Stoughton

Tradebe Treatment and Recycling of Stoughton, LLC

Facility ID: 32004859

441 R Canton Street
Stoughton, MA 02072

Permit: Issued: 03/10/2023 Expires: 04/15/2025

National Pretreatment Categorical Standards: 01-Mar-2009 to 437.47 D Centralized Waste Treatment

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated hazardous & nonhazardous waste treatment

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 07-Sep-2023
13-Mar-2024

Monitoring: 0101 01-Nov-2023
0101 19-Dec-2023
0101 11-Mar-2024
0101 12-Mar-2024

Enforcement Actions: 26-Aug-2022 Notice of Violation
02-Sep-2022 Notice of Violation
21-Sep-2022 Notice of Violation
02-Dec-2022 Notice of Violation
14-Dec-2022 Notice of Violation
16-Mar-2023 Penalty Assessment Notice
16-Mar-2023 Administrative Order
05-Apr-2023 Extension of NON/OTCA/EO/SOC/NPPR Letter
13-Apr-2023 Appeal
23-Aug-2023 Administrative Settlement

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Wakefield

<i>Xyleco, Inc</i>	Facility ID:	33404577
360 Audubon Road Wakefield, MA 01880		

Permit: Issued: 11/02/2023 Expires: 11/15/2025
Issued: 03/16/2022 Expires: 11/15/2023 Termination: 11/01/2023

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Oct-2023
21-Mar-2024

Monitoring: 0101 06-Dec-2023
0101 07-Dec-2023
0101 28-Feb-2024
0101 14-May-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Walpole

Edward J. Delaney Water Treatment Facility

Facility ID: 34101766

1303 Washington Street
Walpole, MA 02081

Permit: Issued: 01/05/2023 Expires: 12/15/2026

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Recycled back wash water

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 08-Dec-2023
24-May-2024

Monitoring: 0101 07-Nov-2023
0101 05-Feb-2024
0101 03-Apr-2024
9100 07-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Hollingsworth & Vose Company	Facility ID: 34001921
112 Washington Street Walpole, MA 02032	

Permit: Issued: 01/24/2023 Expires: 01/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated wastewater from paper manufacturing

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 22-Aug-2023
20-Feb-2024

Monitoring: 0101 25-Sep-2023
0101 26-Sep-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Waltham

Acton Metal Processing Corporation

Facility ID: 35004598

41 Athletic Field Road
Waltham, MA 02451

Permit: Issued: 05/29/2024 Expires: 06/15/2026
Issued: 06/09/2022 Expires: 06/15/2024 Termination: 05/28/2024

National Pretreatment Categorical Standards: 30-Sep-2002 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 18-Dec-2023
10-May-2024

Monitoring: 0101 15-Nov-2023
0101 16-Nov-2023
0101 17-Jan-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Brandeis University

Facility ID: 35005368

415 South Street
Waltham, MA 02454

Permit: Issued: 01/20/2023 Expires: 01/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	General science and biochem labs on the top three floors of Kosow
	0103	OTHER_DESC	Chemistry, Biology, Life Science and Physics Laboratories
	0104	OTHER_DESC	Biology Laboratories
	0105	OTHER_DESC	Animal care facility
	0107	OTHER_DESC	Basic Medical Science Laboratories
	0108	Process Wastewater - Unregulated	
	0109	Process Wastewater - Unregulated	

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 10-Aug-2023
19-Jan-2024

<u>Monitoring:</u>	0101	17-Jan-2024
	0101	06-May-2024
	0103	26-Feb-2024
	0103	27-Feb-2024
	0103	09-Apr-2024
	0103	06-May-2024
	0103	07-May-2024
	0104	26-Feb-2024
	0104	27-Feb-2024
	0105	18-Jan-2024
	0107	16-Jan-2024
	0107	17-Jan-2024
	0107	27-Feb-2024
	0107	28-Feb-2024
	0108	17-Jan-2024
	0109	17-Jan-2024

<u>Enforcement Actions:</u>	30-Jun-2022	Notice of Violation
	22-Jan-2024	Notice of Violation
	15-May-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Giner, Inc.

Facility ID: 35004157

89 Rumford Avenue
Waltham, MA 02466

Permit: Issued: 04/24/2024 Expires: 04/15/2028
Issued: 02/05/2020 Expires: 12/15/2023 Amended: 08/19/2021 Termination: 04/23/2024

National Pretreatment Categorical Standards: 04-Mar-1994 to 433.17 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated
0104

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES F3 Quarter: 1
A Quarter: 3
B Quarter: 3
F3 Quarter: 3
B Quarter: 4

Inspections: 28-Nov-2023
22-Apr-2024

Monitoring: 0101 11-Oct-2023
0101 11-Apr-2024

Enforcement Actions: 21-Sep-2022 Notice of Noncompliance
02-Mar-2023 Returned to Permit Letter
16-Oct-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Nova Biomedical Corporation

Facility ID: 35006361

200 Prospect Street
Waltham, MA 02454

Permit: Issued: 09/19/2022 Expires: 10/15/2024

National Pretreatment Categorical Standards: 21-May-2010 to 433.17 A Metal Finishing

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Regulated
		Process Wastewater - Unregulated
	0105	Process Wastewater - Unregulated
	0107	
	0109	Process Wastewater - Unregulated

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 19-Sep-2023
06-Feb-2024

<u>Monitoring:</u>	0101	10-Oct-2023
	0101	11-Oct-2023
	0105	11-Oct-2023
	0109	11-Oct-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Plating for Electronics, Inc.

Facility ID: 35006562

94 Calvary Street
Waltham, MA 02453

Permit: Issued: 12/04/2023 Expires: 12/15/2025
Issued: 04/26/2022 Expires: 12/15/2023 Termination: 12/03/2023

National Pretreatment Categorical Standards: 16-May-2007 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated
0102 Cyanide Waste Stream

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 08-Nov-2023
16-Apr-2024

Monitoring: 0101 14-Nov-2023
0101 15-Nov-2023
0101 17-Jan-2024
0101 10-Apr-2024
0101 25-Jun-2024
0102 14-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Queen Screw & Mfg. Inc.	Facility ID: 35100124
60 Farwell Street Waltham, MA 02453	

Permit: Issued: 03/24/2022 Expires: 11/15/2026

National Pretreatment Categorical Standards: 01-Nov-2016 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 14-Feb-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Watertown

EyePoint Pharmaceuticals	Facility ID: 36102959
480 Pleasant Street Suite B300 Watertown, MA 02472	

Permit: Issued: 10/31/2022 Expires: 10/15/2026 Amended: 10/18/2023
Issued: 10/31/2022 Expires: 10/15/2026 Termination: 10/17/2023

National Pretreatment Categorical Standards: 04-Mar-2002 to 439.16 A Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated
0102 Process Wastewater - Unregulated
0103 Process Wastewater - Regulated Non-discharging Fed Cat 439

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 01-Aug-2023
11-Jun-2024

Monitoring: 0101 07-May-2024
0102 11-Jan-2024
0104 11-Jan-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

West Roxbury

VA Boston Healthcare System	Facility ID: 56005702
1400 VFW Parkway 138-S West Roxbury, MA 02132	

Permit: Issued: 09/18/2023 Expires: 07/15/2027
Issued: 06/26/2019 Expires: 07/15/2023 Amended: 08/20/2021 Termination: 09/17/2023

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	Clinical and research labs.
	0102	OTHER_DESC	Clinical and research labs.
	0103	Process Wastewater - Unregulated	Surgical instrument cleaning
	0104	Process Wastewater - Unregulated	Animal Cage Washer
	0105	Process Wastewater - Unregulated	Sterilizer, Building 21
	0206	Process Wastewater - Unregulated	
	0207	Process Wastewater - Unregulated	

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 1
B Quarter: 4

Inspections: 12-Oct-2023
28-Jun-2024

<u>Monitoring:</u>	0101	28-Sep-2023
	0101	29-Sep-2023
	0101	21-Dec-2023
	0101	14-Mar-2024
	0102	28-Sep-2023
	0102	13-Mar-2024
	0102	14-Mar-2024
	0103	13-Mar-2024
	0103	14-Mar-2024
	0104	21-Dec-2023
	0105	21-Dec-2023
	0105	14-Mar-2024
	0206	21-Dec-2023
	0206	14-Mar-2024
	0206	28-Jun-2024

<u>Enforcement Actions:</u>	17-Jan-2023	Notice of Violation
	01-Feb-2024	Notice of Violation
	26-Mar-2024	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Westwood

<i>Romanow Container</i>	Facility ID:	38101644
346 University Avenue Westwood, MA 02090		

Permit: Issued: 01/20/2023 Expires: 01/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Ink wastewater from treatment system

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 13-Nov-2023
21-Feb-2024

Monitoring: 0101 12-Sep-2023

Enforcement Actions: 03-Aug-2022 Notice of Noncompliance
28-Nov-2022 Ruling on Req for recon of NON/OTCA/EO/SOC/NPPR
06-Jan-2023 Returned to Permit Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Weymouth

Calpine Fore River Energy Center, LLC	Facility ID: 39102547
9 Bridge Street Weymouth, MA 02191	

Permit: Issued: 11/15/2023 Expires: 08/15/2025
Issued: 01/06/2022 Expires: 08/15/2023 Termination: 11/14/2023

National Pretreatment Categorical Standards: 21-May-2007 to 423.17 N/A Steam Electric Power Generating

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated power plant discharge

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 18-Jul-2023
12-Jan-2024

Monitoring: 0101 14-Nov-2023
0101 10-Jan-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Great Pond Water Treatment Plant

Facility ID: 39102335

239 Pond Street
Weymouth, MA 02190

Permit: Issued: 05/18/2023 Expires: 03/15/2027 Amended: 03/11/2024
Issued: 05/18/2023 Expires: 03/15/2027 Termination: 03/10/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Residuals discharge
0103 OTHER_DESC Water quality laboratory wastewater

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: YES A Quarter: 1
F3 Quarter: 1
A Quarter: 2
F3 Quarter: 2
F3 Quarter: 3

Inspections: 30-Jan-2024

Monitoring: 0101 19-Oct-2023
0101 09-Nov-2023
0101 05-Feb-2024
0101 06-Feb-2024
0101 21-Feb-2024
0101 20-Mar-2024
0101 21-Mar-2024
0103 18-Oct-2023
0103 19-Oct-2023
0103 09-Nov-2023
9100 09-Nov-2023
9100 21-Feb-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

South Shore Hospital

Facility ID: 39005749

55 Fogg Road
Weymouth, MA 02190

Permit: Issued: 04/03/2024 Expires: 12/15/2027
Issued: 04/05/2019 Expires: 12/15/2023 Amended: 08/19/2021 Termination: 04/02/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0501	OTHER_DESC	Clinical laboratory wastewater
	0601	OTHER_DESC	Washwater from stainless steel hospital carts
	0701	Process Wastewater - Unregulated	lab wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 07-Dec-2023
03-May-2024

<u>Monitoring:</u>	0501	30-Oct-2023
	0501	31-Oct-2023
	0601	30-Oct-2023
	0701	30-Oct-2023

<u>Enforcement Actions:</u>	03-Mar-2023	Notice of Violation
	15-Mar-2023	Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Wilmington

Allcoat Technology, Inc.

Facility ID: 40003193

100 Eames Street
Wilmington, MA 01887

Permit: Issued: 08/26/2020 Expires: 05/15/2025 Amended: 08/20/2021

National Pretreatment Categorical Standards: 15-Mar-1996 to 414.45 D Organic Chemicals, Plastics, and Synthetic Fibers
15-Mar-1996 to 414.55 E Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 04

Sample Locations: 0105 OTHER_DESC Non-discharging fed cat process

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 11-Mar-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Analog Devices, Inc./Wilmington Manufacturing

Facility ID: 40005633

1 Analog Way
Wilmington, MA 01887-3462

Permit: Issued: 03/28/2023 Expires: 04/15/2025

National Pretreatment Categorical Standards: 01-Apr-1991 to 433.17 A Metal Finishing
01-Apr-1991 to 469.16 A Electrical and Electronic Components

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated Semiconductor manufacturing discharge
Process Wastewater - Unregulated Incoming water treatment discharge
0105 Process Wastewater - Regulated Semiconductor manufacturing discharge
Process Wastewater - Regulated Metal plating operations

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 04-Dec-2023
18-Apr-2024

Monitoring: 0101 11-Jul-2023
0101 12-Jul-2023
0101 13-Dec-2023
0101 14-Dec-2023
0105 11-Jul-2023
0105 12-Jul-2023
0105 13-Dec-2023
0105 14-Dec-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

CHEP Services

Facility ID: 40408129

1 Burlington Avenue
Wilmington, MA 01887

Permit: Issued: 01/20/2023 Expires: 01/15/2025

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated aqua klippa unit wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 19-Oct-2023
10-Apr-2024

Monitoring: 0101 17-Jul-2023
0101 18-Jul-2023
0101 31-Oct-2023
0101 24-Jan-2024

Enforcement Actions: 23-Aug-2022 Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Conformis, Inc.

Facility ID: 40404506

600 Research Drive
Wilmington, MA 01887

Permit: Issued: 04/02/2020 Expires: 03/15/2025 Amended: 08/19/2021

National Pretreatment Categorical Standards: 13-Sep-2019 to 433.17 A Metal Finishing

MWRA Category: 02

<u>Sample Locations:</u>	0101	Process Wastewater - Regulated	Metal Parts Passivation Line
	0102	Process Wastewater - Regulated	Final parts cleaning line
	0103	Process Wastewater - Regulated	Non-discharging federally regulated operations

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 06-Feb-2024
20-May-2024

<u>Monitoring:</u>	0101	30-Aug-2023
	0101	16-Nov-2023
	0102	28-Aug-2023
	0102	29-Aug-2023
	0102	16-Nov-2023
	0102	17-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Covestro, LLC

Facility ID: 40004688

730 Main Street
Wilmington, MA 01887-3366

Permit: Issued: 12/21/2022 Expires: 10/15/2024

National Pretreatment Categorical Standards: 29-Jan-1993 to 414.45 D Organic Chemicals, Plastics, and Synthetic Fibers
29-Jan-1993 to 414.55 E Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated Process wastewater from organic coating, resin, and chemical manufa

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES B Quarter: 3
B Quarter: 4

Inspections: 01-Mar-2024
10-May-2024

Monitoring: 0101 13-Jul-2023
0101 21-Nov-2023
0101 22-Nov-2023

Enforcement Actions: 03-Aug-2023 Notice of Violation
21- Aug-2023 Notice of Violation
22- Sep-2023 Notice of Violation
05-Apr-2024 Notice of Noncompliance
15-Apr-2024 Extension of NON/OTCA/EO/SOC/NPPR Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Kovalus Separation Solutions

Facility ID: 40000409

850 Main Street
Wilmington, MA 01887

<u>Permit:</u>	Issued: 10/23/2023	Expires: 07/15/2025	Amended: 08/06/2024	
	Issued: 10/23/2023	Expires: 07/15/2025		Termination: 08/05/2024
	Issued: 06/25/2021	Expires: 07/15/2023	Amended: 08/19/2021	Termination: 10/22/2023

<u>National Pretreatment Categorical Standards:</u>	23-May-2009	to	463.16 A Plastics Molding and Forming
	23-May-2009	to	463.26 B Plastics Molding and Forming
	23-May-2009	to	463.36 C Plastics Molding and Forming
	23-May-2009	to	463.999 A Plastics Molding and Forming

MWRA Category: 01

Sample Locations: 0103 OTHER_DESC Filter manufacturing discharge

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Jan-2024
22-Apr-2024

<u>Monitoring:</u>	0103	12-Jul-2023
	0103	20-Nov-2023
	0103	21-Nov-2023
	0103	14-Dec-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Lubrizol Advanced Materials, Inc.

Facility ID: 40103056

207 Lowell Street
Wilmington, MA 01887

Permit: Issued: 05/01/2023 Expires: 05/15/2027

National Pretreatment Categorical Standards: 08-May-2007 to 414.55 E Organic Chemicals, Plastics, and
Synthetic Fibers
08-May-2007 to 463.15 A Plastics Molding and Forming

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Polyurethane pellets contact cooling wastewater
0102 Process Wastewater - Regulated Polyurethane tubing contact cooling wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 23-Oct-2023
10-Apr-2024

Monitoring: 0101 29-Aug-2023
0101 30-Aug-2023
0101 31-Aug-2023
0102 30-Aug-2023

Enforcement Actions: 10-Jan-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Monogram Gourmet Foods.LLC

Facility ID: 40103339

330 Ballardvale Street
Wilmington, MA 01887

Permit: Issued: 11/15/2022 Expires: 08/15/2026

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Food manufacturing wastewater

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 05-Mar-2024
22-May-2024

Monitoring: 0101 04-Jan-2024
0101 05-Jan-2024

Enforcement Actions: 31-May-2023 Notice of Noncompliance
25-Jul-2023 Extension of NON/OTCA/EO/SOC/NPPR Letter

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Scully Signal Company

Facility ID: 40003195

70 Industrial Way
Wilmington, MA 01887

Permit: Issued: 04/04/2024 Expires: 03/15/2029
Issued: 05/10/2019 Expires: 03/15/2024 Amended: 08/20/2021 Termination: 04/03/2024

National Pretreatment Categorical Standards: 26-Jun-1992 to 464.45 D Metal Molding and Casting

MWRA Category: 04

Sample Locations: 0103

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 16-Feb-2024
10-May-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Tecomet

Facility ID: 40005637

115 Eames Street
Wilmington, MA 01887

Permit: Issued: 07/17/2024 Expires: 07/15/2028
Issued: 08/26/2020 Expires: 07/15/2024 Amended: 08/19/2021 Termination: 07/16/2024

National Pretreatment Categorical Standards: 04-Oct-2005 to 471.34 C Nonferrous Metals Forming and Metal Powders
04-Oct-2005 to 471.64 F Nonferrous Metals Forming and Metal Powders
04-Oct-2005 to 471.94 I Nonferrous Metals Forming and Metal Powders

MWRA Category: 02

Sample Locations: 0104 Process Wastewater - Regulated Dye penetrant testing of parts
0109 OTHER_DESC Non-discharging metal finishing operations

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 17-Jan-2024
13-Jun-2024

Monitoring: 0104 30-Aug-2023
0104 31-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Winchester

Ceramic to Metal Seals, Inc.

Facility ID: 41403622

33 East Street
Winchester, MA 01890

Permit: Issued: 06/08/2021 Expires: 04/15/2026 Amended: 08/20/2021

National Pretreatment Categorical Standards: 25-May-2011 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 24-Oct-2023

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

<i>Olympic Systems Corporation</i>	Facility ID: 41007116
15 Lowell Avenue Winchester, MA 01890	

Permit: Issued: 03/12/2021 Expires: 01/15/2025 Amended: 08/20/2021

National Pretreatment Categorical Standards: 17-Dec-1991 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 19-Apr-2024

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Woburn

Abiomed Inc	Facility ID:	43406797
15 Presidential Way Woburn, MA 01801		

Permit: Issued: 01/10/2023 Expires: 01/15/2027

National Pretreatment Categorical Standards: 01-Feb-2016 to 469.18 A Electrical and Electronic Components

MWRA Category: 02

<u>Sample Locations:</u>	0102	Process Wastewater - Regulated	Semiconductor Operations
	0103	Process Wastewater - Regulated	Parts rinsing of MEMS devices

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 20-Nov-2023
10-May-2024

<u>Monitoring:</u>	0102	29-Aug-2023
	0103	29-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Atlantic Power Cleaning Corp.

Facility ID: 43404836

92 Merrimac Street
Woburn, MA 01801

Permit: Issued: 01/23/2023 Expires: 12/15/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Equipment and truck wash wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 19-Sep-2023
22-Feb-2024

Monitoring: 0101 05-Jun-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

CAES Mission Systems LLC	Facility ID: 43005100
10 Sonar Drive Woburn, MA 01801	

<u>Permit:</u>	Issued: 06/06/2022	Expires: 05/15/2026	Amended: 04/25/2024	
	Issued: 06/06/2022	Expires: 05/15/2026	Amended: 11/16/2023	Termination: 04/24/2024
	Issued: 06/06/2022	Expires: 05/15/2026		Termination: 11/15/2023

National Pretreatment Categorical Standards: 04-May-2001 to 433.15 A Metal Finishing

MWRA Category: 04

Sample Locations: 0105

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 16-Apr-2024

Monitoring:

Enforcement Actions: 09-Nov-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

High Precision Devices, Inc	Facility ID: 43404134
225 Wildwood Avenue Woburn, MA 01801	

Permit: Issued: 09/08/2023 Expires: 07/15/2028
Issued: 07/16/2018 Expires: 07/15/2023 Amended: 09/26/2022 Termination: 09/07/2023

National Pretreatment Categorical Standards: 19-Jul-2013 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101 OTHER_DESC Non-dishcharging fed cat

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 31-Jul-2023

Monitoring:

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Horn Pond Water Treatment Plant

Facility ID: 43103716

5 Cove Street
Woburn, MA 01801

Permit: Issued: 07/09/2024 Expires: 04/15/2028
Issued: 06/06/2022 Expires: 04/15/2024 Termination: 07/08/2024

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated WTP filter backwash
0102 OTHER_DESC Drinking Water Auto-Analyzer Discharge

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 03-Oct-2023
28-Feb-2024

Monitoring: 0101 29-Aug-2023
0101 18-Oct-2023
0101 04-Jan-2024
0102 28-Aug-2023
0102 29-Aug-2023
0102 07-Nov-2023
9100 07-Nov-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

II-VI Photonics (US), Inc.

Facility ID: 43103058

78 - A Olympia Avenue
Woburn, MA 01801

Permit: Issued: 10/26/2022 Expires: 11/15/2026

National Pretreatment Categorical Standards: 05-Nov-2002 to 469.16 A Electrical and Electronic
Components

MWRA Category: 02

Sample Locations: 0101 OTHER_DESC Semiconductor manufacturing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 29-Sep-2023
22-Feb-2024

Monitoring: 0101 28-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Parker Hannifin - Chomerics Division

Facility ID: 43005063

8 Commonwealth Avenue
Woburn, MA 01801

Permit: Issued: 09/22/2023 Expires: 10/15/2025
Issued: 02/28/2022 Expires: 10/15/2023 Termination: 09/21/2023

National Pretreatment Categorical Standards: 06-Apr-2011 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0106 Process Wastewater - Regulated Electroless plating effluent

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 13-Sep-2023
12-Feb-2024

Monitoring: 0106 29-Aug-2023
0106 31-Aug-2023

Enforcement Actions: 12-Sep-2023 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Photonwares, Inc. (formerly Agiltron Corporation)

Facility ID: 43403224

15 Presidential Way
Woburn, MA 01801

Permit: Issued: 03/16/2023 Expires: 03/15/2028

National Pretreatment Categorical Standards: 25-Oct-2018 to 469.18 A Electrical and Electronic
Components

MWRA Category: 04

Sample Locations: 0102 OTHER_DESC Non-dishcarging fed cat

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 24-Aug-2023

Monitoring:

Enforcement Actions: 08-Dec-2022 Notice of Violation

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Skyworks Solutions, Inc.

Facility ID: 43001045

20 Sylvan Road
Woburn, MA 01801

Permit: Issued: 09/13/2022 Expires: 07/15/2026 Amended: 01/20/2023

National Pretreatment Categorical Standards: 03-Oct-2005 to 433.15 A Metal Finishing
03-Oct-2005 to 469.26 B Electrical and Electronic
Components

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated
0105

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 09-Jan-2024
13-Jun-2024

Monitoring: 0101 31-Aug-2023
0101 01-Sep-2023
0101 19-Mar-2024
0101 20-Mar-2024

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Tecomet, Inc.

Facility ID: 43101316

170 New Boston Street
Woburn, MA 01801

Permit: Issued: 09/08/2023 Expires: 07/15/2025
Issued: 06/28/2021 Expires: 07/15/2023 Amended: 08/19/2021 Termination: 09/07/2023

National Pretreatment Categorical Standards: 24-Apr-2007 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER_DESC Metal finishing
0102 OTHER_DESC cyanide destruct

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 12-Dec-2023
20-May-2024

Monitoring: 0101 31-Aug-2023
0101 03-Jan-2024
0101 01-Feb-2024
0102 30-Aug-2023

Enforcement Actions:

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Winfield Brooks Company Inc.

Facility ID: 43004753

70 Conn Street
Woburn, MA 01801

Permit: Issued: 01/20/2023 Expires: 01/15/2028

National Pretreatment Categorical Standards: 29-May-1992 to 414.45 D Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 04

Sample Locations: 0102

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 12-Apr-2024

Monitoring:

Enforcement Actions: 02-Dec-2022 Notice of Noncompliance

Significant Industrial Users: Compliance, Inspection, Monitoring Dates and Enforcement Action

Reporting Period 7/1/2023 To 6/30/2024

Data Source:

FISCAL_YEAR

Parameters:

Fiscal_Year: 2024

Appendix B

Non-SIU Permitted Industrial Users

Includes:

- Permit Category
- Sample Location Description
 - Sampling Requirements
 - Discharge Violations
 - Enforcement Actions

KEY to Appendix B

Industry:

Industry address:

#: *Permit number* **Category:** *MWRA category-see description of MWRA categories below*

Current Sampling Requirements: *Sample location numbers and descriptions; current permit sampling requirements (frequency and parameter)*

Discharge Violations: *Discharge violations occurring during the fiscal year: sample date, parameter, test result and MWRA limit*

Enforcement Actions: *Enforcement actions taken during the fiscal year: enforcement action Date and description*

Notes: This appendix lists all non-significant industrial users which were permitted during the year. Most of these facilities meet the requirements of MWRA's Low Flow/Low Pollutant General Permit and are thus permitted as Category 10 facilities. These facilities are required to comply with all applicable regulations and the terms of their permits, but due to the nature and/or volume of their discharges, they are not required to conduct periodic self-monitoring, and MWRA does not typically sample their wastewater.

The newly issued Dental Discharges permits are included at the end of Appendix B.

Some violations reported in this appendix happened during the latter part of the year, and show no enforcement actions. This is most often due to the lag of time between when a sample is collected and when the data is submitted to MWRA for input into PIMS. Because sample analysis takes three weeks or more, the violation does not appear on the weekly violation report for some time after the violation occurs. Enforcement actions have been taken early in the year for those violations, but are not reported in this report.

Some industries have enforcement actions but no discharge violations. In some cases, the enforcement actions were related to violations occurring prior to the start of the fiscal year. In others, the enforcement actions were related to reporting violations that are not listed in this appendix.

MWRA Category:

Category 1: A sewer user whose process results in a discharge containing one or more substances in a concentration or quantity requiring pretreatment to meet the requirements of 360 CMR 10.021 through 10.025 and who does not have a Group, General, or Combined Permit for the Discharge.

Category 2: A sewer user whose process results in a discharge containing one or more substances regulated by 360 CMR 10.021 through 10.025 at a concentration and quantity not requiring pretreatment to meet the requirements of 360 CMR 10.021 through 10.025 and who does not have a Group, General, or Combined Permit for the Discharge.

Category 3: A sewer user whose process results in a discharge not containing a substance regulated by 360 CMR 10.021 through 10.025 and who does not have a Group, General, or Combined Permit for the Discharge.

Category 4: An SIU without an Industrial Waste Discharge to the Authority Sewerage System or any tributary thereto.

Category 6: A person with a Septage Discharge permit.

Category 10: A person with a General Permit for Low Flow and Low Pollutant Dischargers.

Category 12: A person with a Temporary Construction Site Dewatering permit.

Category C1: A person with a Combined Permit.

Category D1: A person with a Group Permit for Dental Discharges.

Category G1: A person with a Group Permit for Photo Processing, Printing, and Low Flow Operations.

Category G2: A person with a Group Permit for Food Processing.

Possible Enforcement Actions:

The type of enforcement action selected to respond to a violation depends on a variety of factors including, but not necessarily limited to: magnitude of the violations, duration of the violations, compliance history of the sewer user, perceived good faith of the user, clarity of the user's responsibility, and, where such issues arise, the effects of the violation on the receiving waters and/or the treatment works.

TRAC's enforcement options found in this report include:

Notice of Violation (NOV)

This enforcement action is a letter to the user describing the violation and asking the user to identify the reason for the violation and what steps it will take to ensure that the violation will not recur.

Notice of Noncompliance/Order to Take Corrective Action (NON/OTCA)

This formal, written notice and order identifies which requirements the user has violated and specifies deadlines by which the user must come into compliance. It requires increased sampling and reporting of discharges by the user and the submission of a detailed report by the user on how and when it intends to achieve and maintain compliance with MWRA regulations.

Enforcement Order (EO):

Issued by the MWRA to an industry outlining violations, and the steps that the Authority will take to enforce them.

Penalty Assessment Notice (PAN):

Formal, written notice to an industry assessing civil monetary penalties.

Supplemental Order to Comply (SOC):

A further order, usually issued after a previous order fails to bring an industry into compliance. Often issued with a Penalty Assessment Notice (PAN)

Administrative Orders (AO):

These formal written orders include Enforcement Orders, Supplemental Orders, Orders to Take Corrective Action, Orders to Comply, and Cease and Desist Orders. They are sent as follow-ups to NON/OTCA's as new information is obtained, or are sent in other instances where violations of MWRA regulations are taking place or threaten to take place. They often require increased sampling and reporting of discharges by the user and detailed schedules to achieve or maintain compliance with MWRA requirements. They may contain an order to stop a discharge or a violation.

Notice of Proposed Permit Revocation (NPPR):

Issued to an industry when violations are so egregious, that the MWRA must resort to revoking the industry's permit.

Notice of Proposed Permit Suspension (NPPS):

Issued to an industry with outstanding charges due.

Ruling on Request for Reconsideration of NON/OTCA/EO/SOC/NPPR

In response to an industry's appeal of an order or permit revocation, the Authority will issue its decision in the form of a Ruling on Request for Reconsideration of the order or permit revocation.

Compliance Schedule:

Issued by the MWRA in a permit or a settlement agreement. It lists dates and milestones that an industry must meet to achieve compliance.

Settlement Agreement:

A formal document resolving administratively, violations and enforcement actions.

Return to Permit Letter:

Notice to an industry that the industry has been relieved, in part or in full, of the sampling and reporting requirements of a prior enforcement action and can, therefore, return to those of its permit.

Stipulated Penalties Under Agreement:

Penalties which the settling parties agreed to pay for certain types of violations during the period of a settlement agreement.

Interim Ruling on Req. for Reconsideration:

These rulings resolve some but not all, issues appealed by an industry. A formal ruling will be issued later.

Emergency Suspension:

Sewer service may be immediately suspended after informal notice to the user if the discharge reasonably appears to present an imminent danger to health, public welfare or the environment, or if it threatens to interfere with the operation of the sewer system.

Civil Court Action:

TRAC may refer a case to the Attorney general for action in civil court, including injunctive relief, the collection of penalties, and the recovery of expenses. Referrals are seldom made because TRAC can issue and enforce administrative orders and financial penalties without court action.

Criminal Action:

TRAC may refer a case to the Attorney General's Office and the Environmental Crimes Strike Force for criminal charges to be brought against a user. Referrals are made for serious and intentional violations.

THIS PAGE WAS INTENTIONALLY LEFT BLANK

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Allston Dental Associates 196 Harvard Avenue Allston, MA 02134 #: 44405529 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Allston Family Dental PC 127 Harvard Avenue Allston, MA 02134 #: 44405528 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentistar 205 Harvard Avenue Allston, MA 02134 #: 44407153 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DoubleTree Suites 400 Soldiers Field Road Allston, MA 02134 #: 44101792 Category: 02	0101	Washing machine effluent at the drain in the floor trench			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Oil and Grease pH						
Harvard Univ. - Pagluica Life Lab - Allston 127 Western Avenue Allston, MA 02134 #: 44404932 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvard University - Allston Campus 224 Western Avenue Allston, MA 02134 #: 44005958 Category: C1	0104	Photoprocessing in the Saunders Studio			No Discharge Violations		18-Aug-2023	Notice of Violation
	Annual	Self-Monitoring Silver (Total) Silver (Total) pH						
Harvard University - Science & Engineering Complex 150 Western Avenue Allston, MA 02134 #: 44408281 Category: 02	0101	SEC wastewater			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			Limit	-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result		Date	Actions
Houghton Chemical Corp. 52 Cambridge Street Allston, MA 02134 #: 44000211 Category: 10		No Reporting Requirements			No Discharge Violations		05-Feb-2024	Notice of Noncompliance
Planned Parenthood League of Massachusetts 1055 Commonwealth Avenue Allston, MA 02215 #: 44102664 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
AbCellera Boston, Inc. 91 Mystic Street Unit 1 Arlington, MA 02474 #: 01403711 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arlington Dental 43 Broadway Arlington, MA 02474 #: 01405545 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arlington Dental Care 347 Massachusetts Avenue Arlington, MA 02474 #: 01405541 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arlington Dental Group 22 Mill Street Suite 202 Arlington, MA 02476 #: 01405539 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arlington Family Dental PC 101 Massachusetts Avenue Arlington, MA 02474 #: 01405532 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arlington Smiles P.C. 1064 Massachusetts Avenue Unit 1 Arlington, MA 02476 #: 01405533 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Barbara A Lawnicki DMD 1068 Massachusetts Avenue Arlington, MA 02476 #: 01405534 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
First Impression Dental 281 Massachusetts Avenue Arlington, MA 02474 #: 01407341 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Gentle Dental Arlington 725 Massachusetts Avenue Arlington, MA 02476 #: 01405547 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
George Vosgerichian 1365 Massachusetts Avenue Arlington, MA 02476 #: 01405536 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Homewood Suites by Hilton - Boston/Cambridge/Arlington 1 Massachusetts Avenue Arlington, MA 02474 #: 01408242 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Michael S Garber DMD LLP 100 Park Avenue Arlington, MA 02476 #: 01405531 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Perkins Family Dental 375 Massachusetts Avenue Arlington, MA 02474 #: 01405544 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
TRAC TEST DENTAL 201 Main Street Arlington, MA 02155 #: 01408258 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ashland Dental Care 300 Eliot Street #5 Ashland, MA 01721 #: 02407162 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ashland Elite Dental 171 Main Street Suite 100 Ashland, MA 01721 #: 02405549 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ashland Family Dental PC 171 Main Street Suite 102 Ashland, MA 01721 #: 02405548 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ashland Family and Implant Dentistry 37 Main Street Ashland, MA 01721 #: 02405553 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
BioSurfaces, Inc. 200 Homer Avenue Unit 1P Ashland, MA 01721 #: 02404809 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston BioProducts Inc. 159 Chestnut Street Ashland, MA 01721 #: 02103041 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Massachusetts Division of Standards State Metrology Lab 250 Eliot Street Ashland, MA 01721 #: 02409917 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MatTek Corporation 200 Homer Avenue Ashland, MA 01721 #: 02103043 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Metrowest Dental Care 214 Main Street Ashland, MA 01721 #: 02405550 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Practice of Family & Cosmetic Dentistry 30 Main Street Suite 2 Ashland, MA 01721 #: 02405551 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smile Magic 39 Pond Street Ashland, MA 01721 #: 02407159 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Family Pet Hospital Inc. 300 Eliot Street Ashland, MA 01721 #: 02103039 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
VetCor of Ashland LLC dba Ashland Animal Hospital 10 Fountain Street Ashland, MA 01721 #: 02102549 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Zen Family Dental 5 Homer Avenue Ashland, MA 01721 #: 02408931 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
66th Medical Squadron 90 Vandenberg Drive Building 1900 Bedford, MA 01731 #: 03407509 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BCPF One Patriots Park LLC One Patriots Park Bedford, MA 01730 #: 03406668 Category: 02	0101	sampling spigot on discharge line after pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Chromium (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Bedford Dental Associates LLP 50 Loomis Street Bedford, MA 01730 #: 03405562 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bedford Family Dental 41 North Road Unit 107 Bedford, MA 01730 #: 03405559 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Black Mesa Technology, Inc. 9 Alfred Circle Bedford, MA 01730 #: 03409944 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chestnut Dental Associates 41 North Road Suite 110 Bedford, MA 01730 #: 03405560 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Conagen, Inc. 13 -15 DeAngelo Drive Bedford, MA 01730 #: 03404340 Category: 10		No Reporting Requirements			No Discharge Violations		05-Jun-2024	Notice of Noncompliance
Dale Engineering 3 Alfred Circle Bedford, MA 01730 #: 03404191 Category: 10		No Reporting Requirements			No Discharge Violations		28-Nov-2023	Notice of Noncompliance

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Discovery Labware, Inc. 2 Oak Park Drive Bedford, MA 01730 #: 03006194 Category: 02	0101	LABORATORY PROCESS WASTEWATER			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Cyanide (Total) Formaldehyde TTO (Volatile Organic Fraction) pH						
EMD Millipore Corporation 80 Ashby Road Bedford, MA 01730 #: 03003418 Category: 02	0102	Treated process wastewater Building M - spigot on neut sys in Building D			No Discharge Violations		23-Aug-2023 Notice of Violation 16-Feb-2024 Notice of Violation	
	Semi-Annual Self-Monitoring	Butanol Dimethyl Formamide Dimethylacetamide Ethanol Isopropanol Methanol TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
	0105	pH neutralization system in Building F						
	Semi-Annual Self-Monitoring	TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
	0202	Limestone chip tank in Bldg D in Repair Depot						
	Semi-Annual Self-Monitoring	pH						
EMD Millipore Corporation 75 Wiggins Avenue Bedford, MA 01730 #: 03102595 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
ENRM VA Hospital 200 Springs Road Bedford, MA 01730 #: 03006922 Category: 02	0101	SAMPLE SPIGOT AFTER LIMSTONE CHIP TANK			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Copper (Total) Formaldehyde Silver (Total) TTO (Volatile Organic Fraction) Temperature pH						
	0401	SAMPLE SPIGOT AFTER pH NEUTRALIZATION SYSTEM						
	Annual	Self-Monitoring Mercury (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Volatile Organic Fraction)						
		Temperature						
		pH						
	0501	Wastewater from the sterilizers in Sterilization Processing Services						
	Annual	Self-Monitoring						
		Mercury (Total)						
		Temperature						
		pH						
	0502	Wastewater from the autoclaves in Sterilization Processing Services						
	Annual	Self-Monitoring						
		Mercury (Total)						
		Temperature						
		pH						
	0503	Wastewater from the ultrasonic cleaners in Sterilization Processing Services						
	Annual	Self-Monitoring						
		Mercury (Total)						
		Temperature						
		pH						
	0504	Wastewater from the backup ultrasonic cleaner in Sterile Processing Services						
	Annual	Self-Monitoring						
		Mercury (Total)						
		Temperature						
		pH						
	0601	sampling spigot on common disch. line of two washing machines						
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Temperature						
		Zinc (Total)						
		pH						
	0701	common discharge trough drain of four washing machines						
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Temperature						
		Zinc (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Great Meadows Dental Group 56 Great Road Bedford, MA 01730 #: 03407176 Category: D1		pH						
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hanscom Air Force Base 120 Grenier Street Building 1810 Hanscom AFB, MA 01731-1910 #: 03102735 Category: 10								
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Infraredx, Inc. - Bedford 28 Crosby Drive Suite 100 Bedford, MA 01730 #: 03407680 Category: 10								
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Integral BioSystems 23 Crosby Drive Suite 100A Bedford, MA 01730 #: 03406616 Category: 10								
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ixoela, Inc. 135 South Road Bedford, MA 01730 #: 03403987 Category: 10								
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kennedy Family and Cosmetic Dentistry 200 The Great Road Suite 243 Bedford, MA 01730 #: 03405556 Category: D1								
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Labcorp Bedford LLC (formerly Toxikon Corporation) 15 Wiggins Avenue Bedford, MA 01730 #: 03101286 Category: 02								
	0101	Neutralization system for Chemistry and Histology labs			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Copper (Total) Formaldehyde Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
	0102	Toxicology Lab cage-washer effluent						
	Semi-Annual Self-Monitoring	pH						
	0102	CAGEWASHERSIDE-STREAM MONITORING TANK			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Mayada Najim DMD 143 Great Road Bedford, MA 01730 #: 03405555 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Medica Corporation 5 Oak Park Drive Bedford, MA 01730 #: 03006383 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
N2 Biomedical, LLC One Patriots Park Bedford, MA 01730 #: 03004344 Category: 02	0101 sampling spigot after pH Neutralization System		0101 sampling spigot after pH Neutralization System				15-Feb-2024 Notice of Violation	
	Semi-Annual Self-Monitoring		25-Jan-2024 Zinc (Total)	1.13	mg/l	DYMX < 1		
			25-Jan-2024 Copper (Total)	4.64	mg/l	DYMX < 1		
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Ocular Therapeutix 15 Crosby Drive Bedford, MA 01730 #: 03404917 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Pramand, LLC 201 Burlington Road Bedford, MA 01730 #: 03408984 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Reliance Dental Care 363 Great Road Suite 205 Bedford, MA 01730 #: 03405558 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Revvity fka Cisbio US, Inc. 135 South Road Bedford, MA 01730 #: 03403185 Category: 10	No Reporting Requirements		No Discharge Violations				02-Aug-2023 Notice of Noncompliance	
The Mitre Corporation 202 Burlington Road Bedford, MA 01730-1420 #: 03004803 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Thermo Fisher Scientific 35 Wiggins Avenue Bedford, MA 01730 #: 03102197 Category: 02	0201	PROCESS WASTEWATER FROM MFG. AND LABORATORY OPERATIONS.			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
Xenon Property, LLC (45 Wiggins Ave) 45 Wiggins Avenue Bedford, MA 01730 #: 03404855 Category: 02	0101	R&D laboratory wastewater			No Discharge Violations		21-Aug-2023	Notice of Violation
	Annual	Self-Monitoring Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Xenon Property, LLC (47 Wiggins Ave.) 47 Wiggins Avenue Bedford, MA 01730 #: 03405047 Category: 02	0101	R&D Lab Wastewater			No Discharge Violations		21-Aug-2023	Notice of Violation
	Semi-Annual	Self-Monitoring Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
iRobot Corporation 8 Crosby Drive Bedford, MA 01730 #: 03403602 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
rHEALTH LLC 1 Oak Park Drive Floor 1 Bedford, MA 01730 #: 03405259 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
AMG Family Dental 71 Concord Avenue Belmont, MA 02478 #: 04405583 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Belmont Dental Esthetics 84 Leonard Street Belmont, MA 02478 #: 04405585 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Belmont Dental Group 57 Concord Avenue Belmont, MA 02478 #: 04405580 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Belmont Orthodontics & Pediatric Dentist 11 Alexander Avenue Belmont, MA 02478 #: 04405565 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brachowicz Dental LLC dba Belmont Family Dentistry 75 Trapelo Road Belmont, MA 02478 #: 04405584 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Restorative Group at Belmont 385 Concord Avenue Belmont, MA 02478 #: 04405576 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Digital Silver Imaging LLC 9 Brighton Street Belmont, MA 02478 #: 04103681 Category: G1	0101	PHOTO			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Silver (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Elis Paparisto Family Dentistry 6 Hawthorne Street Belmont, MA 02478 #: 04405581 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental of Belmont 250 Trapelo Road Belmont, MA 02478 #: 04405571 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joan E Horgan Family Dentistry/Kendall Dental 233 Waverly Street Belmont, MA 02478 #: 04405570 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Karessa A. Kuntz DDS 66 Leonard Street Belmont, MA 02478 #: 04407189 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mayani Dental Belmont LLC 385 Concord Avenue Suite 001 Belmont, MA 02478 #: 04405577 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
McLean Hospital 115 Mill Street Belmont, MA 02478 #: 04006836 Category: 02	0101	Spigot on Oaks Building pH Neutralization system discharge line			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Formaldehyde						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0201	Spigot on Mailman Research Building pH Neutralization system discharge line						
	Quarterly	Self-Monitoring						
		Formaldehyde						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
Mondovi Dental 18 Moore Street Suite 200 Belmont, MA 02478 #: 04405567 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Paul Davin DDS 68 Trapelo Road Belmont, MA 02478 #: 04405582 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pleasant Street Dental 363 Pleasant Street Belmont, MA 02478 #: 04405573 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Prathima Bayisetty DMD 161 Belmont Street Belmont, MA 02478 #: 04405566 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Scali Dental Associates 425 Trapelo Road Belmont, MA 02478 #: 04405579 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Schrott Perio Implants 93 Concord Avenue Unit 6 Belmont, MA 02478 #: 04407192 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vetcor of Fresh Pond LLC dba Fresh Pond Animal Hos 15 Flanders Road Belmont, MA 02478 #: 04103262 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Waverly Dental Care 333 Trapelo Road Belmont, MA 02478 #: 04405572 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
125 Lincoln Street (DE) LLC and Turner Construction Co. 125 Lincoln Street Boston, MA 02111 #: 45409218 Category: 12	0101	Stormwater catch basin #451 on Tufts St			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	Stormwater catch basin #163 near intersection Lincoln and Beach Streets						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0201	Stormwater catch basin #316 on Beach St						
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
41 LaGrange Street - SFH 48 Boylston Street LLC 41 LaGrange Street Boston, MA 02116 #: 45409918 Category: 12	0101	Dewatering effluent to CB #354 on LaGrange Street			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
AC Hotel Boston Downtown 225 Albany Street Boston, MA 02118 #: 45406606 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
AP Dental Staniford PLLC 50 Staniford Street Suite 804 Boston, MA 02114 #: 45405658 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
ARE-MA Region No. 87, LLC 201 Brookline Avenue Boston, MA 02215 #: 45409386 Category: 02	0101	laboratory wastewater			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Formaldehyde Lead (Total) Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Advanced Cosmetic & Implant Dentistry 156 State Street Floor 4 Boston, MA 02109 #: 45407195 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Arch Street Dental 103 Arch Street Boston, MA 02116 #: 45407829 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atlantic Avenue Dental Group 183 Essex Street Boston, MA 02111 #: 45407201 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health Harvard Vanguard Post Office Square 147 Milk Street Boston, MA 02109 #: 45405009 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health, Part of Optum 133 Brookline Avenue Boston, MA 02215 #: 45102774 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
B Central Dental Associates 180 Cambridge Street Boston, MA 02114 #: 45407200 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Back Bay Dental Associates 745 Boylston Street Suite 206 Boston, MA 02116 #: 45409283 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bao Min Yee, DMD of Boston PC 109 Beach Street Boston, MA 02111 #: 45405594 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Beacon Hill Dental Associates 77 Beacon Street Boston, MA 02108 #: 45405673 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bio-Medical Applications of Massachusetts dba Kidney Center 888 Commonwealth Avenue Boston, MA 02215 #: 45101466 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Center for Oral Health 400 Commonwealth Avenue Boston, MA 02215 #: 45405648 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Chinatown Dental Center 65 Harrison Avenue Suite 306 Boston, MA 02111 #: 45405667 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston City Dental Center 65 Harrison Avenue Suite 508 Boston, MA 02111 #: 45409346 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Dental 36 Chauncy Street Boston, MA 02111 #: 45405643 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Dental 35 Court Street Boston, MA 02110 #: 45407217 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Dental Design 10 Post Office Square Suite 655 Boston, MA 02109 #: 45405589 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Dental Restorative Group 25 New Chardon Street Boston, MA 02114 #: 45405623 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Endodontics 5 Longfellow Place Suite 205 Boston, MA 02114 #: 45405655 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Boston Harbor Hotel 70 Rowes Wharf Boston, MA 02110 #: 45404958 Category: 02	0101	Laundry wastewater			No Discharge Violations		16-Aug-2023	Notice of Violation
	Semi-Annual	Self-Monitoring Oil and Grease Zinc (Total) pH						
Boston Housing Authority and Consigli Construction 34 Heath Street Boston, MA 02130 #: 45409514 Category: 12	0101	Effluent from construction site dewatering			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
Boston Marriott Copley Place 110 Huntington Avenue Boston, MA 02116 #: 45006629 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Medical Center One Boston Medical Center Place Boston, MA 02118 #: 45005924 Category: 02	1101	Process wastewater from the Menino Building CPD (clean side)			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Copper (Total) pH						
	1102	Menino Pavilion CPD (dirty side) wastewater						
	Semi-Annual	Self-Monitoring Copper (Total) pH						
Boston Park Dental Group 128 A Tremont Street Floor 3 Boston, MA 02108 #: 45409028 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Park Plaza 50 Park Plaza Boston, MA 02116 #: 45005782 Category: 02	0101	Laundry effluent from two 65-lb Electrolux washers			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Oil and Grease Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Boston Pre Release Center 430 Canterbury Street Boston, MA 02131 #: 45405651 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Premier Dentistry, P.C. 10 Tremont Street Suite 402 Boston, MA 02108 #: 45407825 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Prosthodontics Dental 50 Staniford Street Floor 5 Boston, MA 02114 #: 45407226 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brito Family Dental 272 W. Broadway Boston, MA 02118 #: 45407210 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Charlesmark Hotel 655 Boylston Street Boston, MA 02116 #: 45405087 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
CitiDental Tremont 32 Tremont Street Boston, MA 02108 #: 45405636 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Citidental High Street 10 High Street Suite 333 Boston, MA 02110 #: 45407697 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Citidental PC 63 Court Street Boston, MA 02108 #: 45405665 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
CitizenM Hotels 70 Causeway Street Boston, MA 02114 #: 45409103 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
City of Boston - Spectacle Island Spectacle Island Boston Harbor, MA 02201 #: 45103504 Category: 02	0101 Quarterly	8 inch connection on Long Island Self-Monitoring Arsenic (Total) Arsenic (Total) Cadmium(Total)			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Chromium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Copper (Total)						
		Lead (Total)						
		Lead (Total)						
		Mercury (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Salinity						
		Salinity						
		Silver (Total)						
		Silver (Total)						
		Zinc (Total)						
		Zinc (Total)						
		pH						
		pH						
City of Boston and Turner Construction Company 900 Washington Street Boston, MA 02111 #: 45409234 Category: 12		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Club Quarters Hotel 161 Devonshire Street Boston, MA 02110 #: 45404946 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cogliano Dental 105 Atlantic Avenue Boston, MA 02110 #: 45407699 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Colortek of Boston 727 Atlantic Avenue Boston, MA 02111 #: 45100134 Category: G1	0101	PHOTO			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Silver (Total)						
Commonwealth Dental Group 400 Commonwealth Avenue Floor 3 Boston, MA 02215 #: 45405647 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Congress Dental Group 160 Federal Street Floor 1 Boston, MA 02110 #: 45405605 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Copley Square Hotel 47 Huntington Avenue Boston, MA 02116 #: 45405329 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Copley View Dental Associates PC 575 Boylston Street Suite 5-R Boston, MA 02116 #: 45405660 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Courtyard Boston Downtown 275 Tremont Street Boston, MA 02116 #: 45103247 Category: 02	0101	Laundry operation discharge	No Discharge Violations				06-Nov-2023 Administrative Order 06-Nov-2023 Penalty Assessment Notice 20-Dec-2023 Appeal	
	Annual	Self-Monitoring Mercury (Total) Oil and Grease Zinc (Total) pH Mercury (Total) Oil and Grease Zinc (Total) pH						
Courtyard Marriott Hotel Copley Square 88 Exeter Street Boston, MA 02116 #: 45405183 Category: 02	0101	Laundry wastewater	0101	Laundry wastewater				02-Feb-2024 Notice of Violation 27-Mar-2024 Notice of Violation
	Semi-Annual	Self-Monitoring Copper (Total) Oil and Grease Zinc (Total) pH	29-Feb-2024	Copper (Total)	6.96	mg/l	DYMX < 1	
			13-Mar-2024	Copper (Total)	5.14	mg/l	DYMX < 1	
Daniel J Bley DDS 2 Center Plaza Boston, MA 02108 #: 45405615 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Davita Boston 660 Harrison Avenue Boston, MA 02118 #: 45101058 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Dental Arts of Boston 26 Marlborough Street Boston, MA 02116 #: 45407814 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Dental Associates of New England 585 Boylston Street Unit 2 Boston, MA 02116 #: 45407232 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Dental Group at Post Office Square, LLC 3 Post Office Square Floor 9 Boston, MA 02109 #: 45405631 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dental Partners of Boston - Charles River LLC 50 Staniford Street Suite 303 Boston, MA 02114 #: 45405656 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Partners of Boston - Prudential Ctr. 800 Boylston Street Suite 200 Boston, MA 02199 #: 45405677 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentology 330 Congress Street Floor 1 Boston, MA 02210 #: 45407216 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Devonshire Dental Associates 185 Devonshire Street Suite 410 Boston, MA 02110 #: 45405612 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dialysis Clinic, Inc. - Tufts Medical Ctr. 35 Kneeland Street Floor 5 Boston, MA 02111 #: 45407718 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Diba Dastjerdi, DMD dba Carr & Associates 68 New Edgerly Road Boston, MA 02115 #: 45405668 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DoubleTree by Hilton Hotel Boston - Downtown 821 Washington Street Boston, MA 02111 #: 45405222 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Downtown Boston Dental 21 Merchants Row Suite 2A Boston, MA 02109 #: 45405619 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Downtown Dental Center 333 Washington Street Suite 341 Boston, MA 02108 #: 45405640 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. James R. Seligman 1180 Washington Street Unit 102 Boston, MA 02118 #: 45405595 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			Limit	-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result		Date	Actions
Emmanuel College 400 The Fenway Boston, MA 02115 #: 45004514 Category: 10		No Reporting Requirements			No Discharge Violations		02-Aug-2023	Notice of Noncompliance
Fairmont Copley Plaza Hotel 138 Saint James Avenue Boston, MA 02116 #: 45102966 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Faneuil Hall Dental Associates 177 State Street Boston, MA 02109 #: 45405610 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fenway Health Center 1340 Boylston Street Boston, MA 02215 #: 45405601 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fiorillo Dental 437 Boylston Street Floor 5 Boston, MA 02116 #: 45405653 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Found Hotel 78 Charles Street S Boston, MA 02116 #: 45405238 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Four Seasons Hotel 200 Boylston Street Boston, MA 02116 #: 45102868 Category: 02	0101	Laundry operation discharge.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Oil and Grease Zinc (Total) pH						
G&D Smiles; dba Geoffrey Davis DMD 581 Boylston Street Suite 401 Boston, MA 02116 #: 45405662 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Giangrasso Dental LLC 279 Hanover Street Boston, MA 02113 #: 45405627 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Great Hill Dental Boston 1610 Tremont Street Boston, MA 02120 #: 45405607 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Gritstone Bio, Inc. 660 Beacon Street Floor 5 & 6 Boston, MA 02115 #: 45409629 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
HHLP Bulfinch Lessee, LLC dba The Boxer 107 Merrimac Street Boston, MA 02114 #: 45403860 Category: 02	0101	Laundry effluent			No Discharge Violations		16-Aug-2023	Notice of Violation
		Semi-Annual Self-Monitoring						
		Oil and Grease						
		Zinc (Total)						
Harborside Inn Boston 185 State Street Boston, MA 02109 #: 45404943 Category: 02		pH						
	0101	Wastewater from the laundry operation.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Oil and Grease						
Harmony 410 Tremont Street Boston, MA 02116 #: 45407221 Category: D1		Zinc (Total)						
		pH						
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harmony Dental Care, LLC 128 A Tremont Street Floor 5 Boston, MA 02108 #: 45405598 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvard School of Dental Medicine 188 Longwood Avenue Boston, MA 02115 #: 45405613 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Helen K Foo DMD 922 Beacon Street Boston, MA 02215 #: 45405681 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hilton Boston Back Bay 40 Dalton Street Boston, MA 02115 #: 45006401 Category: 02					No Discharge Violations			No Enforcement Actions
	0101	Hotel laundry wastewater						
		Semi-Annual Self-Monitoring						
		Mercury (Total)						
Hirshberg Dental Associates of Boston PC 12 Post Office Square Boston, MA 02109 #: 45405596 Category: D1		Oil and Grease						
		pH						
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Hotel Commonwealth 500 Commonwealth Avenue Boston, MA 02215 #: 45405322 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hotel Indigo Boston Garden 280 Friend Street Boston, MA 02114 #: 45404976 Category: 02	0101	Laundry effluent			No Discharge Violations		16-Aug-2023	Administrative Settlement
	Semi-Annual	Self-Monitoring Copper (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						
Hotel aka Boston Common 90 Tremont Street Boston, MA 02108 #: 45405010 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hyatt Centric Faneuil Hall Boston 68 Devonshire Street Boston, MA 02109 #: 45409556 Category: 10		No Reporting Requirements			No Discharge Violations		29-Mar-2024	Notice of Noncompliance
IQHQ - 20 Overland, LLC 20 Overland Street Boston, MA 02215 #: 45409466 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Inquilinos Boricuas en Acción (IBA) & J. Derenzo Co 85 West Newton Street Boston, MA 02118 #: 45409930 Category: 12		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Intercontinental Boston 510 Atlantic Avenue Boston, MA 02210 #: 45407273 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Intercontinental Real Estate Corporation 4 Blackfan Street Boston, MA 02115 #: 45406654 Category: 02	0101	Lab effluent from sinks, glass washing facilities			No Discharge Violations		14-Aug-2023 20-Nov-2023	Notice of Violation Notice of Violation
	Quarterly	Self-Monitoring Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction) pH						
James M. Stein, DMD 50 Staniford Street Floor 10 Boston, MA 02114 #: 45407225 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Joseph J Milavec DMD 400 Commonwealth Avenue Suite 104D Boston, MA 02215 #: 45405649 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joseph P Nore DDS 586 Tremont Street Boston, MA 02118 #: 45405663 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joslin Diabetes Center One Joslin Place Boston, MA 02215 #: 45006018 Category: 02	0101	Wastewater effluent from the neutralization system.			No Discharge Violations		25-Sep-2023	Notice of Violation
	Semi-Annual Self-Monitoring	Formaldehyde Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Kowa Holdings America, Inc. 3 Blackfan Street Floor 17 Boston, MA 02115 #: 45403358 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lewis Wharf Dental 237 Lewis Wharf Boston, MA 02113 #: 45407206 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Limited to Endodontics 2 Center Plaza Suite 230 Boston, MA 02108 #: 45405616 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MCPHS University 179 Longwood Avenue Boston, MA 02115 #: 45004517 Category: 02	0301	Process wastewater from educational and research laboratories			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Mercury (Total) Phenol TTO (Volatile Organic Fraction) Zinc (Total) pH						
MGH Dental Group 165 Cambridge Street Suite 401 Boston, MA 02114 #: 45405608 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Mass Dental Associates 770 Tremont Street Boston, MA 02118 #: 45405675 Category: D1	No Reporting Requirements		No Discharge Violations			No Enforcement Actions		
Mass General Brigham/Mass Eye & Ear - 800 Huntington Ave 800 Huntington Avenue Boston, MA 02115 #: 45404778 Category: 02	0101	Process wastewater from Central Processing Department and OR flash sterilizers	No Discharge Violations			No Enforcement Actions		
	Semi-Annual	Self-Monitoring Copper (Total) Zinc (Total) pH						
Mass General Brigham/Mass Eye & Ear - Charles Street 243 Charles Street Boston, MA 02114 #: 45005735 Category: 02	0107	Lab discharge from main & connector buildings	No Discharge Violations			No Enforcement Actions		
	Quarterly	Self-Monitoring Copper (Total) Formaldehyde Mercury (Total) pH TTO (Volatile Organic Fraction)						
	0201	Lab discharge from 325 Cambridge Street building						
	Annual	Self-Monitoring TTO (Volatile Organic Fraction) Mercury (Total) pH						
Massachusetts College of Art and Design 621 Huntington Avenue Boston, MA 02115 #: 45006884 Category: C1	0101	PHOTO and studio wastewater	No Discharge Violations			No Enforcement Actions		
	Annual	Self-Monitoring Silver (Total)						
Massachusetts Eye & Ear Infirmary - Schepens 20 Staniford Street Boston, MA 02114 #: 45102333 Category: 02	0101	Laboratory and cage washeffluent	No Discharge Violations			No Enforcement Actions		
	Semi-Annual	Self-Monitoring Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Matthew S. Ginsburg, DMD 31 St. James Avenue Suite 780 Boston, MA 02116 #: 45407214 Category: D1	No Reporting Requirements		No Discharge Violations			No Enforcement Actions		
Merck Sharp & Dohme LLC 33 Avenue Louis Pasteur Boston, MA 02115 #: 45103268 Category: 02	0101	Laboratorywastewater, glassware and tunnel washer effluent	No Discharge Violations			No Enforcement Actions		
	Quarterly	Self-Monitoring Copper (Total) Cyanide (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Mercury (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Micro Endodontics 10 Post Office Square Suite 1101 Boston, MA 02109 #: 45409366 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Millenium Dental, LLC 177 Tremont Street Floor 6 Boston, MA 02111 #: 45407828 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mint 200 Lincoln Street Suite 500 Boston, MA 02111 #: 45407204 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nevins Dental Center 3 Center Plaza Suite 310 Boston, MA 02108 #: 45407818 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
New England Aquarium 250 Atlantic Avenue Boston, MA 02110 #: 45006091 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newbury Dental Associates LLC 274 Newbury Street Boston, MA 02116 #: 45407822 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
North End Waterfront Health Center 332 Hanover Street Boston, MA 02113 #: 45405639 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Northeastern University - Forsyth Institute 140 The Fenway Boston, MA 02115 #: 45403630 Category: 02	0101	Process wastewater from pharmaceutical research laboratory operations.			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
	0201	Process wastewater from pharmaceutical research laboratory operations.						
	Semi-Annual	Self-Monitoring						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
Oliver Dental Associates 295 Devonshire Street Suite 301 Boston, MA 02110 #: 45405630 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Omni Parker House Hotel 60 School Street Boston, MA 02108 #: 45005644 Category: 02	0201	Laundry wastewater			No Discharge Violations		13-Jun-2024	Notice of Violation
	Semi-Annual	Self-Monitoring						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
Osorio Dental Group 60 Federal Street Boston, MA 02110 #: 45407233 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Oxford Properties Group 745 Atlantic Avenue Boston, MA 02111 #: 45409881 Category: 02	0101	Laboratory wastewater			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring						
		Color						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		Temperature						
Parkside Dental Care 37 Newbury Street Suite 3 Boston, MA 02116 #: 45407218 Category: D1		pH						
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Pat Kinsel and Jill Ozzie and Sea-Dar Construction 10 Union Park Boston, MA 02118 #: 45409375 Category: 12	0101	18" line on southwest side of 10 Union Park beneath Public Alley No. 701	No Discharge Violations				No Enforcement Actions	
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	77" x 50" line on northeast side of 10 Union Park beneath Union Park						
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
Prudential Dental Associates 575 Boylston Street Floor 7 Boston, MA 02116 #: 45405661 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Rago Veal 124 Newmarket Square Boston, MA 02118 #: 45102999 Category: G2	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Regeneron Pharmaceuticals 1325 Boylston Street Floor 5 Boston, MA 02215 #: 45405110 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Residence Inn Boston Back Bay/Fenway 125 Brookline Avenue Boston, MA 02215 #: 45405229 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Revere Hotel 200 Stuart Street Boston, MA 02116 #: 45103217 Category: 02	0101 Laundry discharge				No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Mercury (Total) Oil and Grease Zinc (Total) pH						
Richard Brewer, DMD aka Franklin Street Dental 77 Franklin Street Suite 808 Boston, MA 02110 #: 45405674 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Riley Dental Associates LLC 10 Hawthorne Place Suite 102 Boston, MA 02114 #: 45405588 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Shriners Hospitals for Children - Boston 51 Blossom Street Boston, MA 02114 #: 45101038 Category: 02	0101 Research lab wastewater				No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Formaldehyde Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction) pH						
Simmons University 300 The Fenway Boston, MA 02115 #: 45004519 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Smile Design Boston 21 Custom House Street Boston, MA 02110 #: 45407824 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South Cove Community Health Care 145 South Street Boston, MA 02111 #: 45405603 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South End Community Health Center Hass Center 400 Shawmut Avenue Boston, MA 02118 #: 45409267 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South End Community Health Center SECHC 1601 Washington Street Boston, MA 02118 #: 45405606 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
South End Dental Arts 544 Tremont Street Boston, MA 02116 #: 45407230 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
StayPineapple Boston - Pineapple Hospitality 26 Chandler Street Boston, MA 02116 #: 45405109 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Stuparich & Nouel Dental Associates LLP 607 Boylston Street Suite 302 Boston, MA 02116 #: 45405637 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Suffolk County HOC Dental Suite 20 Bradston Street Boston, MA 02108 #: 45405617 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Suffolk Dental Group 128 A Tremont Street Floor 2 Boston, MA 02108 #: 45405599 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Suffolk University 20 Somerset Street Boston, MA 02108 #: 45004524 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
TDC-BP Tenant, LLC and John Moriarty & Associates 350 Boylston Street Boston, MA 02116 #: 45409549 Category: 12	0101 Monthly	MH on Providence Street Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH			No Discharge Violations			No Enforcement Actions
The Dagny 89 Broad Street Boston, MA 02110 #: 45103264 Category: 02	0101 Quarterly	Laundry wastewater discharge Self-Monitoring Oil and Grease Zinc (Total) pH			No Discharge Violations		14-Aug-2023 Notice of Violation 12-Nov-2023 Notice of Violation 02-Apr-2024 Notice of Violation 04-Apr-2024 Notice of Noncompliance 13-Jun-2024 Notice of Violation	

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
The Eliot Hotel 370 Commonwealth Avenue Boston, MA 02215 #: 45405027 Category: 02	0101	Laundry wastewater			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Oil and Grease pH						
The Inn at Longwood Medical 342 Longwood Avenue Boston, MA 02115 #: 45405113 Category: 02	0101	Laundry wastewater			No Discharge Violations		14-Aug-2023	Notice of Violation
	Semi-Annual	Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH					22-Apr-2024	Notice of Violation
The Langham Hotel 250 Franklin Street Boston, MA 02110 #: 45404945 Category: 02	0101	Laundry wastewater			No Discharge Violations		14-Aug-2023	Notice of Violation
	Quarterly	Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH					21-Feb-2024	Notice of Violation
The Onyx Hotel 155 Portland Street Boston, MA 02114 #: 45103329 Category: 02	0101	Wastewater from the laundry operation			No Discharge Violations		27-Oct-2023	Notice of Violation
	Annual	Self-Monitoring Mercury (Total) Oil and Grease Zinc (Total) pH Mercury (Total) Oil and Grease Zinc (Total) pH					13-Mar-2024	Notice of Noncompliance
The Ritz-Carlton, Boston 10 Avery Street Boston, MA 02111 #: 45005643 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Verb Hotel 1271 Boylston Street Boston, MA 02215 #: 45405108 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Whitney Hotel 170 Charles Street Boston, MA 02114 #: 45408164 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Tower Dental Associates 336 -A Tremont Street Boston, MA 02116 #: 45405641 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Trade Center Dental Associates 2 Boylston Street Suite 202 Boston, MA 02116 #: 45405614 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tremont Family Dentistry 951 Tremont Street Boston, MA 02120 #: 45407237 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Triple Ring Technologies 38 Wareham Street Suite 300 Boston, MA 02118 #: 45407120 Category: 02	0101 Annual	R&D laboratory wastewater Self-Monitoring Copper (Total) Formaldehyde Mercury (Total) TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions
Trustees of Tufts College - Tufts Univ. Boston SMFA Campus 230 The Fenway Boston, MA 02115 #: 45102442 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tufts University School Dental Medicine 1 Kneeland Street Boston, MA 02111 #: 45405587 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Turning Leaf Dental 328 Newbury Street Boston, MA 02115 #: 45405638 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
USCG HSWL Base Boston Dental Clinic 427 Commercial Street Boston, MA 02109 #: 45405650 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
USDA Human Nutrition Research Center 711 Washington Street Boston, MA 02111 #: 45006784 Category: 02	0101 Semi-Annual	Laboratory wastewater Self-Monitoring Copper (Total) Formaldehyde Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction)			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Valdemar Welz DMD 398 Commonwealth Avenue Boston, MA 02215 #: 45405646 Category: D1		pH No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vasilidis Mourmoutis, DMD PC 359 Boylston Street Boston, MA 02116 #: 45405642 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vicinity Energy Boston, Inc.- Scotia Street Station 19 - 27 Scotia Street Boston, MA 02116 #: 45005931 Category: 02	0102 Quarterly	Effluent from steam generation operation Self-Monitoring Copper (Total) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
W Hotel Boston 100 Stuart Street Boston, MA 02116 #: 45405026 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
WM Jacob Murray DMD 100 Charles Street S Boston, MA 02116 #: 45405591 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Warshauer & Samtataria 396 Commonwealth Avenue Boston, MA 02215 #: 45407220 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wayne B Yong DDS 28 Atlantic Avenue Boston, MA 02110 #: 45405628 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wentworth Institute of Technology 550 Huntington Avenue Boston, MA 02115 #: 45403851 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Westin Copley Place Boston 10 Huntington Avenue Boston, MA 02116 #: 45006413 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
William B Chan DMD 886 Washington Street Boston, MA 02111 #: 45405680 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wyndham Boston Beacon Hill 5 Blossom Street Boston, MA 02114 #: 45005659 Category: 02	0101	Laundry wastewater effluent			No Discharge Violations		08-May-2024	Notice of Violation
		Semi-Annual Self-Monitoring Oil and Grease Zinc (Total) pH						
Allen Dental Associates 382 Grove Street Braintree, MA 02184 #: 06405691 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arthur E Brown DDS 367 Washington Street Braintree, MA 02184 #: 06405689 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atlas High Purity Solutions, LLC 100 Messina Drive Suite 105 Braintree, MA 02184 #: 06404646 Category: 02		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Blue Hills Dental Associates 340 Wood Road Suite 288 Braintree, MA 02184 #: 06407242 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Braintree Dental Group 369 Washington Street Braintree, MA 02184 #: 06407244 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Braintree Dentistry and Braces 292 Grove Street Braintree, MA 02184 #: 06407241 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Braintree Family Dental 381 Washington Street Braintree, MA 02184 #: 06405690 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Braintree Printing Inc. 230 Wood Road Braintree, MA 02184 #: 06103121 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dunkin Brands, Inc. (University) 589 Granite Street Braintree, MA 02184 #: 06405210 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Earl R Marrow III DMD 409 Pond Street Suite 7 Braintree, MA 02184 #: 06405693 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Extended Stay America #1029 Braintree 20 Rockdale Street Braintree, MA 02184 #: 06404931 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Family Dental Health Center 222 Forbes Road Suite 1105 Braintree, MA 02184 #: 06406171 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Financial Graphic Services, Inc. 1 Rex Drive Braintree, MA 02184 #: 06009461 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fireking Baking Company 185 Campanelli Drive Braintree, MA 02184 #: 06102573 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Braintree 102 /103 Pearl Street Braintree, MA 02184 #: 06405686 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
George Salem DMD & Associates PC 60 Adams Street Braintree, MA 02184 #: 06405699 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Great Hill Dental Braintree 100 Grossman Drive Suite 210 Braintree, MA 02184 #: 06405685 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hampton Inn Boston/Braintree 215 Wood Road Braintree, MA 02184 #: 06103119 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Harvard Vanguard Medical Associates 111 Grossman Drive Braintree, MA 02184 #: 06006710 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hersey Dental PC 1150 Washington Street Braintree, MA 02184 #: 06405687 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hub Pen Company 1525 Washington Street Braintree, MA 02184 #: 06103647 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jack and Jill Pediatric Dentists 340 Wood Road Suite 288 Braintree, MA 02184 #: 06407243 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Konditor Meister 32 Wood Road Braintree, MA 02184 #: 06405125 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Local Motion, Inc. 77 Rocsam Park Road Braintree, MA 02184 #: 06404798 Category: 02	0101	Bus wash waste water			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Marr Crane & Rigging Co. 201 Commerce Drive Braintree, MA 02184 #: 06408366 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Montillo Dental Associates of Braintree 420 Washington Street Suite 101 Braintree, MA 02184 #: 06405695 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Norfolk Hospitality LLC, dba Best Western 190 Wood Road Braintree, MA 02184 #: 06101810 Category: 02	0101	Wastewater from laundry			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Copper (Total) Lead (Total) Oil and Grease Zinc (Total) pH						
OB1 Dental 14 Wood Road Suite 104 Braintree, MA 02184 #: 06405875 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peterson Linen Rental & Sales, Inc. 215 Shaw Street Braintree, MA 02184 #: 06007387 Category: 02	0101	Washing machine effluent			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Oil and Grease pH Oil and Grease pH						
Pinnacle Dental 10 Forbes Road Suite 230 Braintree, MA 02184 #: 06405684 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Residence Inn Boston-Braintree 180 Forbes Road Braintree, MA 02184 #: 06405373 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard F. Struzziero 575 Washington Street Braintree, MA 02184 #: 06405698 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard J Baker DMD 409 Pond Street Unit 6 Braintree, MA 02184 #: 06405694 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smilistic Dental Care LLC 250 Granite Street Suite 1060 Braintree, MA 02184 #: 06409309 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sonesta Simply Suites 235 Wood Road Braintree, MA 02184 #: 06103118 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
South Shore Dental Group 350 Granite Street Braintree, MA 02184 #: 06405688 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Shore Smiles 44 Adams Street Braintree, MA 02184 #: 06405696 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
United Rentals (North America) Inc. 115 Wood Road Braintree, MA 02184 #: 06405488 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
United Rentals (North America), Inc. 131 Messina Drive Braintree, MA 02184 #: 06405269 Category: 02	0101	Washwater from equipment washbay from OWS inlet pipe			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Nickel (Total) Oil and Grease TTO (Volatile Organic Fraction) Zinc (Total) pH						
Widowmaker Brewing Co. 220 Wood Road Braintree, MA 02184 #: 06405225 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wollaston Alloys, Inc. 205 Wood Road Braintree, MA 02184 #: 06000965 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Zanfaly Dental 400 Washington Street Suite 103 Braintree, MA 02184 #: 06407251 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
60 Guest Street Owner LLC 60 Guest Street Boston, MA 02135 #: 46409919 Category: 02	0101	Spigots on the discharge line after the pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Zinc (Total) pH						
Amity Dental Center 637 Washington Street Brighton, MA 02135 #: 46405711 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BioAgilytix Labs 1320 Soldiers Field Road Brighton, MA 02135 #: 46101954 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brighton Dental Associates 367 Washington Street Brighton, MA 02135 #: 46407256 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brighton Dental Group LLC 1607 Commonwealth Avenue Unit 3 Brighton, MA 02135 #: 46405701 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brighton Family Dental Group LLP 77 Warren Street Brighton, MA 02135 #: 46405712 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Charles River Community Health 495 Western Avenue Brighton, MA 02135 #: 46405708 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Franciscan Hospital for Children 30 Warren Street Brighton, MA 02135 #: 46405705 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Brighton 320 Washington Street Brighton, MA 02135 #: 46405706 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ice Box, LLC 80 Guest Street Brighton, MA 02135 #: 46406531 Category: 02	0101	Neutralized effluent from R&D labs			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Silver (Total) TTO (Extractable Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Volatile Organic Fraction) Zinc (Total) pH						
Ilya Ginzburg DMD 2001 Beacon Street Suite 102 Brighton, MA 02135 #: 46405702 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Maria Vasilakis DMD 438 Washington Street Brighton, MA 02135 #: 46405707 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Meola Dental Group 1576 Commonwealth Avenue Brighton, MA 02135 #: 46405700 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
NanoView Biosciences, Inc. 1380 Soldiers Field Road Suite 1000 Brighton, MA 02135 #: 46408214 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alan Sasson DMD 12 Webster Street Brookline, MA 02446 #: 07405726 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alpha Plus Dental Center 185 Harvard Street Brookline, MA 02446 #: 07405753 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ascend Dental Studio, PLLC 1051 Beacon Street Suite 408 Brookline, MA 02446 #: 07405719 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beacon Dental Center 1842 Beacon Street Suite 206 Brookline, MA 02446 #: 07407286 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beacon Family Dental 1691 Beacon Street Suite 104 Brookline, MA 02446 #: 07407279 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Beacon Place Dental Group 1371 Beacon Street Suite 101 Brookline, MA 02446 #: 07405733 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beacon Street Dental Care 1678 Beacon Street Suite 1 Brookline, MA 02445 #: 07405744 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boris Urman DMD 1149 Beacon Street Brookline, MA 02446 #: 07405721 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston College - Brookline Campus 400 Heath Street Brookline, MA 02467 #: 07006028 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brigham & Women's Ambulatory Care Center 850 Boylston Street Chestnut Hill, MA 02467 #: 07102508 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brook House Dental Associates 77 Pond Avenue Brookline, MA 02445 #: 07405771 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookline Dental Associates 209 Harvard Street Suite 502 Brookline, MA 02446 #: 07407856 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookline Dental Center 1199 Beacon Street Unit 1 Brookline, MA 02446 #: 07405725 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookline Dental Specialists 21 Longwood Avenue Brookline, MA 02446 #: 07407298 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookline Dental Studio 1247 A Beacon Street Brookline, MA 02446 #: 07405728 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Brookline Denture Center 1842 Beacon Street Suite 102 Brookline, MA 02445 #: 07407285 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookline Endodontic Associates 1 Brookline Place Brookline, MA 02445 #: 07405713 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookline Family Dentistry 81 School Street Brookline, MA 02446 #: 07405773 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookline Progressive Dental Team 1842 Beacon Street Suite 301 Brookline, MA 02445 #: 07405749 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookline Village Dental 33 Pond Avenue Suite 103 Brookline, MA 02445 #: 07405765 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Center for Pediatric Dental Care 209 Harvard Street Floor 2 Brookline, MA 02446 #: 07405739 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Citidental Center Brookline, PC 637 Washington Street Suite 210 Brookline, MA 02446 #: 07405770 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cleveland Circle Dental Associates, PC 1798 Beacon Street Brookline, MA 02445 #: 07407281 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Coolidge Corner Dental 367 Harvard Street Brookline, MA 02446 #: 07405768 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DaVita Inc. - Brookline Dialysis 322 Washington Street Brookline, MA 02445 #: 07101085 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Darel Moss DDS PC 1682 Beacon Street Brookline, MA 02445 #: 07405745 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Partners of Brookline 1540 Beacon Street Brookline, MA 02446 #: 07405738 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentures Today 1051 Beacon Street Suite 514 Brookline, MA 02446 #: 07405720 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Alex Verbitsky DMD 1415 Beacon Street Suite 321 Brookline, MA 02446 #: 07405736 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Eash Dental 1330 Beacon Street Suite 261 Brookline, MA 02446 #: 07407857 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elovic Dental Care 209 Harvard Street Suite 501 Brookline, MA 02446 #: 07405757 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fenway Communications Group 870 Commonwealth Avenue Boston, MA 02215 #: 07404839 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gary R Login 209 Harvard Street Suite 402 Brookline, MA 02446 #: 07405761 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Center of Brookline 1037 -A Beacon Street Brookline, MA 02446 #: 07405716 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kenneth L Krowne DMD 209 Harvard Street Brookline, MA 02446 #: 07405760 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Lawrence L Phan DMD PC 1330 Beacon Street Suite 353 Brookline, MA 02446 #: 07405731 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lee Dental Associates 1368 Beacon Street Brookline, MA 02446 #: 07405732 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Limited to Endodontics 209 Harvard Street Suite 500 Brookline, MA 02446 #: 07405755 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Longwood Dental Group 1842 Beacon Street Suite 100 Brookline, MA 02445 #: 07405748 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Modern Dental Associates, LLC 1037 Beacon Street Suite 2 Brookline, MA 02446 #: 07405715 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nicholas G. Tsakos, DDS 1842 Beacon Street Suite 306 Brookline, MA 02445 #: 07405752 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
OG Dental Group 1330 Beacon Street Suite 228 Brookline, MA 02446 #: 07407268 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Po Po Isa Chui DMD 1051 Beacon Street Suite 102 Brookline, MA 02446 #: 07405717 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert Guen DMD 1035 A Beacon Street Brookline, MA 02446 #: 07405714 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert S. Hutner, DMD 1842 Beacon Street Suite 405 Brookline, MA 02445 #: 07405751 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Rooted Dental Company PLLC 1371 Beacon Street Suite 201 Brookline, MA 02446 #: 07405734 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Royal Dental Brookline PLLC dba Royal Dental Boston 1051 Beacon Street Suite 306 Brookline, MA 02446 #: 07409899 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sahani Dental LLC 33 Pond Avenue Suite 100 Brookline, MA 02445 #: 07405723 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sahara Dental Center 364 Harvard Street Suite 1C Brookline, MA 02446 #: 07405766 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sara Stock DDS PC 1425 Beacon Street Brookline, MA 02446 #: 07405737 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smile Solutions 1051 Beacon Street Suite 409 Brookline, MA 02446 #: 07407261 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
SmileBoston Cosmetic & Implant Dentistry 1180 Beacon Street Suite 2B Brookline, MA 02446 #: 07405724 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Theodore Swardlick 389 Harvard Street Brookline, MA 02446 #: 07405769 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Whiteman Dental Associates LLC 8 Alton Place Suite 1 Brookline, MA 02446 #: 07405772 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
A Step Ahead Prosthetics Boston LLC 21 A Street Burlington, MA 01803 #: 08404246 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
AbPro, Inc. 15 A Street Burlington, MA 01803 #: 08404789 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Advanced Dental Care 388 Cambridge Street Burlington, MA 01803 #: 08405786 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Air Purchases Incorporated 24 Blanchard Road Burlington, MA 01803 #: 08005553 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Albion Dental Care 23 -C Cambridge Street Burlington, MA 01803 #: 08405778 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Boronite Corp. (Boronite) 11 Cypress Drive Burlington, MA 01803 #: 08404787 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Food Systems, Inc. 30 B Street Burlington, MA 01867 #: 08006692 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 20 Wall Street Burlington, MA 01803 #: 08008981 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Azzur Cleanrooms on Demand 60 Blanchard Road Burlington, MA 01803 #: 08409607 Category: 02	0101	sampling spigot on discharge pipe of pH neutralization system			No Discharge Violations		05-Jun-2024	Notice of Violation
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Bliss Dental 83 Cambridge Street Suite 3A Burlington, MA 01803 #: 08405789 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Burlington Center Dental Associates 30 Chestnut Avenue Floor 2 Burlington, MA 01803 #: 08405785 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Burlington Children's Dental 131 Cambridge Street Floor 1 Burlington, MA 01803 #: 08407311 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Burlington Family Dental 51 Winn Street Burlington, MA 01803 #: 08405787 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Burlington Smiles Dental 279 Cambridge Street Suite 9 Burlington, MA 01803 #: 08408118 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Bright of Burlington 11 Cambridge Street Burlington, MA 01803 #: 08407300 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Care of Burlington 113 Terrace Hall Avenue Burlington, MA 01803 #: 08407303 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Derek Song, DMD 281 Cambridge Street Burlington, MA 01803 #: 08407937 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Desktop Metal, Inc. 63 Third Avenue Burlington, MA 01803 #: 08405013 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
EMD Millipore Corporation 400 Summit Drive Burlington, MA 01803 #: 08405325 Category: 02	0101	pH neutralization tank building 400			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		pH						
	0103	pH neutralization tank building 600						
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Extended Stay America #9664 Boston-Burlington 40 South Avenue Burlington, MA 01803 #: 08102142 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
FDR Center for Prosthetics & Orthotics 8 Ray Avenue Burlington, MA 01803 #: 08404482 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Burlington 184 Cambridge Street Burlington, MA 01803 #: 08405777 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Glaukos Corp. (formerly Avedro, Inc.) 30 North Avenue Burlington, MA 01803 #: 08406549 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Goodway Graphics of Massachusetts, Inc. 16 A Street Burlington, MA 01803 #: 08004919 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hyatt House Boston Burlington 2 Van De Graaff Drive Burlington, MA 01803 #: 08102133 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
James P Kostas DMD PC 165 Bedford Street Suite 2 Burlington, MA 01803 #: 08407165 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Keurig Doctor Pepper 63 South Avenue Burlington, MA 01803 #: 08404160 Category: 02	0101	Wastewater from the coffee brewer R&D labs	0101	Wastewater from the coffee brewer R&D labs			05-Jan-2024	Notice of Violation
			7-Dec-2023	Copper (Total)	1.11	mg/l	02-May-2024	Notice of Violation
	Semi-Annual	Self-Monitoring						
		Arsenic (Total)						
		Chromium (Total)						
		Copper (Total)						
		Nickel (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
LeMaitre Vascular, Inc. 63 Second Avenue Burlington, MA 01803 #: 08403541 Category: 02	0101	pH neutralization system						
	Semi-Annual	Self-Monitoring						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
Lihsih Tang DMD PLLCdba Burlington Dental 120 Cambridge Street Suite 13 Burlington, MA 01803 #: 08405775 Category: D1	0201	latex balloon DI water baths (8) discharge to sink						
	Annual	Self-Monitoring						
		TTO (Volatile Organic Fraction)						
		pH						
Masterpiece Dentistry of Burlington-former James W Quinn DMD 279 Cambridge Street Burlington, MA 01803 #: 08405780 Category: D1		No Reporting Requirements						
Natural PharmaciaInternational, Inc. 121 Middlesex Turnpike Burlington, MA 01803 #: 08404478 Category: 10		No Reporting Requirements						
Northeastern University-Burlington Campus 145 S Bedford Street Burlington, MA 01803 #: 08008982 Category: 10		No Reporting Requirements						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Paul G. Lombardo, DMD 104 Winn Street Burlington, MA 01803 #: 08405774 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Poly6 Technologies 164 Middlesex Turnpike Burlington, MA 01803 #: 08409914 Category: 01	0101	sampling spigot after pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) Zinc (Total) pH						
Sarepta Therapeutics 55 Blue Sky Drive Burlington, MA 01803 #: 08406823 Category: 02	0101	sampling spigot after pH neutralization			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Serenity Family Dental of Burlington 279 Cambridge Street Floor 2 Burlington, MA 01803 #: 08405781 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Super Smiles Dental 54 Middlesex Turnpike Burlington, MA 01803 #: 08405788 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Surmet Corporation 18 A Street Burlington, MA 01803 #: 08403416 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tayari Dental LLC 265 Winn Street Suite 204 Burlington, MA 01803 #: 08405779 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Thoratec LLC, dba Abbott 23 Fourth Avenue Burlington, MA 01803 #: 08103259 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
VulcanForms Inc. 20 North Avenue Burlington, MA 01803 #: 08408260 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wayne's Drains Inc. 36 Grant Avenue Unit 5 Burlington, MA 01803 #: 08103411 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
24M Technologies, Inc. 130 Brookline Street Suite 200 Cambridge, MA 02139 #: 09404270 Category: 10		No Reporting Requirements			No Discharge Violations		05-Feb-2024	Notice of Noncompliance
620 Memorial Leasehold LLC 620 Memorial Drive Cambridge, MA 02139 #: 09404466 Category: 02	0101	pH neutralization system			No Discharge Violations		20-May-2024	Notice of Violation
		Semi-Annual Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Molybdenum Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
700 Main Street Leasehold, LLC 700 Main Street Cambridge, MA 02139 #: 09404370 Category: 02	0101	biomedical research waste water			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Formaldehyde Mercury (Total) TTO (Volatile Organic Fraction) pH						
AC Hotel by Marriott Boston/Cambridge 10 Acorn Park Drive Cambridge, MA 02140 #: 09405168 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ARE-MA Region No. 45, LLC 100 Binney Street Cambridge, MA 02142 #: 09405495 Category: 02	0101	Laboratory R&D effluent from the 6th & 7th floors.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Formaldehyde						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
ARE-MA Region No. 59, LLC One Kendall Square Suite B1400 Cambridge, MA 02139 #: 09403452 Category: 02	0101	Building 1400 3rd floor incubator/lab effluent	0502	Laboratory wastewater from 3rd floor of building 200	2.2	mg/l	DVMX < 1	16-Nov-2023 Notice of Violation
		Semi-Annual Self-Monitoring		Chloroform (Trichloromethane)				
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0102	Laboratory wastewater from first floor lab space in building 1400						
		Semi-Annual Self-Monitoring						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
0301 Building 700 pH adjustment system	Semi-Annual Self-Monitoring	Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
0302 Sampling spigots on discharge piping after pH adjustment system #4	Semi-Annual Self-Monitoring	Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
0401 399 Binney Street pH adjustment system	Semi-Annual Self-Monitoring	Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0501	Building 200 pH adjustment system						
		Semi-Annual Self-Monitoring						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0502	Laboratory wastewater from 3rd floor of building 200						
		Semi-Annual Self-Monitoring						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
ARE-Tech Square LLC (100 Tech Sq) 100 Technology Square Cambridge, MA 02139 #: 09103122 Category: 02	0101	Sample port on the pH neutralization system discharge line			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
AZENTA 733 Concord Avenue Cambridge, MA 02138 #: 09403418 Category: 02	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Acceleron Pharma, Inc. 128 Sidney Street Cambridge, MA 02139 #: 09103277 Category: 02	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Agios Pharmaceuticals Inc. 88 & 64 Sidney Street Cambridge, MA 02139 #: 09103308 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Albert R Duarte DMD PC 2130 Massachusetts Avenue Suite 1A Cambridge, MA 02140 #: 09405806 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Alnylam Pharmaceuticals, Inc. 675 West Kendall Street Cambridge, MA 02142 #: 09103256 Category: 02	0101	Sample spigot(s) on the pH neutralization system effluent line.			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Cyanide (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0201	Sample spigot(s) on the pH neutralization system effluent line						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
	Quarterly	Self-Monitoring						
		Cyanide (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Alvarez Dental Group 403 Cambridge Street Cambridge, MA 02141 #: 09405815 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Dental Cambridge 2335 Massachusetts Avenue Cambridge, MA 02140 #: 09407347 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Amgen Cambridge Real Estate Holdings, Inc. (ACREH) 360 Binney Street Cambridge, MA 02142 #: 09102684 Category: 02	0101	Spigots on 4" piping downstream of ejector pit and perfusion waste connection			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Temperature						
		Zinc (Total)						
		pH						
Anchor Line Partners 60 First Street Cambridge, MA 02141 #: 09409875 Category: 02	0101	pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Astellas Engineered Small Molecules US, Inc. 441 Morgan Avenue Cambridge, MA 02139 #: 09409931 Category: 02	0101	Laboratory effluent			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Avastus Preclinical Services LLC 44 Spinelli Place Cambridge, MA 02138 #: 09406892 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Axcella Health, Inc. 840 Memorial Drive Floor 3 Cambridge, MA 02139 #: 09403579 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BIG GRP Cambridge Owner, LLC 99 Erie Street Cambridge, MA 02139 #: 09409941 Category: 02	0101	pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
BIG GRP Cambridge Sidney Owner, LLC 167 Sidney Street Cambridge, MA 02139 #: 09409940 Category: 02	0101	pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
BMR - 325 Vassar Street LLC 325 Vassar Street Cambridge, MA 02139 #: 09403618 Category: 02	0101	research waste water			No Discharge Violations		09-Aug-2023	Notice of Violation
	Semi-Annual	Self-Monitoring						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Be Fresh Dental of Cambridge 777 Concord Avenue Suite 303 Cambridge, MA 02138 #: 09405822 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beam Therapeutics 26 Landsdowne Street Cambridge, MA 02139 #: 09406670 Category: 02	0101	pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Biogen, Inc. 125 Broadway Cambridge, MA 02142 #: 09102730 Category: 02	0101	Spigot on the pH neutralization system discharge line			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Formaldehyde						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Bolton Street Partners, LLC 85 Bolton Street Cambridge, MA 02140 #: 09403580 Category: 02	0101	research wastewater after pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Brachowicz Dental LLC dba Cambridge Family Dental 872 Massachusetts Avenue Suite 2-4 Cambridge, MA 02141 #: 09407359 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brammer Bio 250 Binney Street Cambridge, MA 02142 #: 09005998 Category: 02	0101	Spigot on discharge line of the pH neutralization system in Bldg 6A			No Discharge Violations		21-May-2024	Notice of Violation
	Annual Self-Monitoring							
		1,2-Dichlorobenzene						
		1,2-Dichloroethane						
		4-Methyl-2-Pentanone (MIBK)						
		Acetone						
		Ammonia-Nitrogen AsN						
		Benzene						
		Biochemical Oxygen Demand (5 Day)						
		Chlorobenzene						
		Chloroform (Trichloromethane)						
		Cyanide (Total)						
		Diethylamine						
		Ethyl Acetate						
		Isobutyraldehyde						
		Isopropyl Acetate						
		Isopropyl Ether						
		Methyl Cellulose						
		Methyl Formate						
		Methylene Chloride (Dichloromethane)						
		N-Amyl Acetate						
		N-Butyl Acetate						
		N-Heptane						
		N-Hexane						
		Sulfate						
		Tetrahydrofuran						
		Toluene						
		Triethylamine						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----								
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions							
Broad Institute 415 Main Street Cambridge, MA 02142 #: 09103391 Category: 02	0101	Xylenes 2235													
		Antimony (Total)													
		Arsenic (Total)													
		Cadmium (Total)													
		Chromium (Total)													
		Copper (Total)													
		Cyanide (Total)													
		Formaldehyde													
		Lead (Total)													
		Mercury (Total)													
		Nickel (Total)													
		Selenium (Total)													
		Silver (Total)													
		TTO (Extractable Organic Fraction)													
		TTO (Volatile Organic Fraction)													
		Zinc (Total)													
		pH													
	No Discharge Violations														
	No Enforcement Actions														
	Semi-Annual Self-Monitoring														
		Antimony (Total)													
		Arsenic (Total)													
		Cadmium (Total)													
		Chromium (Total)													
		Copper (Total)													
		Cyanide (Total)													
		Formaldehyde													
		Lead (Total)													
		Mercury (Total)													
		Nickel (Total)													
		Selenium (Total)													
		Silver (Total)													
		TTO (Extractable Organic Fraction)													
		TTO (Volatile Organic Fraction)													
		Zinc (Total)													
		pH													
	0201								Biomedical research wastewater from the 75 Ames St. Building						
	Semi-Annual Self-Monitoring														
		Antimony (Total)													
		Arsenic (Total)													
		Cadmium (Total)													
		Chromium (Total)													
		Copper (Total)													
		Cyanide (Total)													
		Formaldehyde													
		Lead (Total)													
		Mercury (Total)													
	Nickel (Total)														
	Selenium (Total)														
	Silver (Total)														

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Broad Institute Inc. 320 Charles Street Cambridge, MA 02142 #: 09101882 Category: 02	0101	SAMPLE PORT ON THE pH NEUTRALIZATION SYSTEM DISCHARGE LINE Semi-Annual Self-Monitoring Formaldehyde Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions
Camberville Dental 825 Cambridge Street Cambridge, MA 02141 #: 09405823 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridge Brewing Company 1 Kendall Square Suite B-1102 Cambridge, MA 02139 #: 09405174 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridge Dental Group 126 Inman Street Cambridge, MA 02139 #: 09405794 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridge Dental Group 897 Massachusetts Avenue Cambridge, MA 02139 #: 09405827 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridge Endodontics 1692 Massachusetts Avenue Cambridge, MA 02138 #: 09405801 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridge Health Alliance - Cambridge Hospital 1493 Cambridge Street Cambridge, MA 02139 #: 09005730 Category: 02	0101	Spigot on discharge line of pH neutralization system Semi-Annual Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Cambridge Marriott Hotel 50 Broadway Cambridge, MA 02142 #: 09103239 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridgeport Dental 10 Magazine Street Suite D Cambridge, MA 02139 #: 09407333 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridgeside Dental 77 Hurley Street Cambridge, MA 02141 #: 09405820 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridgeside Galleria Associates Trust and John Moriarty & 80 First Street Cambridge, MA 02141 #: 09409374 Category: 12	0101	Manhole D03DMH1100 located on Edwin Land Blvd			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring						
		Arsenic (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB's						
		Pesticides						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						
	0102	Catchbasin D03CBN0147 located along Cambridgeside Place						
	Monthly	Self-Monitoring						
		Arsenic (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB's						
		Pesticides						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						
Center for Human Genetics, Inc. 840 Memorial Drive Suite 101 Cambridge, MA 02139 #: 09403914 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Central Square Dental 14 Pleasant Street Floor 1 Cambridge, MA 02139 #: 09405797 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chang Shing Tofu, Inc. 37 -39 Rogers Street Cambridge, MA 02142 #: 09103465 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Charles W Malta DDS (Cambridge) 538 Cambridge Street Cambridge, MA 02141 #: 09405816 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Clear Scientific, Inc. 735 Concord Avenue Cambridge, MA 02138 #: 09102758 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Commonwealth Fusion Systems 148 Sidney Street Cambridge, MA 02139 #: 09408820 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Courtyard Dental 842 Massachusetts Avenue Cambridge, MA 02139 #: 09405824 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DaVita Northeast Cambridge Dialysis 799 Concord Avenue Cambridge, MA 02138 #: 09103261 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DePrimo's Dental 121 Charles Street Cambridge, MA 02141 #: 09405793 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Restorative Group @ Cambridge 1751 Massachusetts Avenue Cambridge, MA 02138 #: 09405810 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Services PC 1696 Massachusetts Avenue Cambridge, MA 02138 #: 09405802 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dermbiont, Inc. 19 Blackstone Street Cambridge, MA 02139 #: 09408790 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Dental of Cambridge, PC 714 Massachusetts Avenue Cambridge, MA 02139 #: 09407357 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Eagle Pharmaceuticals, Inc. 47 Moulton Street Cambridge, MA 02138 #: 09407087 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Eutropics Pharmaceuticals, Inc. 767 -C Concord Avenue Floor 2 Cambridge, MA 02138 #: 09403557 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
FAEC 35 CPD, LLC 35 Cambridgepark Drive Cambridge, MA 02138 #: 09406802 Category: 02	0101	Spigots and Access on Discharge Piping after pH Adjustment			No Discharge Violations		20-Jul-2023	Notice of Violation
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0201	Spigots on Discharge Piping after pH Adjustment						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
FogPharma 30 Acorn Park Drive Cambridge, MA 02140 #: 09405002 Category: 02	0101	Sample spigot on discharge piping after pH adjustment			No Discharge Violations		08-Aug-2023	Notice of Violation
	Semi-Annual Self-Monitoring	Copper (Total) Formaldehyde Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Forsyth Institute 245 First Street Cambridge, MA 02142 #: 09405813 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Freepoint Hotel 220 Alewife Brook Parkway Cambridge, MA 02138 #: 09103237 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fulcrum Therapeutics, Inc. 26 Landsdowne Street Cambridge, MA 02139 #: 09404799 Category: 02	0101	Spigots on discharge piping after pH adjustment			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
GSK 200 Cambridge Park Drive Cambridge, MA 02140 #: 09102720 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
GVD Corporation 45 Spinelli Place Cambridge, MA 02138 #: 09103124 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Generation Bio 301 Binney Street Cambridge, MA 02139 #: 09407270 Category: 10		No Reporting Requirements			No Discharge Violations		25-Mar-2024	Notice of Noncompliance
Gentle Dental Center of Cambridge 19 White Street Cambridge, MA 02140 #: 09405805 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----		
INDUSTRY	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Hampton Inn by Hilton - Boston/Cambridge 191 Monsignor O'Brien Highway Cambridge, MA 02141 #: 09103243 Category: 02	0102	Hotel laundry operation effluent	No Discharge Violations				No Enforcement Actions	
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
Harbinger Oncology, Inc. 25 Spinelli Place Cambridge, MA 02138 #: 09409181 Category: 02	0101	25 Spinelly Place pH neutralization system	0101	25 Spinelly Place pH neutralization system			21-May-2024 Notice of Violation	
			30-Apr-2024	Chloroform (Trichloromethane)	1.4	mg/l	DYMX < 1	06-Jun-2024 Notice of Violation
	Semi-Annual Self-Monitoring							
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0201	35/37 Spinelli Place, Lab "A"						
	Annual							
		Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
	Nickel (Total)							

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Harvard Street Dental 287 Harvard Street Cambridge, MA 02139 #: 09405814 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Harvard University Health Services 114 Mount Auburn Street Cambridge, MA 02138 #: 09405792 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
HiFiBio Therapeutics 19 Blackstone Street Cambridge, MA 02139 #: 09407121 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Holiday Inn Express and Suites Cambridge 250 Monsignor O'Brien Highway Cambridge, MA 02141 #: 09103238 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hotel Veritas 1 Remington Street Cambridge, MA 02141 #: 09405169 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hyperion Catalysis International, Inc. 38 Smith Place Cambridge, MA 02138 #: 09007176 Category: 02	0101	Riser pipe on the chip tank effluent line			No Discharge Violations		30-Aug-2023	Notice of Violation
	Semi-Annual Self-Monitoring							
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Molybdenum						
		Nickel (Total)						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0201	Plastic extrusion contact cooling water						
	Semi-Annual Self-Monitoring							
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		pH						
	0202	Wastewater from nanotubule oxidation process						
		Semi-Annual Self-Monitoring						
		TTO (Volatile Organic Fraction)						
		pH						
Iggy's Bread, Ltd. 130 Fawcett Street Cambridge, MA 02138 #: 09102766 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Intellia Therapeutics, Inc. (130 Brookline Street) 130 Brookline Street Floor 2 Cambridge, MA 02139 #: 09404460 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jeffrey E. Greenberg, DMD, P.C (dba Sweet Spot Dental) 763 Massachusetts Avenue Suite 1 Cambridge, MA 02139 #: 09405819 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kendall Hotel 350 Main Street Cambridge, MA 02142 #: 09103236 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kendall Square Dental Associates 1 Kendall Square Suite 3104 Cambridge, MA 02139 #: 09405790 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kronos Bio., Inc. 301 Binney Street Floor 2 Cambridge, MA 02142 #: 09408655 Category: 02		0101 Sample spigots on discharge piping			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Formaldehyde						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		pH						
LEAD II PROPERTY 2023, LLC 790 Memorial Drive Cambridge, MA 02139 #: 09102944 Category: 02		0101 Sample port after the pH neutralization tank			No Discharge Violations		21-Aug-2023	Notice of Violation
		Semi-Annual Self-Monitoring						
		Cadmium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
LS 400/500 CDP, LLC 20 Acorn Park Drive Cambridge, MA 02140 #: 09408148 Category: 02	0101	TTO (Volatile Organic Fraction)						No Discharge Violations
		Zinc (Total)						
		pH						
		Sample spigot on discharge piping after pH adjustment						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
LabCentral 700 Main Street Cambridge, MA 02139 #: 09404113 Category: 02	0101	Nickel (Total)	25-Jun-2024	Laboratory R&D wastewater from 700 Main Street	Cyanide (Total)	0.69	mg/l	DYM < 0.5
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
		Semi-Annual Self-Monitoring						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
	0201	Copper (Total)		Laboratory R&D wastewater from 610 Main Street				No Enforcement Actions
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
	0201	Zinc (Total)		Laboratory R&D wastewater from 610 Main Street				No Enforcement Actions
		pH						
		Semi-Annual Self-Monitoring						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Lesley University 1801 Massachusetts Avenue Cambridge, MA 02138 #: 09103338 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
LifeCanvas Technologies 1035 Cambridge Street Suite 6 Cambridge, MA 02141 #: 09406651 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MIT Dental Service 77 Massachusetts Avenue Cambridge, MA 02139 #: 09405821 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Marie B Jean-Mary DMDLCC dba Alegria Dental Group 1058 Cambridge Street Cambridge, MA 02139 #: 09407335 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mass General Brigham Healthcare 65 Landsdowne Street Cambridge, MA 02139 #: 09102849 Category: 02	0101	EFFLUENT DISCHARGED FROM PH NEUTRALIZATION			No Discharge Violations		21-Aug-2023	Notice of Violation
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Mercury (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Massachusetts General Hospital Corporation 38 Sidney Street Suite 100 Cambridge, MA 02139 #: 09102987 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Merck Sharp & Dohme LLC 320 Bent Street Cambridge, MA 02141 #: 09102677 Category: 02	0201	wastewater discharge from biomedical research			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring						
		Cadmium (Total)						
		Copper (Total)						
		Formaldehyde						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions	
		Zinc (Total)							
		pH							
	0202	Spigot on pH neutralization discharge line							
		Semi-Annual Self-Monitoring							
		Cadmium (Total)							
		Copper (Total)							
		Formaldehyde							
		Mercury (Total)							
		Nickel (Total)							
		TTO (Extractable Organic Fraction)							
		TTO (Volatile Organic Fraction)							
		Zinc (Total)							
		pH							
	Mersana Therapeutics, Inc. 840 Memorial Drive Cambridge, MA 02139 #: 09103409 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
	Metalmark Innovations 767 Concord Avenue Suite 2-1 Cambridge, MA 02138 #: 09408604 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
Michael J. Bane, DDS 2179 Massachusetts Avenue Cambridge, MA 02140 #: 09405808 Category: D1	No Reporting Requirements			No Discharge Violations			No Enforcement Actions		
MolecularMD 840 Memorial Drive Floor 1 Cambridge, MA 02139 #: 09403802 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions		
Mount Auburn Hospital 330 Mount Auburn Street Cambridge, MA 02138 #: 09005756 Category: 02	0101	EFFLUENT FROM PH NEUTRALIZATION SYSTEM	0101	EFFLUENT FROM PH NEUTRALIZATION SYSTEM			23-Aug-2023 Notice of Violation 09-Feb-2024 Notice of Violation 05-May-2024 Notice of Violation		
	Quarterly	Self-Monitoring	18-Jan-2024	Cyanide (Total)	0.74	mg/l	DYMX < 0.5		
		Cyanide (Total)							
		Formaldehyde							
		Mercury (Total)							
		TTO (Volatile Organic Fraction)							
		pH							
	0201	EFFLUENT FROM CENTRAL PROCESSING OPERATIONS							
	Semi-Annual Self-Monitoring								
		Chromium (Total)							
		Nickel (Total)							
		Zinc (Total)							
		pH							

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
North Cambridge Dental 2331 Massachusetts Avenue Cambridge, MA 02141 #: 09407345 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Novartis Institutes for BioMedical Research 181 Massachusetts Avenue Cambridge, MA 02139 #: 09404634 Category: 02	0101	181 Mass Ave - biomedical research waste water	0101	181 Mass Ave - biomedical research waste water			No Enforcement Actions	
	Quarterly	Self-Monitoring	27-Jun-2024	Lead (Total)	0.23	mg/l	DYMX < 0.2	
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
	0201	22 Windsor St - biomedical research wastewater						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
Novartis Institutes for BioMedical Research, Inc. 250 Massachusetts Avenue Cambridge, MA 02139 #: 09103233 Category: 02	0101	SPIGOT ON NORTH PH NEUTRALIZATION SYSTEM DISCHARGE LINE	0101	SPIGOT ON NORTH PH NEUTRALIZATION SYSTEM DISCHARGE LINE			06-Jun-2024 Notice of Violation	
		Semi-Annual Self-Monitoring	22-May-2024	Zinc (Total)	6.67	mg/l	DYMX < 1	
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
	0201	SPIGOT ON SOUTH PH NEUTRALIZATION SYSTEM DISCHARGE LINE						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
NovoBiotic Pharmaceuticals, LLC 767 C Concord Street Cambridge, MA 02138 #: 09103303 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Paula Sones, DDS, PC dba Cambridge Smiles 180 Alewife Brook Parkway Cambridge, MA 02138 #: 09405811 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peter J. McDonald, DMD 872 Massachusetts Avenue Suite 2-6 Cambridge, MA 02139 #: 09407354 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pfizer, Inc. 610 Main Street Cambridge, MA 02139 #: 09403775 Category: 02	0201	One Portland Street R&D wastewater neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Cadmium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Phenol						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0301	610 Main Street R&D wastewater neutralization system						
	Semi-Annual Self-Monitoring							
		Cadmium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Mercury (Total)						
		Phenol						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Philips Medical Systems 222 Jacobs Street Cambridge, MA 02141 #: 09408084 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Porter Square Family Dental 14 Upland Road Cambridge, MA 02140 #: 09405798 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Prospect Dental Group 30 Prospect Street Cambridge, MA 02139 #: 09407351 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quad 75 Moulton Street & 20 Wilson Road, LLC 75 Moulton Street Cambridge, MA 02138 #: 09406704 Category: 02	0101	Spigot on Discharge Piping			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Ra Pharmaceuticals, Inc. 87 Cambridge Park Drive Floor 1 Cambridge, MA 02140 #: 09403443 Category: 02	0101	Biomedical research wastewater			No Discharge Violations		08-Aug-2023	Notice of Violation
		Semi-Annual Self-Monitoring Formaldehyde TTO (Volatile Organic Fraction) pH						
Ragon Institute 400 Tech Square 400 Technology Square Floor 7,8,9, basemnt Cambridge, MA 02139 #: 09403940 Category: 02	0101	biomedical research wastewater			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Ragon Institute of Mass General, MIT, and Harvard 600 Main Street Cambridge, MA 02139 #: 09409857 Category: 02	0101	pH neutralization system on mezzanine level			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Repertoire Immune Medicine 26 Landsdowne Street Cambridge, MA 02139 #: 09406641 Category: 02	0101	pH neutralization system in lower level of building.			No Discharge Violations		28-Aug-2023 Notice of Violation 10-May-2024 Notice of Violation	
	Semi-Annual	Self-Monitoring Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Residence Inn Boston Cambridge 120 Broadway Cambridge, MA 02142 #: 09006929 Category: 02	0101	laundry waste water			No Discharge Violations		21-Mar-2024 Notice of Noncompliance	
	Annual	Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Oil and Grease Zinc (Total) pH						
Rheos Medicines, Inc. 245 First Street Cambridge, MA 02142 #: 09408666 Category: 10	No Reporting Requirements				No Discharge Violations		No Enforcement Actions	

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Richard S. Brown DMD 14 Concord Avenue Suite 203 Cambridge, MA 02138 #: 09405796 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Rowland Institute at Harvard 100 Edwin H. Land Boulevard Cambridge, MA 02142 #: 09006099 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Royal Sonesta Hotel 40 Edwin H Land Boulevard Cambridge, MA 02142 #: 09405160 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Russell L Forman DMD PC 875 Massachusetts Avenue Suite 63 Cambridge, MA 02139 #: 09405826 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sanofi Corporation 640 Memorial Drive Cambridge, MA 02139 #: 09403933 Category: 02		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sanofi Pasteur Biologics 38 Sidney Street Floor 4 Cambridge, MA 02139 #: 09101547 Category: 02	0101	Spigot(s) on the pH neutralization system discharge line			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Formaldehyde Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Schlumberger Technology Corporation One Hampshire Street MD-A108 Cambridge, MA 02139 #: 09103590 Category: 02	0101	Spigot on the pH neutralization system discharge line			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Scholar Rock Inc. 301 Binney Street Cambridge, MA 02142 #: 09408764 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Seres Therapeutics 271 Cambridge Street Cambridge, MA 02141 #: 09409075 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sheraton Commander Hotel 16 Garden Street Cambridge, MA 02138 #: 09103492 Category: 02	0101	WASHING MACHINE DISCHARGE LINE IN THE LAUNDRY ROOM			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Oil and Grease pH						
Shire Human Genetic Therapies 205 Alewife Brook Parkway Cambridge, MA 02138 #: 09102452 Category: 02	0101	STANDPIPE ON THE pH NEUTRALIZATION SYSTEM DISCHARGE LINE			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Oil and Grease TTO (Volatile Organic Fraction) Zinc (Total) pH						
Smile Line Dental Medicine 11 Binney Street Cambridge, MA 02142 #: 09407336 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Smithsonian Astrophysical Observatory 100 Acorn Park Drive Cambridge, MA 02140 #: 09103606 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Spaulding Hospital - Cambridge 1575 Cambridge Street Cambridge, MA 02138 #: 09007674 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Superior Nut Co., Inc. 225 Msgr. O'Brien Highway Cambridge, MA 02141 #: 09001997 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Takeda Pharmaceuticals U.S.A., Inc. 35 Landsdowne Street Cambridge, MA 02139 #: 09103014 Category: 02	0101	SAMPLE PORT ON THE PH NEUTRALIZATION DISCHARGE LINE	0101	SAMPLE PORT ON THE PH NEUTRALIZATION DISCHARGE LINE			04-Aug-2023 Notice of Violation	
	Semi-Annual Self-Monitoring	Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total) Nickel (Total) Silver (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH	17-Oct-2023 pH		5	S.U. Grab/ Ph > 5.5	07-Nov-2023 Notice of Violation	
Takeda Pharmaceuticals U.S.A., Inc. 40 Landsdowne Street Cambridge, MA 02139 #: 09103180 Category: 02	0101	SPIGOT ON pH NEUT. SYS DISCHARGE LINE BEFORE WEIR BOX			No Discharge Violations		No Enforcement Actions	
	Semi-Annual Self-Monitoring	Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Takeda Vaccines, Inc. 75 Sidney Street Cambridge, MA 02139 #: 09102278 Category: 10		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Telis Biosciences, Inc. 19 Blackstone Street Cambridge, MA 02139 #: 09409057 Category: 10		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
The Charles Hotel 1 Bennett Street Cambridge, MA 02138 #: 09007167 Category: 10		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
The Forsyth Institute 245 First Street Cambridge, MA 02142 #: 09403492 Category: 02	0101	dental research wastewater discharged through the neutralization system			No Discharge Violations		No Enforcement Actions	
	Semi-Annual Self-Monitoring	Mercury (Total) TTO (Volatile Organic Fraction) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Torus Biosystems Inc. 125 Cambridgepark Drive Floor 5 Cambridge, MA 02140 #: 09408626 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ultimate Dental of Cambridge PC 2286 Massachusetts Avenue Cambridge, MA 02140 #: 09405809 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vericel Corporation 64 Sidney Street Cambridge, MA 02139 #: 09007633 Category: 02	0101	Glassware Facilities Room 334			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Copper (Total) Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
	0102	Sanitization Facilities Room 331						
	Annual	Self-Monitoring Copper (Total) Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
	0103	Limestone chiptank beneath sanitization room sink						
	Annual	Self-Monitoring Copper (Total) Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vizgen, Inc. 61 Moulton Street Cambridge, MA 02138 #: 09408147 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
WSQ Ltd Partnership&City of Cambridge, Bond Civil & Utility Sherman Street Cambridge, MA 02140 #: 09409427 Category: 12		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Walker Dental 60 Brattle Street Cambridge, MA 02138 #: 09405818 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Waters Corporation 301 Binney Street Suite 102A Cambridge, MA 02142 #: 09408589 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wave Life Sciences 733 Concord Avenue Cambridge, MA 02138 #: 09403396 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Whitehead Institute for Biomedical Research 455 Main Street Cambridge, MA 02142 #: 09006332 Category: 02	0101 Quarterly	pH neutralization system effluent line sample port Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
AmericanBio, Inc. 20 Dan Road Canton, MA 02021 #: 10102671 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Anna Dalavurak DDS 779 Washington Street Canton, MA 02021 #: 10405836 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Armstrong Pharmaceuticals, Inc. 25 John Road Canton, MA 02021 #: 10103660 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Baohua Zhang DMD PC 8 Forge Pond Canton, MA 02021 #: 10405837 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boyajian, Inc. 144 Will Drive Canton, MA 02021 #: 10405456 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Canton Dental Collaborative 726 Washington Street Canton, MA 02021 #: 10405835 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Canton Dental Group 608 Washington Street Canton, MA 02021 #: 10405832 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Canton Distributors CML Inc. 250 Dan Road Canton, MA 02021 #: 10404736 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Canton Family Dental 713 Washington Street Canton, MA 02021 #: 10405834 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chemic Laboratories, Inc. 480 Neponset Street Building 7 Canton, MA 02021 #: 10405066 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cobb Corner Endodontics PC 95 Washington Street Suite 482 Canton, MA 02021 #: 10405838 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
David F. Gaughan DDS 656 Chapman Street Canton, MA 02021 #: 10405833 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Del Monte Fresh Produce N.A., Inc. 105 Shawmut Road Canton, MA 02021 #: 10405429 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Aid 1 95 Washington Street Suite 480 Canton, MA 02021 #: 10405839 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Draper Properties, Inc. 28 Draper Lane Canton, MA 02021 #: 10002472 Category: 02	0102	WASTEWATER FROM DYEING OF FIBERS			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Oil and Grease pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dream Smile Dental 2184 Washington Street Canton, MA 02021 #: 10405828 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dunkin Brands (Corporate Headquarters) 130 Royall Street Canton, MA 02021 #: 10405211 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Emergent BioSolutions, Inc. 50 Shawmut Road Canton, MA 02021 #: 10103255 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Emessa Dental Associates, P.C. 95 Washington Street Suite 472 Canton, MA 02021 #: 10409147 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
HTL BMI 95 Shawmut Road Canton, MA 02120 #: 10409651 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Homewood Suites by Hilton 50 Royall Street Canton, MA 02021 #: 10405320 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ideal Instrument Co., Inc. 863 Washington Street Canton, MA 02021 #: 10002364 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kindness Dental Center 1032 Turnpike Street Suite 203 Canton, MA 02021 #: 10407867 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Matrix Sciences 70 Shawmut Road Suite 6 Canton, MA 02021 #: 10005495 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Organogenesis, Inc. 150 Dan Road Canton, MA 02021 #: 10007292 Category: 02	0101	Wastewater from cell culture operations			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Formaldehyde Mercury (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Organogenesis, Inc. 85 Dan Road Canton, MA 02021 #: 10403747 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
PecunitStreetWater Treatment Facility 40 Carey Circle Canton, MA 02021 #: 10103692 Category: 02	0101	Backwash residuals sample port			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Total Suspended Solids Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Nickel (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Pledge Biosciences, LLC 45 Dan Road Suite 382 Canton, MA 02021 #: 10405477 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Podgurski Corporation 8 Springdale Avenue Canton, MA 02021 #: 10100401 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert Reiser & Co., Inc. 725 Dedham Street Canton, MA 02021 #: 10006496 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Saratoga Salad Dressing 5 Whitman Road Canton, MA 02021 #: 10403770 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
TrilliumBrewing Company 110 Shawmut Road Canton, MA 02021 #: 10405189 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tufts Dental Facility at Pappas Rehabilitation Hosp. 3 Randolph Street Canton, MA 02021 #: 10405829 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
UL VS Canton, Inc. 85 John Road Canton, MA 02021 #: 10102647 Category: 02	0101	Effluent from Microbiology and Chemistry Laboratories			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		TTO (Volatile Organic Fraction)						
		pH						
	0102	Effluent from the Physical Testing Laboratory						
	Annual	Self-Monitoring						
		Mercury (Total)						
		Zinc (Total)						
		pH						
3D Fortify, Inc. 75 Hood Park Drive Charlestown, MA 02129 #: 47409499 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
A John's John 9 R Sherman Street Charlestown, MA 02129 #: 47404182 Category: 06	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Accion Systems, Inc. 529 Main Street Suite 114 Charlestown, MA 02129 #: 47404707 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Charlestown Dental Care 1 Thompson Square Suite 203 Charlestown, MA 02129 #: 47405840 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Eton Bioscience, Inc. 56 Roland Street Suite 306 Charlestown, MA 02129 #: 47403829 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hood Park LLC and Lee Kennedy Co. Inc. 10 Stack Street Charlestown, MA 02129 #: 47407764 Category: 12	0101	Sampling spigots on the final discharge pipe of the fractionation tank to M.H. #23			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring						
		Arsenic (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB/Pesticides						
		Selenium (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Indigo, Inc. 500 Rutherford Avenue Charlestown, MA 02129 #: 47404765 Category: 02	0102	Sampling spigots on the final discharge pipe of the fractionation tank to M.H. #28						
	Monthly	Self-Monitoring						
		Arsenic (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB/Pesticides						
		Selenium (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						
Indigo, Inc. 500 Rutherford Avenue Charlestown, MA 02129 #: 47404765 Category: 02	0101	Spigot after the pH neutralization tank		0101	Spigot after the pH neutralization tank		06-Oct-2023 Notice of Violation	
				27-Sep-2023	TTO	6.45 mg/l	DYMX	< 5
				27-Sep-2023	Chloroform (Trichloromethane)	6.4 mg/l	DYMX	< 1
				0201	Spigot after the pH neutralization tank			
				22-Sep-2023	Copper (Total)	1.62 mg/l	DYMX	< 1
				27-Sep-2023	Copper (Total)	3.39 mg/l	DYMX	< 1
Louis W. Mian Incorporated 547 Rutherford Avenue Charlestown, MA 02129 #: 47002583 Category: 10	0201	Spigot after the pH neutralization tank						
MGH Mass Biomedical Research Center 114 16th Street Charlestown, MA 02129 #: 47102651 Category: 02		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
MGH Mass Biomedical Research Center 114 16th Street Charlestown, MA 02129 #: 47102651 Category: 02	0101	SAMPLING PORT AFTER NEUTRALIZATION						
MGH Mass Biomedical Research Center 114 16th Street Charlestown, MA 02129 #: 47102651 Category: 02	Quarterly	Self-Monitoring						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Cyanide (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		Zinc (Total)						
		pH						
		Formaldehyde						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
Mama Rosie's Ravioli Co., Inc. 10 Dorrance Street Charlestown, MA 02129 #: 47102694 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Massachusetts General Hospital - CNY Building 75 75 Third Avenue Charlestown, MA 02129 #: 47103610 Category: 02	0101	Sampling port after pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
N.E.W. Health Charlestown 15 Tufts Street Charlestown, MA 02129 #: 47405841 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert J Esdale DDS 175 Main Street Charlestown, MA 02129 #: 47405843 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Spaulding Rehabilitation Hospital 300 First Avenue Charlestown, MA 02129 #: 47006021 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Spaulding Rehabilitation Hospital Corporation 96 Thirteenth Street Charlestown, MA 02129 #: 47404173 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Teamsterscare Dental Local 25 16 Sever Street Charlestown, MA 02129 #: 47405842 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Whittemore-Wright Co. 62 Alford Street Charlestown, MA 02129 #: 47002590 Category: 02	0101	SOAPMANUFACTURINGWASTEWATERAFTER NEUTRALIZATION			No Discharge Violations		12-Feb-2024	Notice of Violation
		Semi-Annual Self-Monitoring Oil and Grease pH						
Affordable Family Dental 59 Washington Avenue Chelsea, MA 02150 #: 11405851 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alpha Dental Chelsea 778 Broadway Chelsea, MA 02150 #: 11407385 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bellingham Square Family Dental PC 2 Washington Avenue Chelsea, MA 02150 #: 11407381 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beth Israel Deaconess Healthcare-Chelsea 1000 Broadway Chelsea, MA 02150 #: 11101469 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Broadway Family Dental 373 Broadway Chelsea, MA 02150 #: 11405850 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chelsea Dental Associates 109 Washington Avenue Chelsea, MA 02150 #: 11405846 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chelsea Pediatric Dentistry 950 Broadway Unit 1C Chelsea, MA 02150 #: 11407387 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Cortland Dental & Braces _Chelsea Facility 1096 Revere Beach Parkway Chelsea, MA 02150 #: 11405847 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cutone Specialty Foods Inc. 145 Market Street Chelsea, MA 02150 #: 11101795 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Jeyasri Gunarajasingam 100 Everett Avenue Unit 5 Chelsea, MA 02150 #: 11407377 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Family Dental Care 357 Broadway Chelsea, MA 02150 #: 11405849 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Golden Cannoli Shells Company 99 Crescent Avenue Chelsea, MA 02150 #: 11007114 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Holden Fruit & Produce, Inc. 1 Griffin Way Chelsea, MA 02150 #: 11407872 Category: 10		No Reporting Requirements			No Discharge Violations		05-Jun-2024	Notice of Noncompliance
Holiday Inn - Boston Logan Airport 1012 Broadway Chelsea, MA 02150 #: 11408322 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
JSB Industries Inc. dba Muffin Town 130 Crescent Avenue Chelsea, MA 02150 #: 11103153 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lang's Dental Center 110 Park Street Chelsea, MA 02150 #: 11407379 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MGH Chelsea Health Center 151 Everett Avenue Chelsea, MA 02150 #: 11101531 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Mystic Dental Studio 158 Everett Avenue Unit 5 Chelsea, MA 02150 #: 11407462 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peter Condakes Co., Inc. 74 -77 New England Produce Center Chelsea, MA 02150 #: 11000828 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peter Pan Bus Lines 333 Third Street Chelsea, MA 02150 #: 11103361 Category: 02	0102	Spigot(s) on the discharge line of the 2500 gallon storage tank			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Oil and Grease Zinc (Total) pH						
Residence Inn by Marriott_Boston Logan Airport 200 Maple Street Chelsea, MA 02150 #: 11403900 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sonoran Boston Logan LLC_Double Tree by Hilton Boston Logan 201 Everett Avenue Chelsea, MA 02150 #: 11403674 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
TND 170 Cottage LLC & Bald Hill Builders LLC 170 Cottage Street Chelsea, MA 02150 #: 11409854 Category: 12	0101	Catch Basin at Southeast corner of jobsite (AD4)			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	Catch basin at the north of the southeast corner of jobsite (Contech CDS S1515-3)						
	Monthly	Self-Monitoring Arsenic (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB's						
		Pesticides						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						
	0103	Catch basin the the left of the southeast corner or the jobsite (AD3)						
	Monthly	Self-Monitoring						
		Arsenic (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB's						
		Pesticides						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						
	0104	Manhole in doghouse at Southeast corner of jobsite (DMH5)						
	Monthly	Self-Monitoring						
		Arsenic (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB's						
		Pesticides						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						
TRAC TEST INDUSTRY 2 2 Griffin Way Chelsea, MA 02150 #: 11408504 Category: 02	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Trans Dental Care Inc. 242 Everett Avenue Chelsea, MA 02150 #: 11405848 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Aim Dental, P.C. 19 High Street Clinton, MA 01020 #: 57407410 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Clinton Hospital 201 Highland Street Clinton, MA 01510 #: 57101963 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dunn & Company 75 Green Street Clinton, MA 01510-0968 #: 57101034 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Immediate Dental 127 High Street Clinton, MA 01510 #: 57407409 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Liberty Compassion Inc. dba Affinity 179 Brook Street Clinton, MA 01510 #: 57408176 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
New England Harvest 89 Parker Street Clinton, MA 01510 #: 57409351 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Simply Pediatric Dentistry and Orthodontics 200 High Street Clinton, MA 01510 #: 57407411 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Society Cannabis Co. 470 Main Street Clinton, MA 01510 #: 57409022 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sterling Precision dba Vitesse Systems - Lawrence Street 99 Lawrence Street Clinton, MA 01510 #: 57409768 Category: 02	0101	Desalt rinsewater			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Aluminum						
		Chromium (Total)						
		Copper (Total)						
		Mercury (Total)						
		Nickel (Total)						
Sterling Street Brewery 175 Sterling Street Clinton, MA 01510 #: 57409352 Category: 10		Oil and Grease						
		Zinc (Total)						
		pH						
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Town of Clinton DPW, Clinton Water Treatment Fac. 55 West Boylston Street Clinton, MA 01510 #: 57103331 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tyca Corporation 470 Main Street Clinton, MA 01510 #: 57101499 Category: 02	0101	Apparel washing and dyeing operations			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Chromium (Total) Copper (Total) Zinc (Total) pH						
Advanced Oakdale Dental 244 River Street Dedham, MA 02026 #: 12407417 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Red Cross Blood Services - New England 180 Rustcraft Road Dedham, MA 02026 #: 12100250 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aspen Dental 162 Providence Highway Dedham, MA 02026 #: 12405863 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health dba Dedham Medical Associates 1 Lyons Street Dedham, MA 02026 #: 12102794 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dedham Dental Associates 888 Washington Street Suite 306 Dedham, MA 02026 #: 12405872 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dedham Dental Group 15 Bryant Street Dedham, MA 02026 #: 12405862 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dedham Dentist 110 Bridge Street Dedham, MA 02026 #: 12405861 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dedham Family Dental Care 395 Washington Street Dedham, MA 02026 #: 12405870 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dedham/Westwood Water District (Bridge Street WTP) 536 Bridge Street Dedham, MA 02026 #: 12007016 Category: 02	0101 Monthly	SPIGOT ON PVC BACKWASH DISCHARGE LINE Self-Monitoring Total Suspended Solids pH Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Nickel (Total) Zinc (Total)			No Discharge Violations			No Enforcement Actions
Dental Park 211 High Street Dedham, MA 02026 #: 12405865 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Specialties 245 Washington Street Dedham, MA 02026 #: 12405866 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Anna Vishart Digital Dental 418 Washington Street Dedham, MA 02026 #: 12407422 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Endodontic Care PC 5 School Street Dedham, MA 02026 #: 12405871 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fairfield Inn by Marriott Boston Dedham 235 Elm Street Dedham, MA 02026 #: 12007169 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gauri Patil DMD PC 380 High Street Dedham, MA 02026 #: 12405869 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Island Hospitality Management III LLC dba Residence Inn Dedh 259 Elm Street Dedham, MA 02026 #: 12103690 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John J Fiore DMD 19 Needham Street Dedham, MA 02026 #: 12405864 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Moderna Inc. 210 Rustcraft Road Dedham, MA 02026 #: 12408653 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
New England Baptist Outpatient Care Center 40 Allied Drive Dedham, MA 02026 #: 12403947 Category: 02	0101	Discharge from the operating room Central Supply Operation			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Copper (Total) Formaldehyde pH TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)						
P-LR-5A, LP (dba) Hilton Dedham 25 Allied Drive Dedham, MA 02026 #: 12100007 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smile Design Dental Team of Dedham 347 Washington Street Suite 302 Dedham, MA 02026 #: 12407869 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Spire Hospitality LLC dba Holiday Inn Dedham 55 Ariadne Road Dedham, MA 02026 #: 12006066 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vargas Family Dentistry 263 Washington Street Dedham, MA 02026 #: 12405867 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ATS Equipment Inc. 33 Locust Street Dorchester, MA 02125 #: 48103356 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Adams Dental Care 253 Adams Street Dorchester, MA 02122 #: 48405885 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Apollo Dental Associates 940 Dorchester Avenue Dorchester, MA 02122 #: 48407449 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BCP BEAT Property LLC 135 Morrissey Boulevard Dorchester, MA 02125 #: 48409372 Category: 02	0101	Spigot on the discharge line after the pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0201	Spigot on the discharge line after the pH neutralization system						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0301	Spigot on the discharge line after the pH neutralization system						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0401	Spigot on the discharge line after the pH neutralization system						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Zinc (Total) pH						
Beacon Dental Group 1026 Blue Hill Avenue Dorchester, MA 02124 #: 48405874 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Codman Square Health Center, Inc. 637 Washington Street Dorchester, MA 02124 #: 48102354 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
CommonWealth Kitchen 196 Quincy Street Dorchester, MA 02121 #: 48404925 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Commonwealth Zoological Corporation dba Zoo New England 1 Franklin Park Road Dorchester, MA 02121 #: 48103571 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Courtyard by Marriott 63 R Boston Street Dorchester, MA 02125 #: 48103566 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cummins Family Dental 1100 Washington Street Suite 208 Dorchester, MA 02124 #: 48407424 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dentonic dba Franklin Park Family Dental 614 B Blue Hill Avenue Suite B Dorchester, MA 02121 #: 48407441 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Diamond Windows & Doors Mfg. 99 E Cottage Street Dorchester, MA 02125 #: 48103253 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dorchester Beer Holdings LLC 1250 Massachusetts Avenue Dorchester, MA 02125 #: 48404650 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dorchester Dental 1370 Dorchester Avenue Unit 32 - 34 Dorchester, MA 02122 #: 48407427 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
DotHouse Health, Inc. 1353 Dorchester Avenue Dorchester, MA 02122 #: 48102474 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Malkemus Inc. 166 Columbia Road Dorchester, MA 02122 #: 48407430 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Emmerson Animal Hospital, Inc. 255 Freeport Street Dorchester, MA 02122 #: 48103157 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Family Dental Care of Dorchester 1444 Dorchester Avenue Dorchester, MA 02122 #: 48405878 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Family Dentistry 1470 Dorchester Avenue Dorchester, MA 02122 #: 48407605 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Folan Family Dental 540 Gallivan Boulevard Suite 203 Dorchester, MA 02124 #: 48409209 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Geiger Gibson Community Health Center 250 Mt Vernon Street Dorchester, MA 02125 #: 48405884 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Han M. Le DMD PC 1510 Dorchester Avenue Dorchester, MA 02111 #: 48405880 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvard St Neighborhood Health Center 632 Blue Hill Avenue Dorchester, MA 02121 #: 48405888 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Holiday Inn Express Boston 69 -R Boston Street Dorchester, MA 02125 #: 48103562 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
M. F. Foley Co. 24 W Howell Street Dorchester, MA 02125 #: 48003371 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Metropolitan Dental Center 1417 Dorchester Avenue Dorchester, MA 02122 #: 48405877 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Michael J Masse DDS 212 Ashmont Street Dorchester, MA 02124 #: 48405882 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
NSTAR Electric Company, dba Eversource Energy 120 East Cottage Street Dorchester, MA 02125 #: 48102159 Category: 02	0101	VEHICLE WASHING EFFLUENT AT MANHOLE AFTER SEPARATOR			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Lead (Total)						
		Lead (Total)						
		Oil and Grease						
		Oil and Grease						
		PCB's						
		PCB's						
		Pesticides						
		Pesticides						
		TTO (Extractable Organic Fraction)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		Zinc (Total)						
		pH						
		pH						
Ramada Inn Boston 800 Morrissey Boulevard Dorchester, MA 02122 #: 48103706 Category: 10		No Reporting Requirements			No Discharge Violations		14-Sep-2023	Notice of Noncompliance
Robert R. Perry, Jr. DMD PC 256 Ashmont Street Dorchester, MA 02124 #: 48405886 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sparkle Dental 97 Neponset Avenue Dorchester, MA 02122 #: 48405893 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Steward Carney Hospital, Inc. 2100 Dorchester Avenue Dorchester, MA 02124-5666 #: 48103066 Category: 10		No Reporting Requirements			No Discharge Violations		22-Feb-2024	Notice of Noncompliance
The Braces Place and T-Station Dental 1792 Dorchester Avenue Dorchester, MA 02124 #: 48407939 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Uphams Corner Health Center 636 Columbia Road Dorchester, MA 02125 #: 48405889 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
AP Dental & Laser Center 231 Border Street East Boston, MA 02128 #: 49407459 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Airlines, Inc. Logan International Airport Terminal B East Boston, MA 02128 #: 49003535 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Central Square Smiles, P.C. 38 Central Square Unit 1 East Boston, MA 02128 #: 49407463 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Channel Fish Company 370 East Eagle Street East Boston, MA 02128 #: 49003550 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Courtyard Marriott 225 McClellan Highway East Boston, MA 02128 #: 49103563 Category: 02		0101 Laundry effluent from common line Semi-Annual Self-Monitoring Mercury (Total) Oil and Grease pH			No Discharge Violations			No Enforcement Actions
Delta Air Lines, Inc. 100 Terminal A East Boston, MA 02128 #: 49003562 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Downeast Cider House, LLC 256 Marginal Street East Boston, MA 02128 #: 49404180 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
East Boston Dental and Orthodontics PC 999 Saratoga Street East Boston, MA 02128 #: 49405902 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
East Boston Neighborhood Health Center EPNHC 20 Maverick Square East Boston, MA 02128 #: 49407461 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Embassy Suites Boston at Logan Airport 207 Porter Street East Boston, MA 02128 #: 49406355 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gate Gourmet 21 Lovell Street East Boston, MA 02128 #: 49003616 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hilton Boston Logan Airport One Hotel Drive East Boston, MA 02128 #: 49405020 Category: 02		0101 Laundry wastewater discharge.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Mercury (Total) Oil and Grease Zinc (Total) pH						
Hyatt Regency - Boston Harbor Lessee 101 Harborside Drive East Boston, MA 02128 #: 49103104 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Julia Faigel, DDS 55 Meridian Street East Boston, MA 02128 #: 49407470 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
LSG/Skychefs 25 Lovell Street East Boston, MA 02128 #: 49102144 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Liliana DiFabio DMD 56 Bennington Street East Boston, MA 02128 #: 49405900 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Maverick Family Dental PC 45 Maverick Square East Boston, MA 02128 #: 49405898 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
My Dental - East Boston 151 Meridian Street East Boston, MA 02128 #: 49407457 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
All Care Dental of Everett 80 Chelsea Street Everett, MA 02149 #: 13405913 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bearmoose Brewing Company, Inc. 1934 Revere Beach Parkway Everett, MA 02149 #: 13406920 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bone Up Brewing Company, LLC 38 Norman Street Everett, MA 02149 #: 13404713 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bostonean Marble & Granite 151 Bow Street Everett, MA 02149 #: 13405043 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Broadway Dentists LLC 609 Broadway Everett, MA 02149 #: 13405912 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Buenas LLC 189 Elm Street Everett, MA 02149 #: 13407551 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chicken & Rice Guys 77 Ferry Street Everett, MA 02149 #: 13406598 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Colonial Marble Company, Inc. 25 Garvey Street Everett, MA 02149 #: 13000049 Category: 10		No Reporting Requirements			No Discharge Violations		03-Jan-2024	Notice of Noncompliance

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
DPV Transportation, Inc. 383 Second Street Everett, MA 02149 #: 13408000 Category: 02	0101	Y-connection clean-out before gas/oil separator	0101	Y-connection clean-out before gas/oil separator			11-Aug-2023	Notice of Violation
	Semi-Annual Self-Monitoring		27-Jun-2024	Zinc (Total)	1.12	mg/l DVMX < 1		
		Chromium (Total)						
		Copper (Total)						
		Lead (Total)						
		Nickel (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Everett Dental Associates 345 Main Street Everett, MA 02149 #: 13405907 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Everett Dental Center 95 Main Street Everett, MA 02149 #: 13405916 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Everett Dental Wellness 826 Broadway Everett, MA 02149 #: 13405914 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Everett Family Dental 459 Broadway Unit 1 Everett, MA 02149 #: 13407873 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Everett Smiles Pediatric Dentistry & Orthodontics 11 Victoria Street Everett, MA 02149 #: 13409420 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
GK Dental PC 505 Broadway Everett, MA 02149 #: 13405908 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Garden Fresh Salad Company, Inc. 304 Second Street Everett, MA 02149 #: 13407413 Category: G2	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Global Dental 439 Broadway Everett, MA 02149 #: 13407480 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Great Smiles Dental 285 Main Street Everett, MA 02149 #: 13407479 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
H.P. Cookie Company 56 Garden Street Everett, MA 02149 #: 13101801 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Night Shift Brewing, Inc. 87 Santilli Highway Everett, MA 02149 #: 13404507 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peter A Capodilupo DDS PC Family Dentistry 563 Broadway Suite 21 Everett, MA 02149 #: 13405910 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Phuong Dao DMD LLC 910 Broadway Floor 1 Everett, MA 02149 #: 13405915 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richie's King of Slush Mfg. Co. 3 Garvey Street Everett, MA 02149 #: 13404651 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Short Path Distillery, Inc. 71 Kelvin Street Unit 2 Everett, MA 02149 #: 13404611 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Signs 2 Go 4 Inc. 670 Broadway Everett, MA 02149 #: 13407720 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Universal Screening Studio, Inc. 175 Ferry Street Everett, MA 02149 #: 13101165 Category: 10		No Reporting Requirements			No Discharge Violations		22-Jan-2024	Notice of Noncompliance

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Above & Beyond Teeth 186 Union Avenue Unit G Framingham, MA 01702 #: 14407489 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Apollonia Dental LLC 223 Walnut Street Suite 6 Framingham, MA 01702 #: 14407507 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atlantis Dental Center 118 Concord Street Framingham, MA 01702 #: 14405919 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bose Corporation One New York Avenue Framingham, MA 01701 #: 14101633 Category: 10	0201	Spigot on the discharge pipe from 3D printer water jet washing			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring pH						
Boston Heart Diagnostics 175 Crossing Boulevard Suite 100 Framingham, MA 01702 #: 14404514 Category: 02	0101	Discharge line after the pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Formaldehyde TTO (Volatile Organic Fraction) pH						
C & Z Dental of Framingham 463 Worcester Road Suite 102 Framingham, MA 01701 #: 14405946 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
City of Framingham Landfill 200 Crossing Boulevard Framingham, MA 01702 #: 14102700 Category: 02	0101	Sump in the leachate pumping station			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) Thallium (Total) Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Comfort Dental of Framingham 223 Walnut Street Suite 3 Framingham, MA 01702 #: 14405928 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Concord Dental of Framingham 32 Concord Street Framingham, MA 01702 #: 14407493 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Specialty Partners 405 Cochituate Road Suite 304 Framingham, MA 01701 #: 14405941 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentplant 100 Concord Street Suite 1E Framingham, MA 01702 #: 14405917 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr Meera Ohri & Associates 463 Worcester Road Suite 404 Framingham, MA 01701 #: 14405945 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Neide Coutinho & Associates, P.C. 435 Union Avenue Framingham, MA 01702 #: 14407878 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Endodontic Associates in Framingham PC 235 Walnut Street Framingham, MA 01702 #: 14405931 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Exhibit 'A' Brewing Company, Inc. 81 Morton Street Framingham, MA 01702 #: 14404865 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
FMC - Framingham 110 Mount Wayte Avenue Framingham, MA 01702 #: 14404617 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Framingham Animal Hospital 1415 Edgell Road Framingham, MA 01701 #: 14102253 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			Limit	-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result		Date	Actions
Framingham Dental Arts Condominium Trust 55 Main Street Framingham, MA 01701 #: 14407875 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Framingham Dental Center 1283 Old Worcester Road Framingham, MA 01701 #: 14405920 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Framingham Dental Group 1671 Worcester Road Suite 103 Framingham, MA 01701 #: 14405926 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Framingham Family Dental Care 434 Old Connecticut Path Framingham, MA 01701 #: 14405942 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Framingham State University 100 State Street Framingham, MA 01701 #: 14102219 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Grace Dental 55 Main Street Framingham, MA 01702 #: 14405948 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
JNL Family Dental Office 270 Concord Street Suite 1 Framingham, MA 01702 #: 14407157 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jack's Abby Brewing 100 Clinton Street Framingham, MA 01702 #: 14404631 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joan Petracca DMD 60 Lexington Street Framingham, MA 01702 #: 14405951 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lulu Dental, P.C. dba Chang Dental Group Framingham 1671 Worcester Road Suite 401 Framingham, MA 01701 #: 14407874 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
MCI Framingham 99 Loring Drive Framingham, MA 01701 #: 14405959 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MCR Labs, LLC 85 Speen Street LL Framingham, MA 01701 #: 14406800 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Marilyn Rivero DMD 235 Walnut Street Unit 2 Framingham, MA 01702 #: 14405932 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mark Fried DMD PC 61 Edgell Road Framingham, MA 01701 #: 14405952 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Metrowest Prosthodontics 661 Franklin Street Floor 2 Framingham, MA 01701 #: 14407504 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Michael A Ayik DDS 1310 Old Worcester Road Framingham, MA 01701 #: 14405922 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nelson J Huang Family Dental 61 Lincoln Street Suite 202 Framingham, MA 01702 #: 14405953 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nobscot Dental Care 231 Worcester Road Framingham, MA 01701 #: 14407491 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
OCP LLC 500 Old Connecticut Path Framingham, MA 01701 #: 14101100 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
OS990 Corporate Center Associates LLC 200 Staples Drive Framingham, MA 01702 #: 14409496 Category: 02	0101	Process wastewater from discharge line of pH neutralization system.			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Orris Dental 233 Cochituate Road Framingham, MA 01701 #: 14407492 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peter C Morris DDS 400 Union Avenue Framingham, MA 01702 #: 14405939 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Replimune, Inc. 33 New York Avenue Framingham, MA 01701 #: 14407981 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert A Kelly DDS 434 Old Connecticut Path Suite 2A Framingham, MA 01701 #: 14405943 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sanofi 78 New York Avenue Framingham, MA 01701 #: 14103222 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sanofi - Genzyme 51 New York Avenue Framingham, MA 01701 #: 14006351 Category: 02	0102	Spigot on discharge line of neutralization system			No Discharge Violations		07-Aug-2023	Notice of Violation
		Semi-Annual Self-Monitoring Biochemical Oxygen Demand (5 Day) Sulfate pH						
	0104	Passivation wastewater						
	Annual	Self-Monitoring Chromium (Total) Nickel (Total) Oil and Grease Zinc (Total) pH						
Sanofi - Genzyme 31 New York Avenue Framingham, MA 01701 #: 14101558 Category: 02	0101	Spigot on neutralization system discharge line			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Mercury (Total) Silver (Total) Zinc (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		pH						
Sanofi - Genzyme 49 & 55 New York Avenue Framingham, MA 01701 #: 14103408 Category: 02	0101	Spigot on discharge line of neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring						
		Biochemical Oxygen Demand (5 Day)						
		Copper (Total)						
		Formaldehyde						
		Mercury (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		Zinc (Total)						
		pH						
Sanofi-Genzyme 45 New York Avenue Framingham, MA 01701 #: 14101556 Category: 02	0201	Spigot on the discharge line after the neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring						
		Biochemical Oxygen Demand (5 Day)						
		Chromium (Total)						
		Copper (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		Sulfate						
		Zinc (Total)						
		pH						
Sanofi-Genzyme 8 New York Avenue Framingham, MA 01701 #: 14404408 Category: 02	0101	Wastewater from the Integrated Continuous Bio-manufacturing Facility			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring						
		Biochemical Oxygen Demand (5 Day)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		Zinc (Total)						
		pH						
	0102	Passivation wastewater						
	Annual	Self-Monitoring						
		Chromium (Total)						
		Nickel (Total)						
		pH						
Sarah Lecerf DMD 61 Lincoln Street Suite 114 Framingham, MA 01702 #: 14405954 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sawan & Sawan Family Dental 2 Irving Street Framingham, MA 01701 #: 14407490 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Smlage Dental Center 463 Worcester Road Suite 201 Framingham, MA 01701 #: 14407876 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Speen Family Dental 689 Cochituate Road Framingham, MA 01701 #: 14407506 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Star Smile 615 Concord Street 1 Framingham, MA 01702 #: 14405937 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Braces Place of Framingham 509 Concord Street Framingham, MA 01701 #: 14407494 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Dentist at Framingham 116 Cochituate Road Framingham, MA 01701 #: 14405918 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Pediatric Dental Group 297 Union Avenue Framingham, MA 01702 #: 14405935 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Union Ave Dental 383 Union Avenue Framingham, MA 01702 #: 14405938 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Unique Dental of Framingham 130 Maynard Road Framingham, MA 01701 #: 14407488 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Walnut Dental Group 235 Walnut Street Suite 1 Framingham, MA 01702 #: 14405933 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Anderson Dentistry 190 Lincoln Street Hingham, MA 02043 #: 15405964 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dr. Jeffrey Darling DMD 22 Central Street Hingham, MA 02043 #: 15405967 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Evergrin Dental 400 Lincoln Street Suite 21 Hingham, MA 02043 #: 15405970 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hingham Dental Associates 20 Downer Avenue Suite 2 Hingham, MA 02043 #: 15405965 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hingham Dentistry 169 Lincoln Street Suite 101 Hingham, MA 02043 #: 15405962 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hingham Shipyard Family Dental PLLC 350 Lincoln Street Suite 1106 Hingham, MA 02043 #: 15407525 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Linden Ponds at Hingham Dental Office 300 Linden Ponds Way Hingham, MA 02043 #: 15405968 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Myra J Brennan DMD PC 24 Shipyard Drive Suite 203 Hingham, MA 02043 #: 15409315 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Shore Prosthodontics 210 Whiting Street Unit 1 Hingham, MA 02043 #: 15405966 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Surfside Dental Studio PLLC 344 Rockland Street Hingham, MA 02043 #: 15405969 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
TGE Associates 312 High Street Hingham, MA 02043 #: 15407524 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Brookville Dental Associates 838 South Franklin Street Holbrook, MA 02343 #: 16405973 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mica-Tron Products Corporation 275 Centre Street Unit 13 Holbrook, MA 02343 #: 16000678 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pearl Dental Associates 175 N Franklin Street Holbrook, MA 02343 #: 16407530 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Preferred Services Company, Inc. 52 Plymouth Street Holbrook, MA 02343 #: 16100468 Category: 02	0101	Discharge piping after shaker screen			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Mercury (Total) Oil and Grease Zinc (Total) pH						
South Shore Dental Care 169 N. Franklin Street Holbrook, MA 02343 #: 16407529 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ace Dental Boston 1138 River Street Hyde Park, MA 02136 #: 50405974 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aerogel Technologies, LLC 1 Westinghouse Plaza D157 Hyde Park, MA 02136 #: 50404349 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Armin Dental Associates 1234 Hyde Park Avenue Suite 201 Hyde Park, MA 02136 #: 50405977 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bankhead & Groipen 1259 Hyde Park Avenue Suite 102 Hyde Park, MA 02136 #: 50405978 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Boston Baking, Inc. 101 Sprague Street Hyde Park, MA 02136 #: 50407722 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chadda Family Dental 1234 Hyde Park Avenue Suite 103 Hyde Park, MA 02136 #: 50405976 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
My Grandma's of New England 1636 Hyde Park Avenue Hyde Park, MA 02136 #: 50102652 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Orleans Packing Company 1715 Hyde Park Avenue Hyde Park, MA 02136 #: 50102607 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Perfect Dental Hyde Park 912 River Street Hyde Park, MA 02136 #: 50405979 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Roundhead Brewing, LLC 1 Westinghouse Plaza Suite I-107 Hyde Park, MA 02136 #: 50409398 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
U Smile PC 1250 Hyde Park Avenue Hyde Park, MA 02136 #: 50407538 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
21st Century Foods, Inc. 30 -A Germania Street Jamaica Plain, MA 02130 #: 51103685 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brookside CHC Dental Dept. 3297 Washington Street Jamaica Plain, MA 02130 #: 51405982 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Caring Family Dental 594 Center Street Jamaica Plain, MA 02130 #: 51405987 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Fresh City 31 Germania Street Jamaica Plain, MA 02130 #: 51103683 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Jamaica Plain 612 Centre Street Jamaica Plain, MA 02130 #: 51405988 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
JP Family Dental 315 Centre Street Jamaica Plain, MA 02130 #: 51405981 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jamaica Plain Dental, PPL 225 Centre Street Suite 207B Jamaica Plain, MA 02119 #: 51407543 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lemuel Shattuck Hospital 170 Morton Street Jamaica Plain, MA 02130 #: 51005748 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lemuel Shattuck Hospital 170 Morton Street Jamaica Plain, MA 02130 #: 51407701 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lenox-Martell, Inc. 89 Heath Street Jamaica Plain, MA 02130 #: 51101142 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Linens by Alice 18 Brookley Road Jamaica Plain, MA 02130 #: 51404602 Category: 02		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MSPCA Angell 350 South Huntington Avenue Jamaica Plain, MA 02130 #: 51103140 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pondside Dental Associates 793 Centre Street Jamaica Plain, MA 02130 #: 51405991 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Pure Dental 3531 Washington Street Suite 102 Jamaica Plain, MA 02130 #: 51405989 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Boston Beer Company 30 Germania Street Jamaica Plain, MA 02130 #: 51007379 Category: 02	0101	Spigot on discharge line after pH neutralization			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring pH						
Turtle Swamp Brewing LLC 3377 3379 Washington Street Jamaica Plain, MA 02130 #: 51404747 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
VA Boston Health Care System Dental 150 South Huntington Avenue Jamaica Plain, MA 02130 #: 51405980 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Washington Pine LLC and Cranshaw Construction 3368 Washington Street Jamaica Plain, MA 02130 #: 51409219 Category: 12		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bob's Turkey Farm, Inc. 181 Old Common Road Lancaster, MA 01523 #: 58101498 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DaVinci Biomedical Research Products, Inc. 40 Maple Street Lancaster, MA 01561 #: 58103102 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lancaster Dental PC 136 High Street Extension Lancaster, MA 01523 #: 58405992 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mossmann Family Dental, PC 240 Main Street South Lancaster, MA 01561 #: 58406290 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nashaway Dental Group PC 131 Main Street South Lancaster, MA 01561 #: 58406289 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Theodore R. Nelson, DDS 387 Sterling Street Lancaster, MA 01523 #: 58407557 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Agenus, Inc. 3 Forbes Road Lexington, MA 02421 #: 17103198 Category: 02	0101	Spigot(s) on the discharge line after pH neutralization			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Chromium (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Volatile Organic Fraction)						
		pH						
Alexion Pharmaceuticals 65 Hayden Avenue Lexington, MA 02421 #: 17407076 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beth Israel/Children's Hospital Medical Care Ctr. 482 Bedford Street Lexington, MA 02420 #: 17101147 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Bioskills Lab LLC 1 Hartwell Place Suite 103 Lexington, MA 02421 #: 17404936 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Family Dental 16 Clarke Street Suite 14 Lexington, MA 02421 #: 17407561 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brammer Bio, LLC 45 Hartwell Avenue Lexington, MA 02421 #: 17407849 Category: 02	0101	spigot(s) located on discharge line of pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
CBSET, Inc. 500 Shire Way Lexington, MA 02421 #: 17103485 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Clarke Street Family Dental 16 Clarke Street Suite 15 Lexington, MA 02421 #: 17405999 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Daniel R Olsen DDS 1 Wallis Court Level 2 Lexington, MA 02421 #: 17405993 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dare MB, Inc. 128 Spring Street Suite 310 Lexington, MA 02421 #: 17404168 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Designer Smiles of Lexington 76 Bedford Street Suite 9 Lexington, MA 02421 #: 17407582 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dicerna Pharmaceuticals, Inc. 33 Hayden Avenue Lexington, MA 02421 #: 17407912 Category: 02	0101	Spigot(s) after pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Chromium (Total)						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Family Dentistry 175 Bedford Street Suite 14 Lexington, MA 02420 #: 17406002 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Galina Gitlin DMD 62 Massachusetts Avenue Lexington, MA 02420 #: 17406016 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Garrett K Piskor DMD PC 57 Bedford Street Suite 208 Lexington, MA 02420 #: 17406014 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions	
Genezen (formerly known as uniQure) 113 Hartwell Avenue Lexington, MA 02421 #: 17404248 Category: 02	0101	Spigot(s) off the pH neutralization system discharge line, Building A	No Discharge Violations						No Enforcement Actions
			Semi-Annual Self-Monitoring						
	Cadmium (Total)								
	Chromium (Total)								
	Copper (Total)								
	Lead (Total)								
	Mercury (Total)								
	Nickel (Total)								
	Silver (Total)								
	TTO (Extractable Organic Fraction)								
	TTO (Volatile Organic Fraction)								
	Zinc (Total)								
	pH								
	0102	Spigot(s) off the pH neutralization system final discharge line, Building B							
			Semi-Annual Self-Monitoring						
Cadmium (Total)									
Chromium (Total)									
Copper (Total)									
Lead (Total)									
Mercury (Total)									
Nickel (Total)									
Silver (Total)									
TTO (Extractable Organic Fraction)									
TTO (Volatile Organic Fraction)									
Zinc (Total)									
pH									
Hadar Dental LLC 3 Bow Street Suite 2 Lexington, MA 02420 #: 17406010 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
Hyallex Orthopaedics 99 Hayden Avenue Building D-340 Lexington, MA 02421 #: 17406523 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
Icon Dental 57 Bedford Street Suite 220 Lexington, MA 02420 #: 17406015 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
J&J Innovative Medicine (formerly Janssen) 113 Hartwell Avenue Lexington, MA 02421 #: 17403239 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Jacobio (US) Pharmaceuticals Inc. 99 Hayden Avenue Suite C-230 Lexington, MA 02421 #: 17407574 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Keith Asarkof DMD 10 Muzzey Street Lexington, MA 02421 #: 17406026 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lex Smiles PC 27 Muzzey Street Lexington, MA 02421 #: 17406008 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lexington Dental Associates PC 271 Lincoln Street Suite 2 Lexington, MA 02421 #: 17406009 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lexington Dental Care 922 Waltham Street Suite 205 Lexington, MA 02421 #: 17406022 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lexington Dental Group 57 Bedford Street Suite 110 Lexington, MA 02420 #: 17407577 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lexington Smile Studio 922 Waltham Street Suite 202 Lexington, MA 02421 #: 17407944 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Maria Evangelisti, DDS 1 Wallis Court Suite 1 Lexington, MA 02421 #: 17407560 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Medchem Partners LLC 99 Hayden Avenue Suite 210 Lexington, MA 02421 #: 17103567 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pulmatrix, Inc. 99 Hayden Avenue Suite 390 Lexington, MA 02421 #: 17103608 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Rapid Micro Biosystems, Inc. 25 Hartwell Avenue Lexington, MA 02421 #: 17409900 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert J De Regis DMD 183 Bedford Street Lexington, MA 02420 #: 17406003 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sarah Haven Davis DMD LLC 120 School Street Lexington, MA 02421 #: 17405996 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sun Pharmaceutical, Inc. 65 Hayden Avenue Suite 400 Lexington, MA 02421 #: 17103513 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
T2 Biosystems, Inc. 101 Hartwell Avenue Lexington, MA 02421 #: 17103574 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tepha, Inc. 99 Hayden Avenue Suite 360 Lexington, MA 02421 #: 17103626 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Thomas Braun DDS 20 Muzzey Street Lexington, MA 02421 #: 17406007 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Valo Early Discovery 75 Hayden Avenue Floor 2-2 Lexington, MA 02421 #: 17408889 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wallis Dental LLC 1 Wallis Court Suite 4 Lexington, MA 02421 #: 17405994 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Xenon Property, LLC (44 Hartwell Ave) 44 Hartwell Avenue Lexington, MA 02421 #: 17404648 Category: 02	0101	Cleanout on the discharge line after pH neutralization			No Discharge Violations		06-Oct-2023	Notice of Noncompliance
	Semi-Annual	Self-Monitoring Antimony (Total) Arsenic (Total) Cadmium (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Xenon Property, LLC (60 Westview Street) 60 Westview Street Lexington, MA 02421 #: 17103662 Category: 02	0101	Riser pipe on the discharge line after the pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Zen Dental Group, LLC 14 Muzzey Street Lexington, MA 02421 #: 17405997 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Access Dental, LLC 6 Pleasant Street Suite 325 Malden, MA 02148 #: 18409328 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
American Dental Consultants 578 Main Street Suite 101 Malden, MA 02148 #: 18407356 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Atlantic Dental Partners 214 Main Street Malden, MA 02148 #: 18407583 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BCD Metal Products, Inc. 205 Maplewood Street Malden, MA 02148 #: 18102432 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Family Dental 572 Pleasant Street Suite 1F Malden, MA 02148 #: 18406040 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
D2 Dental 389 Main Street Suite 403 Malden, MA 02148 #: 18406034 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dom's Sausage Company Inc. 10 Riverside Parkway Malden, MA 02148 #: 18000332 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Pei Hua Wu, M.D. 389 Main Street Suite 201 Malden, MA 02148 #: 18407590 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Endodontics of Malden 10 Holden Street Suite 5 Malden, MA 02148 #: 18406027 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Malden 225 Centre Street Malden, MA 02148 #: 18406030 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gerard A Centrella DMD 738 Salem Street Malden, MA 02148 #: 18406044 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hoff's Bakery 35 Green Street Malden, MA 02148 #: 18407879 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Interstate Food Equipment Service Inc. 43 Sharon Street Malden, MA 02148 #: 18404755 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Malden Dental Associates 389 Main Street Suite 204 Malden, MA 02148 #: 18409193 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Malden Dental Care 10 Holden Street Suite 2 Malden, MA 02148 #: 18406023 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Malden Dentistry and Braces 427 Main Street Malden, MA 02148 #: 18409327 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Malden Family Dentist 45 -A Pleasant Street Malden, MA 02148 #: 18407588 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Maplewood Dental Associates 635 Salem Street Malden, MA 02148 #: 18407597 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Piantedosi Baking Company, Inc. 240 Commercial Street Malden, MA 02148 #: 18000057 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pleasant Street Dental Associates 388 Pleasant Street Suite 2 Malden, MA 02148 #: 18406033 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quartzite Processing, Inc. 6 Holyoke Street Malden, MA 02148 #: 18000085 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sky Dental 70 Eastern Avenue Malden, MA 02148 #: 18406043 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Smart Dental 452 Pleasant Street Malden, MA 02148 #: 18406038 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Stoney Brook Family & Cosmetic Dentistry 445 Highland Avenue Malden, MA 02148 #: 18406037 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Supersport Screen Printing LLC 910 Eastern Avenue Malden, MA 02148 #: 18101606 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tabrizi Dental Associates 389 Main Street Suite 404 Malden, MA 02148 #: 18407593 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Children & Family Dentistry & Braces 90 River Street Mattapan, MA 02126 #: 52406045 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dorchester Pediatric Dentistry and Orthodontic 1192 Blue Hill Avenue Mattapan, MA 02126 #: 52408925 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Globus Dental Mattapan 1634 Blue Hill Avenue Mattapan, MA 02126 #: 52407606 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mattapan Community Health Center 1575 Blue Hill Avenue Mattapan, MA 02126 #: 52407603 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
River Street Family Dental 542 River Street Mattapan, MA 02126 #: 52407609 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Albert E Cangiano Jr DMD 132 Forest Street Medford, MA 02155 #: 19406051 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Ali Mashayekhi Family Dentists 0 Governors Avenue Suite 23 Medford, MA 02155 #: 19407613 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Anthony Giamberardino DMD, PC 84 High Street Suite 304 Medford, MA 02155 #: 19406063 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aspen Dental 690 Fellsway Plaza Medford, MA 02155 #: 19406061 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health MSO LLC 26 City Hall Mall Medford, MA 02155 #: 19007152 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BioIVT 200 Boston Avenue Suite 1550 Medford, MA 02155 #: 19403155 Category: 10		No Reporting Requirements			No Discharge Violations		14-Sep-2023	Notice of Noncompliance
Body Toppers Inc. 407 R Mystic Avenue Unit 13 Medford, MA 02155 #: 19009513 Category: 10		No Reporting Requirements			No Discharge Violations		27-Oct-2023	Notice of Noncompliance
Dental Care 0 Governors Avenue Suite 1 Medford, MA 02155 #: 19406046 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Delights PC 84 High Street Suite 203 Medford, MA 02155 #: 19406064 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Edelweiss Enterprises, Inc. 19 Blake Street Medford, MA 02155 #: 19102911 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Evolved By Nature, Inc. 196 Boston Avenue Medford, MA 02133 #: 19404213 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
First Dental 366 Salem Street Medford, MA 02155 #: 19407623 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Medford 23 Riverside Avenue Medford, MA 02155 #: 19408707 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gio Dental at Station Landing 8 Earhart Landing Medford, MA 02155 #: 19407630 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Isabelle B Jaillet DDS 12 Bower Street Medford, MA 02155 #: 19406057 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
KRE HIP HP Medford Owner, LLC dba Hyatt Place Boston Medford 116 Riverside Avenue Medford, MA 02155 #: 19103519 Category: 02	0101 Annual	Sample port on the combined discharge pipe above the floor drain trough Self-Monitoring Oil and Grease pH			No Discharge Violations		27-Mar-2024	Notice of Violation
Lawrence Memorial Hospital 170 Governors Avenue Suite 100 Medford, MA 02155 #: 19005758 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Limited to Endodontics 1 City Hall Mall Medford, MA 02155 #: 19406048 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lorenzo Lepore DDS PC 101 Main Street Suite 206 Medford, MA 02155 #: 19406049 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Main Street Dentistry & Orthodontics 251 Main Street Medford, MA 02155 #: 19406053 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Medford Endodontics 0 Governors Avenue Suite 30 Medford, MA 02155 #: 19406047 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Medford Square Dentistry and Implants 30 Main Street Medford, MA 02155 #: 19406055 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Omnicentix & Associates 289 Middlesex Avenue Medford, MA 02155 #: 19406054 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Paul K. Shick, DMD 3 Ashland Street Medford, MA 02155 #: 19407620 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pharmaron (Boston) Lab Services LLC. 47 Hall Street Medford, MA 02155 #: 19405122 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Renato Carpinto DMD 38 High Street Medford, MA 02155 #: 19406056 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Classic Smile 92 High Street Suite 11-12 Medford, MA 02155 #: 19406065 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Therese H Venedikian DMD PC 84 High Street Suite 7 Medford, MA 02155 #: 19409200 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Trustees of Tufts College 200 Boston Avenue Medford, MA 02155 #: 19103498 Category: 02	0101	Spigot on the discharge line of the pH adjustment system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
Unravel Biosciences 196 Boston Avenue Suite 1200 Medford, MA 02155 #: 19409945 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Wellington Circle Dental 1 City Hall Mall Unit 2 Medford, MA 02155 #: 19406060 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Woburn Street Dental PC 18 Woburn Street Medford, MA 02155 #: 19406052 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Yavner Dental Associates 101 Main Street Suite 220 Medford, MA 02155 #: 19406050 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Mark Gianatassio 820 Lynn Fells Parkway Melrose, MA 02176 #: 20406076 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Exquisite Dentistry - former Joseph J Scolas DMD 486 A Main Street Melrose, MA 02176 #: 20406072 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hillside Press, LLC 192 Green Street Melrose, MA 02176 #: 20103657 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hunt's Photo & Video 100 Main Street Melrose, MA 02176 #: 20101586 Category: G1	0101	PHOTO			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Silver (Total)						
Melrose Center for Oral Health 944 Main Street Melrose, MA 02176 #: 20406078 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Melrose Dental Care 80 West Foster Street Melrose, MA 02176 #: 20406075 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Melrose Family Dental PC 12 Porter Street Melrose, MA 02176 #: 20406067 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Melrose Family Dentistry LLC 10 East Emerson Street Melrose, MA 02176 #: 20406066 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Melrose Oriental Rug Co., Inc. 937 Main Street Melrose, MA 02176 #: 20404418 Category: 02	0101	Rug cleaning wastewater from collection sump in basement			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Oil and Grease pH						
Nowak Family Dental LLC 84 Myrtle Street Melrose, MA 02176 #: 20406077 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pan Dental Care 985 Main Street Melrose, MA 02176 #: 20406079 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Shieh Dental Health Care PC 44 Grove Street Melrose, MA 02176 #: 20406071 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Solomon & Wright Associates PC 12 West Emerson Street Melrose, MA 02176 #: 20406068 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vasilios Mourmoutis DMD PC 27 East Emerson Street Melrose, MA 02176 #: 20409326 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Curry College 1071 Blue Hill Avenue Milton, MA 02186 #: 21406556 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental 1 PC 480 Adams Street Suite 104 Milton, MA 02186 #: 21406084 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentistry of Milton, LLC 524 Adams Street Suite 201 Milton, MA 02186 #: 21406081 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
East Milton Dental 539 Adams Street Milton, MA 02186 #: 21406086 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gayle M Pezzulo DMD PC 480 Adams Street Milton, MA 02186 #: 21406085 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harte Dental LLC 480 Adams Street Suite 206 Milton, MA 02186 #: 21406083 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Milton Hill Dental 99 Adams Street Milton, MA 02186 #: 21406087 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Murphy Dental Group 464 Granite Avenue Milton, MA 02186 #: 21406082 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ABI Lab 27 Strathmore Road Natick, MA 01760 #: 22404969 Category: 02	0101	75-gallon limestone chip tank			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Mercury (Total) TTO (Volatile Organic Fraction) pH						
ABI-LAB2 22 Strathmore Road Natick, MA 01760 #: 22408050 Category: 02	0101	Laboratory wastewater.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Aspen Dental 843 Worcester Road Suite G Natick, MA 01760 #: 22406100 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chang Dental Group 220 North Main Street Suite 203 Natick, MA 01760 #: 22406096 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Courtyard by Marriott 342 Speen Street Natick, MA 01760 #: 22102976 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Craig I MacDonald DMD PC 182 West Central Street Natick, MA 01760 #: 22406092 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elite Dental of Natick 232 Pond Street Suite 5 Natick, MA 01760 #: 22406098 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Center of Natick 1322 Worcester Road Natick, MA 01760 #: 22406090 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jacques Boudreau DMD PC 205 Union Street Natick, MA 01760 #: 22406093 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
James R Sunners DDS PC 209 West Central Street Natick, MA 01760 #: 22406094 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kula Bio 6 Mercer Road Natick, MA 01760 #: 22409937 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Natick Dental Health 164 N Main Street Natick, MA 01760 #: 22406091 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Natick Dental Partners 235 West Central Street Natick, MA 01760 #: 22406097 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Natick Fire - Speen Street Station 268 Speen Street Natick, MA 01760 #: 22300991 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Paul R Galaidd DMD, P.C. dba Natick Dental Associates 1 Common Street Suite B Natick, MA 01760 #: 22406088 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Phoenix Diagnostics, Inc. 8 Tech Circle Natick, MA 01760 #: 22007616 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pillar Biosciences, Inc. (Strathmore Rd.) 9 Strathmore Road Natick, MA 01760 #: 22408278 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Reality Dentistry 10 Union Street Suite 3D Natick, MA 01760 #: 22406089 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
SBH Sciences, Inc. 4 -A Strathmore Road Natick, MA 01760 #: 22101930 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Samer Aleid DDS 318 North Main Street Natick, MA 01760 #: 22406099 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Scott R Helle, DMD, LLC 4 Whittier Road Natick, MA 01760 #: 22409162 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Springvale Water Treatment Plant 1080 Worcester Street Natick, MA 01760 #: 22102009 Category: 02	0101	Spigot on the sludge discharge line in the High Lift Building			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Total Suspended Solids pH						
	0103	Spigot on the Tonka Sludge Discharge Line						
	Semi-Annual	Self-Monitoring Total Suspended Solids pH						
Vita Needle Co. 22 Pleasant Street Natick, MA 01760 #: 22405227 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			-----ENFORCEMENT ACTIONS-----			
INDUSTRY	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Atrius Health - Harvard Vanguard Medical Associates 152 Second Avenue Needham, MA 02494 #: 23404428 Category: 10	No Reporting Requirements				No Discharge Violations			No EnforcementActions
Baker's Best Catering 150 Gould Street Needham, MA 02494 #: 23404100 Category: G2	No Reporting Requirements				No Discharge Violations			No EnforcementActions
Beth Israel Deaconess Hospital - Needham Campus 148 Chestnut Street Needham, MA 02492 #: 23005716 Category: 02	0104	SPIGOT ON THE DISCHARGE PIPE OF THE LIMESTONE CHIPTANK			No Discharge Violations		11-Mar-2024	Notice of Violation
	Quarterly	Self-Monitoring Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0201	OR INSTRUMENT WASHER DRAIN LINE						
	Semi-Annual	Self-Monitoring Chromium (Total) Nickel (Total) pH						
Brookline Rug Cleaning Co. Inc. 317 Hunnewell Street Needham, MA 02494 #: 23005375 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Carrie B. Reddish, DMD PC 1233 Highland Avenue Needham, MA 02492 #: 23406105 Category: D1	No Reporting Requirements				No Discharge Violations			No EnforcementActions
Charles River Wellfield Water Treatment Plant 914 Charles River Street Needham, MA 02492 #: 23101898 Category: 02	0102	Sampling port after limestone chip tank in Lab			No Discharge Violations			No EnforcementActions
	Annual	Self-Monitoring pH						
	0103	Recycled backwash water						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
	Quarterly	Self-Monitoring Arsenic (Total) Copper (Total) Nickel (Total) Total Suspended Solids Zinc (Total) pH						
Chestnut Dental Associates 87 Chestnut Street Needham, MA 02492 #: 23406112 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chillybears Inc. 6 Brook Road Needham, MA 02494 #: 23101730 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Claremont Needham Suites LLC 200 First Avenue Needham, MA 02494 #: 23406555 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
D.L. Atkinson Inc. 48 Mellen Street Needham, MA 02494 #: 23100384 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Evolved By Nature, Inc. 117 Kendrick Street Needham, MA 02494 #: 23409830 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Franklin W. Olin College of Engineering 100 Olin Way Needham, MA 02492 #: 23103042 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gillis Dental 1211 Highland Avenue Needham, MA 02492 #: 23408708 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvey Family Dental 1183 Highland Avenue Needham, MA 02492 #: 23409927 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			Limit	-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result		Date	Actions
Inform Diagnostics 15 19 Crawford Street Needham, MA 02494 #: 23102336 Category: 10		No Reporting Requirements			No Discharge Violations		22-Jan-2024	Notice of Noncompliance
Invicro, LLC 119 Fourth Avenue Needham, MA 02494 #: 23404006 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jonathan M. Davis, DMD 1410 Highland Avenue Suite 203 Needham, MA 02492 #: 23406107 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Marva Khalid DMD 105 Chestnut Street Suite 25 Needham, MA 02492 #: 23406102 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Meola Dental Group Smile & Skin Aesthetics 32 Wexford Street Needham, MA 02459 #: 23409021 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nandita Kapoor DMD PC dba Needham Dental 302 Chestnut Street Needham, MA 02492 #: 23406111 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Needham Laser Dentistry 1253 Highland Avenue Needham, MA 02494 #: 23408869 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Paul H. Aswad, DMD, PC 1253 Highland Avenue Needham, MA 02492 #: 23406106 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ST Equipment & Technology, LLC 101 Hampton Avenue Needham, MA 02494 #: 23403277 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
SXC Needham Inn LLC dba Residence Inn by Marriott 80 B Street Needham, MA 02494 #: 23404390 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			Limit	-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result		Date	Actions
Sheraton Hotel Needham 100 Cabot Street Needham, MA 02494 #: 23007315 Category: 10		No Reporting Requirements			No Discharge Violations		06-Jul-2023	Notice of Noncompliance
The Cancer Center at Beth Israel Deaconess Med. Cntr Needham 148 Chestnut Street Needham, MA 02492 #: 23404409 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Thomas A Analetto DMD 214 Chestnut Street Needham, MA 02492 #: 23406110 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vita Needle Company 919 Great Plain Avenue Needham, MA 02492 #: 23002927 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
William D Irving DDS 1116 Great Plain Avenue Needham, MA 02492 #: 23406103 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Auburndale Dental 2098 Commonwealth Avenue Newton, MA 02466 #: 24407643 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Baek Dental PC 1400 Centre Street Suite 106 Newton Centre, MA 02459 #: 24406142 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beth Israel Deaconess Healthcare - Chestnut Hill 200 Boylston Street Chestnut Hill, MA 02467 #: 24404326 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston College - Chestnut Hill Campus 140 Commonwealth Avenue Chestnut Hill, MA 02467 #: 24005439 Category: 02	0102	after the batch pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0103	Spigot on discharge pipe of neutralization tank						
		Semi-Annual Self-Monitoring						
		Formaldehyde						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0115	Spigot on discharge pipe of neutralization system						
		Semi-Annual Self-Monitoring						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0117	Spigot on the discharge pipe from the washing machines						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
	0118	Discharge from laundry machines in the Conte Forum						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
	0119	Discharge from laundry machines in the Yawkey Center						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
	0301	Discharge from laundry machines in the Frates Center						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Boylston Street Dental, LLC dba Boylston Street Dental Group 300 Boylston Street Suite 202 Chestnut Hill, MA 02467 #: 24407403 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chestnut Hill Dental 631 -A VFW Parkway Chestnut Hill, MA 02467 #: 24405858 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Complete Dental of Newton 558 Commonwealth Avenue Newton, MA 02459 #: 24406133 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Concord Dental Associates 69 Union Street Newton, MA 02459 #: 24406135 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cosmetic Dentistry Center 64 Columbus Street Newton, MA 02461 #: 24406134 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cynthia R Shapiro DMD 1957 Beacon Street Waban, MA 02468 #: 24406344 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dana Farber Cancer Institute 300 Boylston Street Chestnut Hill, MA 02467 #: 24408374 Category: 02	0101	Process wastewater from laboratory operations.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Dental Specialists of Newton 271 Auburn Street Newton, MA 02466 #: 24406123 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentist of Chestnut Hill/Convivial Dental 1244 Boylston Street Suite 205 Chestnut Hill, MA 02467 #: 24405856 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Elevian, Inc. 73 Chapel Street Newton, MA 02458 #: 24409553 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Newton 188 Needham Street Newton, MA 02462 #: 24408704 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hammond Pond Dental Group 822 Boylston Street Suite 200 Chestnut Hill, MA 02467 #: 24405859 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvey J Cohen DMD 1087 Beacon Street Suite 102 Newton, MA 02459 #: 24406114 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Herbert S. Birnbaum DMD 670 Beacon Street Newton Centre, MA 02459 #: 24406144 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kaceli Dental Aesthetics 1400 Centre Street Suite 102 Newton Centre, MA 02459 #: 24409159 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Karyopharm Therapeutics, Inc. 75 -95 Wells Avenue Floor 2 & 3 Newton, MA 02459 #: 24404334 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
LabShares Newton LLC 55 Chapel Street Suite 100 Newton, MA 02458 #: 24409247 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
LabShares Newton, LLC 90 Bridge Street Suite 100 & 200 Newton, MA 02458 #: 24404582 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lasell University 1844 Commonwealth Avenue Newton, MA 02466 #: 24405351 Category: 10		No Reporting Requirements			No Discharge Violations		06-Jul-2023	Notice of Noncompliance

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Mark Dental Group 37 Austin Street Newton, MA 02460 #: 24406129 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Massachusetts General Hospital - Newton, MA 2 Wells Avenue Newton, MA 02459 #: 24403988 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newton Centre Dental 1400 Centre Street Suite 201 Newton, MA 02459 #: 24406120 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newton Corner Dental Care 313 Washington Street Suite 102 Newton, MA 02458 #: 24406127 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newton Dental Associates 93 Union Street Suite 402 Newton, MA 02459 #: 24406139 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newton Dental PLLC 345 Boylston Street Suite 101 Newton, MA 02459 #: 24406128 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newton Dental Wellness 93 Union Street Suite 408 Newton, MA 02459 #: 24406141 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newton Family Dental Center 1172 Beacon Street Suite 104 Newton, MA 02461 #: 24406116 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newton Smile Centre 796 Beacon Street Newton, MA 02459 #: 24409286 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newtonville Dental Associates 701 Washington Street Newton, MA 02458 #: 24406136 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Rousson Family Dentistry 1001 Watertown Street Newton, MA 02465 #: 24406113 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Rustom F. Mehta DMD 1087 Beacon Street Suite 101 Newton, MA 02459 #: 24406115 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Salvatore Angelo II DMD PC 1280 Centre Street Suite 200 Newton, MA 02459 #: 24406118 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Starlident Newton Dental Office 517 Washington Street Newton, MA 02458 #: 24409059 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
T. D. Filandrianos and Associates 1400 Centre Street Suite 101 Newton, MA 02459 #: 24406121 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Center for Advanced Dental Care PLLC 93 Union Street Suite 308 Newton, MA 02459 #: 24406140 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Newton Dental Group 290 Centre Street Suite 201 Newton, MA 02458 #: 24406125 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
TissueVision, Inc. 150 California Street Newton, MA 02458 #: 24408395 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Transcode Therapeutics 73 -B Chapel Street Newton, MA 02458 #: 24409779 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
UMass Amherst - Mount Ida Campus 777 Dedham Street Newton, MA 02459 #: 24005508 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Vast Dental 433 Watertown Street Newton, MA 02458 #: 24407644 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Waban Dental Group 1180 Beacon Street Newton, MA 02461 #: 24406117 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wyzer Biosciences 132 Charles Street Newton, MA 02466 #: 24409783 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Yamamoto and Associate PC 1400 Centre Street Suite 103 Newton Centre, MA 02459 #: 24409160 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
1Globe Health Institute, LLC 333 Providence Highway Norwood, MA 02062 #: 25103550 Category: C1	0101 Annual	X-RAY FILM PROCESSOR AFTER EPAN SILVER RECOVERY SYS Self-Monitoring Silver (Total)			No Discharge Violations			No Enforcement Actions
Advanced Dental Center 125 Central Street Norwood, MA 02062 #: 25406151 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Advanced Instruments 2 Technology Way Norwood, MA 02062 #: 25407959 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Anna Zaborovsky Dental Practice 648 Washington Street Suite 204 Norwood, MA 02062 #: 25406156 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health dba Dedham Medical Associates 1177 Providence Highway Norwood, MA 02062 #: 25405503 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bliss Dental Group 111 Lenox Street Suite 113 Norwood, MA 02062 #: 25406158 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Butera Dental Specialists 89 Access Road Suite 26 Norwood, MA 02062 #: 25406165 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Castle Island Brewing Co., LLC 31 Astor Avenue Norwood, MA 02062 #: 25404620 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Central Dental Associates 470 Washington Street Suite 1 Norwood, MA 02062 #: 25406154 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Courtyard By Marriott - Norwood 300 River Ridge Drive Norwood, MA 02062 #: 25101857 Category: 02	0101	DISCHARGE PIPE AT THE FLOOR TRENCH			No Discharge Violations		02-Aug-2023	Notice of Noncompliance
		Semi-Annual Self-Monitoring Oil and Grease pH						
Dana L. Mandel DMD 63 Broadway Norwood, MA 02062 #: 25406155 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
E.I.C. Laboratories, Inc. 111 Downey Street Norwood, MA 02062 #: 25003019 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Epic Family Dentistry, PLLC dba Epic Dental 315 Norwood Park South Suite 100 Norwood, MA 02062 #: 25409299 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Four Points Hotel and Conference Center 1125 Boston-Providence Turnpike Norwood, MA 02062 #: 25006130 Category: 02	0201	Laundry wastewater			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Oil and Grease pH						
Gentle Dental Norwood 980 Providence Highway Norwood, MA 02062 #: 25406166 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ingleside Corporation dba The Corporate Press 89 Access Road Unit 17 Norwood, MA 02062 #: 25100236 Category: G1	0101	LINE FROM MSII TO DRAIN			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Silver (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Kaceli Dental Studio, LLC 661 Washington Street Unit 211 Norwood, MA 02062 #: 25406159 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Landmark Dental 77 Access Road Suite 1 Norwood, MA 02062 #: 25406163 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Laura E. Sullivan DMD, PC 56 Walpole Street Norwood, MA 02062 #: 25409296 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Modern Testing Services LLC 349 Lenox Street Norwood, MA 02062 #: 25405072 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Moderna Therapeutics, Inc. 1 Moderna Way Norwood, MA 02062 #: 25405498 Category: 02					No Discharge Violations			07-Jul-2023 Notice of Violation
	0101	Wastewater from vaccine manufacturing in MTC-South						
	Quarterly	Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0102	Wastewater from vaccine manufacturing in MTC-South Building						
	Quarterly	Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0202	Wastewater from MTC-North Building						
	Annual	Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions	
		Lead (Total)							
		Mercury (Total)							
		TTO (Extractable Organic Fraction)							
		TTO (Volatile Organic Fraction)							
		Zinc (Total)							
		pH							
	0203	Laboratory wastewater from MTC-North Building							
		Semi-Annual Self-Monitoring							
		Copper (Total)							
		Cyanide (Total)							
		Lead (Total)							
		Mercury (Total)							
		TTO (Extractable Organic Fraction)							
		TTO (Volatile Organic Fraction)							
		Zinc (Total)							
		pH							
	0301	Wastewater from Quality Control and Fill/Finish process lines in MTC-East							
		Semi-Annual Self-Monitoring							
		Copper (Total)							
		Lead (Total)							
		Mercury (Total)							
		TTO (Extractable Organic Fraction)							
		TTO (Volatile Organic Fraction)							
		Zinc (Total)							
		pH							
	Mystic Scenic Studios, Inc. 293 Lenox Street Norwood, MA 02062 #: 25405323 Category: 02	0101	Waterjet effluent after cascading weir				No Discharge Violations		No Enforcement Actions
			Semi-Annual Self-Monitoring						
		Chromium (Total)							
		Copper (Total)							
		Nickel (Total)							
	Zinc (Total)								
	pH								
Neponset River LLC fka FM Global Research Corporation 1 Technology Way Norwood, MA 02062 #: 25103383 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
New England Dental Specialists of Norwood 24 Guild Street Norwood, MA 02062 #: 25409297 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
Norwood Dental Care 47 Central Street Norwood, MA 02062 #: 25406153 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Norwood Dental Center PC 1242 Washington Street Norwood, MA 02062 #: 25406150 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Norwood Family Dental 117 Broadway Norwood, MA 02062 #: 25409298 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Norwood Hospitality, LLC 434 Providence Highway Norwood, MA 02062 #: 25101808 Category: 02	0101	Floor trench behind the washing machines			No Discharge Violations		11-Oct-2023 Penalty Assessment Notice 11-Oct-2023 Administrative Order 20-Feb-2024 Demand Letter 14-May-2024 Returned to Permit Letter 25-Jun-2024 Administrative Settlement	
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						
Olympic Adhesives, Inc. 670 Canton Street Norwood, MA 02062 #: 25005440 Category: 02	0101	discharge pipe in floortrench			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring TTO (Extractable Organic Fraction) pH						
PVG One Hospitality Inc dba Holiday Inn Express 225 Norwood Park S Norwood, MA 02062 #: 25409942 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pediatric & Family Dentistry of Norwood & Endodontic Care 761 Washington Street Floor 1 Norwood, MA 02062 #: 25406162 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Prize Possessions 340 -R Vanderbilt Avenue Norwood, MA 02062 #: 25405449 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Siemens Healthcare Diagnostics, Inc. 2 Edgewater Drive Norwood, MA 02062 #: 25103309 Category: 10		No Reporting Requirements			No Discharge Violations		14-Sep-2023 Notice of Noncompliance	
Taylor Freezer of New England, Inc. 1030 University Avenue Norwood, MA 02062 #: 25405213 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
The Regal Press, Inc. 79 Astor Avenue Norwood, MA 02062 #: 25003884 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
A-Best Enterprises & Portable Toilets, Inc. 267 N Quincy Street Abington, MA 02351 #: 00103251 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
B.N.V. Enterprises, Inc. dba Rooter-Man 48 Sullivan Road Billerica, MA 01862 #: 00100409 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bateson Enterprises Inc. 111 Argilla Road Andover, MA 01810 #: 00409886 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Claude Dubord & Son Inc. 45 Mae Avenue Bridgewater, MA 02324 #: 00100376 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
J. Hockman Inc. 11 Sherwood Drive Norfolk, MA 02056 #: 00409909 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John Zanni Pumping Co., Inc. 5 Hallberg Park North Reading, MA 01864 #: 00100394 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Miles of Excavating 242 Park Street Wrentham, MA 02093 #: 00404013 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
T Horn Pumping Services Inc. dba Stoughton Pumping Service 46 Plain Street E Berkley, MA 02779 #: 00101305 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tewksbury Sewer Service, Inc. 95 Helvetia Street Tewksbury, MA 01876 #: 00100414 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Adams Family Dental 953 Hancock Street Quincy, MA 02170 #: 26406186 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Advanced Dental Arts of Quincy 1250 Hancock Street Suite 123 S Quincy, MA 02169 #: 26406173 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alfredo Aiello Italian Foods, Inc. 122 Water Street Quincy, MA 02169 #: 26001284 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alliance Dental Center, LLC 111 Washington Street Suite 301 Quincy, MA 02169 #: 26409395 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Dental Quincy 688 Hancock Street Quincy, MA 02170 #: 26406201 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aspen Dental 45 Newport Avenue Quincy, MA 02171 #: 26406191 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 1250 Hancock Street Quincy, MA 02169 #: 26102436 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Scientific 500 Commander Shea Boulevard Quincy, MA 02169 #: 26103145 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Coddington Dental 17 Whitney Road Quincy, MA 02169 #: 26407846 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Comprehensive Dental Care 1261 Furnace Brook Parkway Suite 16 Quincy, MA 02169 #: 26405891 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Core Dental LLC 1400 Hancock Street Unit C Quincy, MA 02169 #: 26406198 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Courtney Sanders Knapik, DMD, P.C. 350 Hancock Street Quincy, MA 02171 #: 26407844 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Crown Dental Group 500 Congress Street Suite 3E Quincy, MA 02169 #: 26406193 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Daniel J Madden DMD 1073 Hancock Street Suite 205 Quincy, MA 02169 #: 26406167 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Associates Inc 300 Crown Colony Drive Suite 301 Quincy, MA 02169 #: 26406199 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Dental of Quincy, PC 101 Falls Boulevard Quincy, MA 02169 #: 26409232 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Excel Family Dental PC 1261 Furnace Brook Parkway Suite 24 Quincy, MA 02169 #: 26406175 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
G & L Labs, Inc. 246 Arlington Street Quincy, MA 02170 #: 26405427 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
General Dynamics Mission Systems, Inc. - Bluefin Robotics 553 South Street Quincy, MA 02169 #: 26404987 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Quincy 1530 Hancock Street Quincy, MA 02169 #: 26408706 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Giri Quincy Restaurant Services dba Best Western Adams Inn 29 Hancock Street Quincy, MA 02171 #: 26101809 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Howard Lau, DMD PC 14 Federal Avenue Quincy, MA 02169 #: 26406179 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Huali Fish House Boston Inc 206 Ricciuti Drive Quincy, MA 02169 #: 26409158 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
JF Dental 700 Congress Street Suite 304 Quincy, MA 02169 #: 26406189 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John Ictech-Cassis-Sandra Morin 1372 Hancock Street Suite 204 Quincy, MA 02169 #: 26406178 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lumiere Dental Spa 495 Sea Street Quincy, MA 02169 #: 26406192 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Marina Bay Dental Associates PC 308 Victory Road North Quincy, MA 02171 #: 26406146 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MaryAnne Del Cupolo DDS 21 Franklin Street Quincy, MA 02169 #: 26406183 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nankin Dental Associates Inc 500 Congress Street Suite 2D Quincy, MA 02169 #: 26406194 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Panacea Wellness 216 Ricciuti Drive Quincy, MA 02169 #: 26405232 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Paul H. Murphy & Company, Inc. 634 Willard Street Quincy, MA 02169 #: 26102740 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pelly Chang DMD PC 166 Willard Street Quincy, MA 02169 #: 26406182 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Purity Cheese Company 206 Ricciuti Drive Quincy, MA 02169 #: 26101969 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quincy Center For Endodontics 234 Copeland Street Suite 310 Quincy, MA 02169 #: 26409350 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quincy Dental 875 Southern Artery Quincy, MA 02169 #: 26406204 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quincy Dental Associates 234 Copeland Street Suite 330 Quincy, MA 02169 #: 26406185 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quincy Dental Specialists Group 580 Hancock Street Quincy, MA 02170 #: 26406196 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quincy Dentists 79 Elm Street Quincy, MA 02169 #: 26406203 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quincy Endodontics 67 Coddington Street Suite 102 Quincy, MA 02169 #: 26407850 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert William Ryan DDS Inc 1229 Hancock Street Quincy, MA 02169 #: 26406172 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Shabazian Family Dental 157 Washington Street Quincy, MA 02169 #: 26406180 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sobo Dental 111 Willard Street Suite 1-A, 1-B Quincy, MA 02169 #: 26406169 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Cove Community Health Center 88 Holmes Street Quincy, MA 02171 #: 26406205 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Street Dental 276 South Street Quincy, MA 02169 #: 26406187 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Suburban Dialysis Center (#1610) 241 Parkingway Quincy, MA 02169 #: 26007484 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Spring Dental 440 Hancock Street Suite 205 North Quincy, MA 02171 #: 26407847 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Staybridge Suites/Holiday Inn Express 1 Richard A. Stratton Way Quincy, MA 02171 #: 26407788 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Stella Bondar, DMD 1261 Furnace Brook Parkway Suite 27 Quincy, MA 02169 #: 26407845 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Stephen MacDonald DMD 770 Hancock Street Quincy, MA 02170 #: 26406202 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Stephen Matarrazzo DMD 300 Crown Colony Drive Quincy, MA 02169 #: 26406188 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Sunbelt Rentals 153 Brook Road Quincy, MA 02169 #: 26405388 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Taiyo Seafood Boston, Inc. 256 Arlington Street Quincy, MA 02170 #: 26405425 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Temple Family Dentistry 1261 Furnace Brook Parkway Suite 12 Quincy, MA 02169 #: 26406174 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
US Renal Care Quincy Dialysis 500 Victory Road Quincy, MA 02171 #: 26405118 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
USAPhil Dental Health Care II 52 Greenleaf Street Quincy, MA 02169 #: 26406195 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wollaston Dental Group 628 Hancock Street Quincy, MA 02170 #: 26406327 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aqua Dental LLC 1395 North Main Street Randolph, MA 02368 #: 27406213 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Comfort Inn 1374 North Main Street Randolph, MA 02368 #: 27103560 Category: 02	0101 One Time	Discharge line receiving laundry wastewater Self-Monitoring PFAS Pollutant Group pH Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH	0101 16-Feb-2024	Discharge line receiving laundry wastewater pH	4.41	S.U. Grab/ Ph	> 5.5	28- Nov-2023 Notice of Violation 09-Feb-2024 Notice of Violation 11-Mar-2024 Notice of Violation
Dental Specialties Inc 950 North Main Street Randolph, MA 02368 #: 27406217 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Elite Envelope & Graphics, Inc. 280 Pond Street Randolph, MA 02368 #: 27102306 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Evoqua Water Technologies, LLC 49 York Avenue Randolph, MA 02368 #: 27403177 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fowler Printing & Graphics ,Inc. 132 York Avenue Randolph, MA 02368 #: 27007381 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Frito Lay Inc. dba Stacy's Pita Chip Company 663 North Street Randolph, MA 02368 #: 27103381 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Holiday Inn Express & Suites Boston South-Randolph Hotel 60 Mazzeo Drive Randolph, MA 02368 #: 27407670 Category: 02	0101	Process wastewater from laundry operation.			No Discharge Violations		06-Jul-2023 Notice of Noncompliance 30-Apr-2024 Notice of Violation	
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						
Jimmy Lai DMD PC 10 Mazzeo Drive Suite 209 Randolph, MA 02368 #: 27406207 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
LION TotalCare, Inc. 40 -B Teed Drive Randolph, MA 02368 #: 27405382 Category: 02	0101	Laundry effluent from trough			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Oil and Grease Oil and Grease PFAS Pollutant Group TTO (Volatile Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) Zinc (Total) pH pH						
Melmar Inc 296 North Street Randolph, MA 02368 #: 27101094 Category: 02	0101	Washing machine effluent.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						
Melville Candy Company 28 York Avenue Randolph, MA 02368 #: 27405295 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Progressive Marble Fabrication, Inc. 43 York Avenue Randolph, MA 02368 #: 27007222 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Randolph Dental Group 96 North Main Street Randolph, MA 02368 #: 27406214 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Randolph Dental Smile, PLLC 89 South Main Street Randolph, MA 02368 #: 27406216 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Randolph Engineering Inc. 26 Thomas Patten Drive Randolph, MA 02368 #: 27101001 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Randolph Family Dentistry PC 56 South Main Street Randolph, MA 02368 #: 27406215 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sharri Trilling DMD 1093 North Main Street Randolph, MA 02368 #: 27406209 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Simply Orthodontics & Pediatric Dentistry 15 Warren Street Randolph, MA 02368 #: 27409308 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Trans Dental Care, Inc. 1062 North Main Street Randolph, MA 02368 #: 27406208 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Ultrafiltronics, Ltd. 91 York Avenue Randolph, MA 02368 #: 27102497 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Family Dental Associates 636 Main Street Reading, MA 01867 #: 28406226 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
First Dental Associates 274 Main Street Reading, MA 01867 #: 28406225 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kallen K Hull DMD PC 274 Main Street Suite 205 Reading, MA 01867 #: 28406224 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lisa Vouras DMD, PC 85 Woburn Street Reading, MA 01867 #: 28406252 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MA Dental Care 2 Haven Street Suite 303 Reading, MA 01867 #: 28406220 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Radiance Dental 161 Ash Street Suite C Reading, MA 01867 #: 28406218 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ravens Family Dental 198 Ash Street Reading, MA 01867 #: 28406219 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Reading Dental 270 Main Street Reading, MA 01867 #: 28406223 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Susan E. Fitzgerald DMD 246 Woburn Street Reading, MA 01867 #: 28406222 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Walker's Brook Crossing, LLC, c/o Wilder Companies Walkers Brook Drive Reading, MA 01867 #: 28103125 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Winchester & Reading Pediatric Dentistry LLC 54 Haven Street Reading, MA 01867 #: 28406221 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Annese DMD LLC 106 Broadway Revere, MA 02151 #: 29406229 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bao Min Yee, DMD PC 49 Shirley Avenue Revere, MA 02151 #: 29406239 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Becker Becker & Silvius LLC 34 Shirley Avenue Revere, MA 02151 #: 29406237 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Benecchi Dental Group 140 School Street Revere, MA 02151 #: 29406232 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boschetti Dental One Orr Square Revere, MA 02151 #: 29406228 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DVI 407 Squire Road LLC dba Boston Logan Four Points 407 Squire Road Revere, MA 02151 #: 29101880 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Dental of Revere, PC 339 Squire Road Revere, MA 02151 #: 29409233 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ernest F Powers Jr DMD 276 Squire Road Revere, MA 02151 #: 29406235 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Louis Devito Jr DMD 50 Squire Road Revere, MA 02151 #: 29406244 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
My Dental Revere 334 Broadway Revere, MA 02151 #: 29406236 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Olufemi A. Oguntolu DMD PC 252 Squire Road Revere, MA 02151 #: 29406233 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Page Family Dental LLC 26 Central Avenue Revere, MA 02151 #: 29406234 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Park Avenue Dental Associates 500 Park Avenue Revere, MA 02151 #: 29406240 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Revere Dentistry and Braces 370 Broadway Revere, MA 02151 #: 29409317 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Revere Pediatric Dentistry 11 Vinal Street Revere, MA 02151 #: 29406230 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Trubright Dental 651 Squire Road Revere, MA 02151 #: 29406243 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Collaborative 4452 Washington Street Roslindale, MA 02131 #: 53406246 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gourmet Caterers Inc. 3867 Washington Street Roslindale, MA 02131 #: 53001789 Category: 02	0101	Spigot on discharge piping from lift station			No Discharge Violations		18-Aug-2023	Notice of Violation
		Semi-Annual Self-Monitoring Oil and Grease Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Harvard University - Weld Hill Research Facility 1300 Centre Street Roslindale, MA 02131 #: 53403347 Category: 02	0101	Laboratory and greenhouse wastewater after neutralization			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Formaldehyde Pesticides TTO (Volatile Organic Fraction) Zinc (Total) pH						
Perfect Dental Roslindale 644 American Legion Highway Roslindale, MA 02131 #: 53406247 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Puritan Ice Cream Company 3895 Washington Street Roslindale, MA 02131 #: 53001683 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard F.X. Spagnuolo 1048 South Street Roslindale, MA 02131 #: 53406245 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smiley Dental Roslindale 954 American Legion Highway Roslindale, MA 02131 #: 53407541 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Unity Dental 4172 Washington Street Roslindale, MA 02131 #: 53409498 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
AB Seafood LLC 20 Newmarket Square Roxbury, MA 02118 #: 54404109 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Biomedical Applications of Roxbury 416 Warren Street Roxbury, MA 02119 #: 54101168 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bon Me Foods 148 Hampden Street Roxbury, MA 02119 #: 54404174 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Boston Police Headquarters (City Of Boston) 1 Schroeder Plaza Roxbury, MA 02120 #: 54101319 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bully Boy Distillers, LLC 35 Cedric Street Roxbury, MA 02119 #: 54403457 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
City Fresh Foods, Inc. 77 Shirley Street Roxbury, MA 02119 #: 54403667 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cortland Dental & Braces_Roxbury Facility 2181 Washington Street Suite 101 Roxbury, MA 02119 #: 54406250 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Dreams LLC 3033 Washington Street Roxbury, MA 02119 #: 54406254 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Diablo Glass School 123 Terrace Street Roxbury, MA 02120 #: 54403885 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dimock Community Health Center 45 Dimock Street Floor 3 Roxbury, MA 02119 #: 54406255 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mass Wholesale Food Terminal Condo Trust 140 Newmarket Square Roxbury, MA 02118 #: 54004419 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Morgan Services, Inc. 941 Massachusetts Avenue Roxbury, MA 02118 #: 54004499 Category: 02	0101 Quarterly	8 INCH PALMER BOWLUS FLUME Self-Monitoring Oil and Grease Zinc (Total) pH TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)			No Discharge Violations		22-Feb-2024	Notice of Noncompliance

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Roxbury Dental @Dudley 156 Dudley Street Roxbury, MA 02119 #: 54406249 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Shanghai Ravioli Corporation 25 Howard Street Roxbury, MA 02119 #: 54103466 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Southampton Wholesale Food Terminal 80 -88 Newmarket Square Roxbury, MA 02118 #: 54004548 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Steve Connolly Seafood Company, Inc. 34 Newmarket Square Roxbury, MA 02118 #: 54007642 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
599 Somerville Ventures LLC & Shawmut Design & Construction 599 Somerville Avenue Somerville, MA 02143 #: 30409384 Category: 12	0101	Stormwater catch basin located on Somerville Ave.			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring						
		Arsenic (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB's						
		Pesticides						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						
	0102	Stormwater catch basin located on Spring St.						
	Monthly	Self-Monitoring						
		Arsenic (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		PCB's						
		Pesticides						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		pH						
74M Property Owner, LLC 74 Middlesex Avenue Somerville, MA 02145 #: 30409916 Category: 02	0101	spigot(s) located on discharge line of pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring						
		Antimony (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Aeronaut Brewing Company 14 Tyler Street Somerville, MA 02143 #: 30404392 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alpha Dental 701 Broadway Somerville, MA 02144 #: 30406278 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Anthony P Parrella DMD 102 College Avenue Somerville, MA 02144 #: 30406256 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health 40 Holland Street Somerville, MA 02144 #: 30102777 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brickbottom I QOZB, LP 100 Chestnut Street Somerville, MA 02143 #: 30409678 Category: 02	0101	Process wastewater from R&D laboratory operations after pH adjustment system.			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Volatile Organic Fraction) Zinc (Total) pH						
Brickbottom QOZB LP and Consigli Construction Company, Inc. 28 Chestnut Street Somerville, MA 02143 #: 30409082 Category: 12	0101	Catch basin 001 located on corner of Fitchburg St. and Chestnut St.			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	Catch basin 002 located at 28 Chestnut St. east side of site						
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
Bright Dental 435 Washington Street Suite 97B Somerville, MA 02143 #: 30406271 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridge Health Alliance - Somerville Campus 230 Highland Avenue Somerville, MA 02143 #: 30006648 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
City of Somerville (SHSS Project) and P. Gioioso & Sons Inc. Somerville Avenue Somerville, MA 02143 #: 30409380 Category: 12	0101	Somerville manhole located at intersection of Somerville Avenue and Poplar Street			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Volatile Organic Fraction) Total Suspended Solids pH						
City of Somerville / Barletta Heavy Division, Inc 93 Highland Street Somerville, MA 02143 #: 30406710 Category: 12	0106 Monthly	Manhole located on Somerville Ave Extension; near 216 McGrath Highway Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TSS_ONLY Group TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH			No Discharge Violations			No Enforcement Actions
Corp.#10408875 U.S. Inc. dba nPlexBio 15 Ward Street Somerville, MA 02143 #: 30409292 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Davis Square Dental 67 Holland Street Somerville, MA 02144 #: 30406273 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Deano's Pastacia Inc. 15 Garfield Avenue Somerville, MA 02145 #: 30404538 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Arts Davis Square 396 Highland Avenue Somerville, MA 02144 #: 30406269 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentplant 281 Broadway Somerville, MA 02145 #: 30406265 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dialysis Clinic Inc. - Somerville 643 Broadway Somerville, MA 02145 #: 30101768 Category: 10		No Reporting Requirements			No Discharge Violations		30-Nov-2023	Notice of Noncompliance

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Finch Therapeutics, Inc. 200 Innerbelt Road Somerville, MA 02143 #: 30404858 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Form Energy Inc. 200 Inner Belt Road Somerville, MA 02143 #: 30409859 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Formlabs Inc. 35 Medford Street Suite 301 Somerville, MA 02143 #: 30406785 Category: 10		No Reporting Requirements			No Discharge Violations		05-Feb-2024	Notice of Noncompliance
Gentle Dental Somerville 14 McGrath Highway Somerville, MA 02143 #: 30406260 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Great Hill Dental Somerville 20 Holland Street Suite 400 Somerville, MA 02144 #: 30406264 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvard University - Harvard Art Museums - Somerville 200 Inner Belt Road Somerville, MA 02143 #: 30403337 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hemlock Ink 19 Properzi Way Somerville, MA 02143 #: 30404399 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Highland Dental Associates 366 Broadway Suite 202 Somerville, MA 02145 #: 30406268 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Julian Basha DMD PLLC 36 Bow Street Somerville, MA 02143 #: 30406267 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kappa Dental Group 402 Washington Street Somerville, MA 02143 #: 30406270 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Langs Dental Center 593 McGrath Highway Somerville, MA 02145 #: 30406276 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lina Al-Aswad DDS 1133 Broadway Somerville, MA 02144 #: 30406257 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lorna Lally DMD 109 College Avenue Somerville, MA 02144 #: 30406275 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
M. Catherine Talmo, DMD, PC 180 Highland Avenue Somerville, MA 02143 #: 30406263 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
North Star Rental Systems / Universal Laundry, Inc. 43 Fremont Street Somerville, MA 02145 #: 30002736 Category: 02	0101 Quarterly	Laundry effluent from 8 inch Palmer Bowlus flume Self-Monitoring Oil and Grease TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions
Perfect Dental Somerville 128 Broadway Somerville, MA 02145 #: 30406259 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Rogers Foam Corporation 20 Vernon Street Somerville, MA 02145 #: 30002306 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sandra Tranfaglia DMD PC 17 Washington Street Somerville, MA 02143 #: 30406261 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Silicon PropCo 2021, LLC 101 South Street Somerville, MA 02143 #: 30409004 Category: 02	0101 Semi-Annual Self-Monitoring	Laboratory wastewater after pH neutralization system. Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Zinc (Total) pH						
Smiles Over Somerville 474 Broadway Suite 110 Somerville, MA 02145 #: 30406272 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Smiles by Rosie Family Dentistry 6 Kensington Avenue Somerville, MA 02145 #: 30406277 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Somerville Family Dental 365 Somerville Avenue Somerville, MA 02143 #: 30406274 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Somerville First Dental 622 Somerville Avenue Somerville, MA 02143 #: 30409390 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Spring Hill Dental 174 Highland Avenue Unit 1 Somerville, MA 02143 #: 30406262 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sublime Systems, Inc. 14 Park Street Somerville, MA 02143 #: 30409554 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sublime Systems, Inc. 28 Park Street Somerville, MA 02143 #: 30409865 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Taza Chocolate 561 Windsor Street Somerville, MA 02143 #: 30404337 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Braces Place & T-Station Dental 30 College Avenue Somerville, MA 02144 #: 30407940 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
West Somerville Dental 124 College Avenue Somerville, MA 02144 #: 30406258 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
105 W First Street Owner, LLC 105 W First Street South Boston, MA 02127 #: 55409278 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ARE-MA Region No.74, LLC. 15 Necco Street South Boston, MA 02110 #: 55409915 Category: 02	0101	Sample spigots on the discharge line of the pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Adams-Chapman Co. - FB Packing Co 9 -15 Foodmart Road South Boston, MA 02118 #: 55102995 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Amplitude Vascular Systems, Inc. 451 D Street South Boston, MA 02210 #: 55409858 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Avedot 270 LLC 270 Dorchester Avenue South Boston, MA 02127 #: 55408197 Category: 12	0101	Catch basin located on B Street, near the intersection with W. 6th Street			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	Catch basin located on B Street, near the intersection with W. 7th Street						
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0201	Catch basin located W. 6th Street, near the intersection with B Street						
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
BGP-CG Harbor Property, LLC 2 Harbor Street South Boston, MA 02210 #: 55409877 Category: 02	0101	Sample ports on the pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Boston Sword & Tuna, Inc. 10 Codfish Way South Boston, MA 02210 #: 55103160 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Campco 41 Foodmart Road South Boston, MA 02118 #: 55102997 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cape Cod Shellfish Seafood/Boston Seafood Express 8 Seafood Way South Boston, MA 02210 #: 55408092 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Catamaran Bio, Inc. 451 D Street Suite Flr5-500 South Boston, MA 02210 #: 55409387 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Commercial Lobster Co. 300 Northern Avenue South Boston, MA 02210 #: 55403751 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Constitution Seafoods, Inc. 8 Seafood Way South Boston, MA 02210 #: 55103161 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dana-Farber Cancer Institute 27 Drydock Avenue South Boston, MA 02210 #: 55403136 Category: 02	0101	Sampling spigots located after pH neutralization system			No Discharge Violations		21-Aug-2023	Notice of Violation
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		Zinc (Total)						
		pH						
Emulate, Inc. 27 Drydock Avenue Floor 5 South Boston, MA 02210 #: 55404479 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
F. B. Packing 1 -3 Foodmart Road South Boston, MA 02118 #: 55102998 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Flour Bakery 1 Design Center Place Suite 17-130E South Boston, MA 02210 #: 55404693 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Frank Bertolino Beef 45 -51 Foodmart Road South Boston, MA 02118 #: 55103006 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
GI ETS Fort Point I LLC 51 Melcher Street Boston, MA 02210 #: 55409928 Category: 02	0101	Sample spigots on the discharge line of the pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Gentle Dental South Boston 368 A West Broadway South Boston, MA 02127 #: 55406282 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ginkgo BioWorks 27 Drydock Avenue Floor 8 South Boston, MA 02210 #: 55403380 Category: 02	0101	Lab sink effluent			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0102	Washer effluent						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0103	Autoclave effluent						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0104	Op-Co effluent						
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Molybdenum						
		Nickel (Total)						
		Oil and Grease						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Grab & Go LLC 28 Damrell Street South Boston, MA 02127 #: 55405327 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
GrandTen Distilling 383 Dorchester Avenue South Boston, MA 02127 #: 55404342 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Haemonetics Corporation 125 Summer Street Floor 16 South Boston, MA 02110 #: 55005543 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
IDB 21-25 Drydock Limited Partnership 21 Drydock Avenue Suite 330E South Boston, MA 02210 #: 55409376 Category: 02	0101	Laboratory wastewater to 25-G1 pH neutralization system			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0102	Laboratory wastewater to 23 pH neutralization system						
	Semi-Annual	Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0103	Laboratory wastewater to 21 pH neutralization system						
	Semi-Annual	Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Inozyme Pharma 451 D Street Floor 9 South Boston, MA 02210 #: 55408663 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jnana Therapeutics 6 Tide Street Suite 301 South Boston, MA 02210 #: 55408336 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John Nagle Company 306 Northern Avenue South Boston, MA 02210 #: 55403500 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John P. Pow Company, Inc. 49 D Street South Boston, MA 02127 #: 55004446 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Karas & Karas Glass Company, Inc. 455 Dorchester Avenue South Boston, MA 02127 #: 55002245 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
KeraFast, Inc. 21 Drydock Avenue Floor 7 South Boston, MA 02210 #: 55403859 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Living Proof, Inc. 17 Drydock Avenue Floor 6 South Boston, MA 02210 #: 55103397 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lucky River Transportation Corp. 38 - 48 Damrell Street South Boston, MA 02127 #: 55403873 Category: 02	0101	Standpipe on the discharge line after the oil/water separator			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Nickel (Total) Oil and Grease Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Marriott Residence Inn Seaport 368 Congress Street South Boston, MA 02210 #: 55403594 Category: 02	0101	Effluent from laundry operations			No Discharge Violations		14-Aug-2023	Notice of Violation
	Semi-Annual	Self-Monitoring Oil and Grease Zinc (Total) pH						
Mass Innovation Labs dba SmartLabs 6 Tide Street South Boston, MA 02210 #: 55407805 Category: 02	0101	Lab wastewater from first floor neutralization system #1			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH Copper (Total) Formaldehyde Lead (Total) Mercury (Total) PFAS Pollutant Group TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0102	Lab wastewater from second floor neutralization system #2						
	Semi-Annual	Self-Monitoring Copper (Total) Formaldehyde Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0103	Lab wastewater from third floor neutralization system #3						
	Semi-Annual	Self-Monitoring Copper (Total) Formaldehyde Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Metropolitan Meat Company 1 Widett Circle South Boston, MA 02118 #: 55103088 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Michael F Arcieri DMD Inc 590 East Broadway South Boston, MA 02127 #: 55406286 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mytide Therapeutics, Inc. 451 D Street Suite 707 South Boston, MA 02210 #: 55407702 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nan Fung Life Sciences Real Estate (S.Bos) 51 Sleeper Street South Boston, MA 02210 #: 55409076 Category: 02	0101	Spigot on discharge line of pH neutralization tank			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Chromium (Total) Copper (Total) Formaldehyde Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
New Boston Seafood Center, Inc. 310 -312 Northern Avenue South Boston, MA 02210 #: 55101981 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
North Coast Seafoods 270 West First Street South Boston, MA 02127 #: 55103360 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
OPG MP Parcel Owner (DE), LLC 645 Summer Street Boston, MA 02210 #: 55406792 Category: 02	0101	Central pH neutralization system Lab effluent.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Chromium (Total) Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
ORIG3N 27 Drydock Avenue Floor 3 South Boston, MA 02210 #: 55404469 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Osorio Dental Group DMD, PC, dba South Boston Dental Group 9 Channel Center Street Boston, MA 02210 #: 55406281 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pacific American Fish Company, Inc. 8 Seafood Way South Boston, MA 02210 #: 55103159 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
PureTech Health 6 Tide Street South Boston, MA 02210 #: 55407145 Category: 02	0101	Lab wastewater from the 3rd and 4th floor suites to the neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		PFAS Pollutant Group						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Puritan Foods Company, Inc. 17 Foodmart Road South Boston, MA 02118 #: 55103003 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Roivant Discovery, Inc. 451 D Street Suite 205 South Boston, MA 02210 #: 55406597 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
SG Technology Excellence Center US, Inc. 451 D Street Suite 704 South Boston, MA 02210 #: 55408179 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Samuel Holmes Inc. 25 Foodmart Road South Boston, MA 02118 #: 55102996 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sea-Cap, Inc. 8 Seafood Way South Boston, MA 02210 #: 55103162 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Seaport Dental Associates 451 D Street Suite 200 South Boston, MA 02210 #: 55407223 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Shaughnessy RE LLC 295 W First Street South Boston, MA 02127 #: 55103643 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Boston Community Health Center 386 West Broadway South Boston, MA 02127 #: 55406284 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Boston Family Dental 591 East Broadway South Boston, MA 02127 #: 55406287 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Stavis Seafoods LLC 1 Seafood Way South Boston, MA 02210 #: 55409084 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Transform Mary Ellen McCormack, LLC & Lee Kennedy Company 11 Devine Way South Boston, MA 02127 #: 55409932 Category: 12	0101 Monthly	spigots on discharge line of treatment system Self-Monitoring Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Lead (Total) Mercury (Total) Nickel (Total) Oil and Grease PCB's Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
True World Foods Boston LLC 22 Foodmart Road South Boston, MA #: 55103002 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
U.S. Postal Service 25 Dorchester Avenue South Boston, MA 02205 #: 55101900 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Vertex Pharmaceuticals Inc. 50 Northern Avenue South Boston, MA 02210 #: 55404203 Category: 02	0101	Sample Spigot on Discharge Piping from pH Neutralization	No Discharge Violations				No Enforcement Actions	
	Semi-Annual Self-Monitoring	Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0201	Sampling Spigot on Discharge Piping from pH Neutralization						
	Semi-Annual Self-Monitoring	Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Vertex Pharmaceuticals Inc. 316 -318 Northern Avenue South Boston, MA 02210 #: 55409223 Category: 02	0101	Wastewater from R&DLaboratories	No Discharge Violations				No Enforcement Actions	
	Semi-Annual Self-Monitoring	Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Watermark Donut Company 370 Dorchester Avenue South Boston, MA 02127 #: 55404705 Category: G2	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
West Broadway Family Dental 385 West Broadway South Boston, MA 02127 #: 55406283 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
William Eaves DMD 216 Dorchester Street South Boston, MA 02127 #: 55406280 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Yotel Boston 65 Seaport Boulevard South Boston, MA 02210 #: 55407736 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Charles W Malta DDS (Stoneham) 158 Main Street Stoneham, MA 02180 #: 31406303 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Bruce Doyle DMD 74 Main Street Stoneham, MA 02180 #: 31406330 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Ray Rezanian 271 Main Street Suite G02 Stoneham, MA 02180 #: 31407458 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Drs Pizzarello & Silvestro Family Dentistry 546 Main Street Stoneham, MA 02180 #: 31406306 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
LPI Printing & Graphics, Inc. 18 Spencer Street Stoneham, MA 02180 #: 31405008 Category: G1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lund Dental Associates LLC 2 Main Street Suite 225 Stoneham, MA 02180 #: 31406304 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Michael Stangler, DDS 114 Central Street Stoneham, MA 02180 #: 31406302 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----			Limit	-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result		Date	Actions
Nandhavan Dental PLLC 106 Main Street Suite 5 Stoneham, MA 02180 #: 31409325 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Northshore Family Dentistry 3 Woodland Road Suite 417 Stoneham, MA 02180 #: 31406305 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
R J Wu & Associates 61 Main Street Stoneham, MA 02180 #: 31406307 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Redstone Dental Center 70 Main Street Stoneham, MA 02180 #: 31406329 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert L. Roy DDS 61 Main Street Stoneham, MA 02180 #: 31406308 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Stoneham Dental Care 112 Main Street Stoneham, MA 02180 #: 31406300 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
All Seasons Septic Service Inc. 200 Cushing Street Suite 7 Stoughton, MA 02072 #: 32101571 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alpha Chemical Services, Inc. 46 Morton Street Stoughton, MA 02072 #: 32005051 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alright Dental 684 Washington Street Stoughton, MA 02072 #: 32409303 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Avon Food Company LLC 220 Canton Street Stoughton, MA 02072 #: 32103304 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Crescent Ridge Dairy, Inc. 355 Bay Road Sharon, MA 02067 #: 32408781 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dayspring Dental Solutions 1819 Central Street Stoughton, MA 02072 #: 32409302 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentistry on Park LLC 19 Park Street Stoughton, MA 02072 #: 32406334 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Matthew Finkelstein, DMD dba Cobb Corner Dental 36 Bay Road Stoughton, MA 02072 #: 32409301 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Endodontic Center PC 1256 Park Street Suite 203 Stoughton, MA 02072 #: 32409305 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Endontic Health, PC 839 Washington Street Stoughton, MA 02072 #: 32406341 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
First Impression Printing, Inc. 178 Tosca Drive Stoughton, MA 02072 #: 32102361 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Stoughton 341 Washington Street Stoughton, MA 02072 #: 32406335 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gerald M. Winkler DMD PC 4 Cabot Place Suite 8 Stoughton, MA 02072 #: 32406337 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kid Care Dental PC 1613 Central Street Stoughton, MA 02072 #: 32406333 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Marver Med, Inc. 1063 Turnpike Street Stoughton, MA 02072 #: 32103702 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Massachusetts Bay Technologies (MBT) 378 Page Street Building 7 Stoughton, MA 02072 #: 32403434 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Park Dental Group, PC 480 Park Street Stoughton, MA 02072 #: 32406339 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Plain Street Water Treatment Plant 742 Plain Street Stoughton, MA 02072 #: 32406522 Category: 02	0101	Water treatment plant residuals			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Volatile Organic Fraction) Total Suspended Solids Zinc (Total) pH Antimony (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) TTO (Volatile Organic Fraction) Total Suspended Solids Zinc (Total) pH						
Primo Medical Group 75 Mill Street Stoughton, MA 02072 #: 32100111 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Seth M Roth DMD 450 Pearl Street Stoughton, MA 02072 #: 32406338 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sonesta Select -Stoughton Lodging 200 Technology Center Drive Stoughton, MA 02072 #: 32405319 Category: 02	0101 Trough behind washing machines				No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Copper (Total) Oil and Grease pH						
Stoughton Dentistry 35 Park Street Stoughton, MA 02072 #: 32406336 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Stoughton Family Dental 1255 Central Street Stoughton, MA 02072 #: 32406332 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
TeamstersCare Dental Local 25 1214 Park Street Stoughton, MA 02072 #: 32406331 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Albion Dental Care 6 Albion Street Wakefield, MA 01880 #: 33406358 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Biocytogen Boston Corp 50 -C Audubon Road Wakefield, MA 01880 #: 33405710 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bruce Parad DMD 24 Mansfield Drive Wakefield, MA 01880 #: 33406350 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Crescent Dental Associates, LLC 10 Crescent Street Wakefield, MA 01880 #: 33406346 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Crystal Lake Dental 725 Main Street Wakefield, MA 01880 #: 33406359 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Darr Dental LLC 9-A Richardson Avenue Wakefield, MA 01880 #: 33406362 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
F A Carmichael Dentistry 607 North Avenue Suite 16-1 Wakefield, MA 01880 #: 33406028 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fiore Dental Associates 39 Yale Avenue Wakefield, MA 01880 #: 33406352 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Wakefield 409 Main Street Wakefield, MA 01880 #: 33406353 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Great Pond Dental PC 202 Lowell Street Wakefield, MA 01880 #: 33406348 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jeffrey B. Kravitz DDS 417 Water Street Wakefield, MA 01880 #: 33406354 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joy Dental Care 384 Lowell Street Suite 106 Wakefield, MA 01880 #: 33406351 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lakeside Inn 595 North Avenue Wakefield, MA 01880 #: 33101871 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nardone Septic. Inc. dba John's Pumping Service 82 New Salem Street Wakefield, MA 01880 #: 33103407 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard J. Luise DMD 5 Common Street Floor 2 Wakefield, MA 01880 #: 33406356 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Schumacher Dental 599 North Avenue Unit Door 9 Wakefield, MA 01880 #: 33409324 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wakefield Custom Dental 1 West Water Street Suite 101 Wakefield, MA 01880 #: 33406345 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wakefield Family Dental Center 211 Albion Street Wakefield, MA 01880 #: 33406349 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wakefield Item Company, Inc. 26 Albion Street Wakefield, MA 01880 #: 33102249 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aspen Dental 116 Providence Highway East Walpole, MA 02032 #: 34406363 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
B Saba DMD PC 965 Main Street Walpole, MA 02081 #: 34406369 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Associates of Walpole 1428 Main Street Suite 1 Walpole, MA 02081 #: 34406365 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
H.E. Willis Water Treatment Plant 9 Leonard Road Walpole, MA 02081 #: 34102907 Category: 02	0101	SAMPLE PORT ON THE RESIDUALS DISCHARGE PIPE			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Total Suspended Solids Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Herb Chambers Lexus of Sharon 25 Providence Highway Sharon, MA 02067 #: 34103589 Category: 02	0101	RISER PIPE ON DISCH. LINE OF GAS/OIL SEPARATOR ON ABUTMENT	0101	RISER PIPE ON DISCH. LINE OF GAS/OIL SEPARATOR ON ABUTMENT			05-Jun-2024	Notice of Violation
	Semi-Annual Self-Monitoring	Lead (Total) Nickel (Total) Oil and Grease TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	18-Apr-2024	Zinc (Total)	1.18 mg/l	DYMX < 1		
J. Hockman INC 11 Sherwood Drive Norfolk, MA 02056 #: 34409943 Category: 06	No Reporting Requirements			No Discharge Violations				No Enforcement Actions
Kevin P Mischley DDS 1329 Main Street Walpole, MA 02081 #: 34406364 Category: D1	No Reporting Requirements			No Discharge Violations				No Enforcement Actions
Marshall A. Storm DDS, LLC 841 Main Street Suite 6 Walpole, MA 02081 #: 34409300 Category: D1	No Reporting Requirements			No Discharge Violations				No Enforcement Actions
Peggy Lawton Kitchens, Inc. 255 Washington Street East Walpole, MA 02032 #: 34001783 Category: G2	No Reporting Requirements			No Discharge Violations				No Enforcement Actions
Richard A Collari DMD 420 Main Street Walpole, MA 02081 #: 34406367 Category: D1	No Reporting Requirements			No Discharge Violations				No Enforcement Actions
Scott Septic Inc. 44 Spring Street Hopkinton, MA 01748 #: 34409933 Category: 06	No Reporting Requirements			No Discharge Violations				No Enforcement Actions
Siemens Healthineers 333 Coney Street Walpole, MA 02032 #: 34005974 Category: 02	0101	NEUTRALIZATION SYSTEM BUILDING 1		No Discharge Violations				No Enforcement Actions
	Semi-Annual Self-Monitoring	TTO (Volatile Organic Fraction) pH						
	0301	NEUTRALIZATION SYSTEM PARAMAGNETIC PARTICLE MANUFACTURE						
	Semi-Annual Self-Monitoring	TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		pH						
	0401	NEUTRALIZATION SYSTEM MANUFACTURING AREA BUILDING #3						
	Semi-Annual Self-Monitoring							
		TTO (Volatile Organic Fraction)						
		pH						
	0501	NEUTRALIZATION SYSTEM IN BUILDING #4						
	Semi-Annual Self-Monitoring							
		TTO (Volatile Organic Fraction)						
		pH						
Svetlana Livshin DMD 254 Main Street Walpole, MA 02081 #: 34406366 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Unident Dental Group 90 Boston Providence Highway Walpole, MA 02032 #: 34406370 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
376 Dental Studio 376 Moody Street Waltham, MA 02453 #: 35409285 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
A123 Systems LLC 200 West Street Waltham, MA 02451 #: 35103324 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ARE-MA Region No. 110, LLC 35 Gatehouse Drive Waltham, MA 02451 #: 35102425 Category: 02	0101	Neutralization system located in Building B			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Chromium (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0201	Neutralization system located in Building K						
	Semi-Annual Self-Monitoring							
		Chromium (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0301	Cooling Tower Lift Station						
	Annual	Self-Monitoring						
		Chromium (Total)						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Molybdenum						
		Nickel (Total)						
		Orthophosphate						
		Zinc (Total)						
		pH						
Actronics, Inc. 166 Bear Hill Road Waltham, MA 02451 #: 35004599 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
AdvancedWalthamDental 100 Maple Street Waltham, MA 02453 #: 35409462 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aeroshield Materials, Inc. 154 Calvary Street Waltham, MA 02453 #: 35409862 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aspen Dental 1030 Main Street Waltham, MA 02451 #: 35406373 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Azure Dental Studio 25 Lionel Avenue Suite A Waltham, MA 02452 #: 35406382 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BP3-BOS10 100 Beaver Street LLC 100 Beaver Street Waltham, MA 02452 #: 35100174 Category: 02	0106	SPIGOT ON THE NEUTRALIZATION SYSTEM DISCHARGE LINE			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Copper (Total) Formaldehyde Nickel (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Bentley University 175 Forest Street Waltham, MA 02452 #: 35006032 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Best Western Plus 477 Totten Pond Road Waltham, MA 02451 #: 35101867 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Scientific 309 Waverly Oaks Road Floor 1 Waltham, MA 02452 #: 35406946 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
CeraMem LLC 12 Clematis Avenue Waltham, MA 02453 #: 35101781 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Charles River Community Health 43 Foundry Avenue Waltham, MA 02453 #: 35406393 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Children's Dental of Waltham 695 Main Street Waltham, MA 02451 #: 35406396 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Children's Hospital Boston at Waltham 9 Hope Avenue Waltham, MA 02453 #: 35103502 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Circe Biosciences, Inc. 154 Calvary Street Waltham, MA 02453 #: 35409863 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Comprint, Inc. 216 -R Newton Street Waltham, MA 02453 #: 35102645 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Crescent Suites Hotel 285 -287 Crescent Street Waltham, MA 02453 #: 35404993 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cronins Dental 225 Moody Street Waltham, MA 02453 #: 35406377 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Associates-New England 40 2nd Avenue Suite 500 Waltham, MA 02451 #: 35406387 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Farzaneh & Associates 616 Trapelo Road Waltham, MA 02452 #: 35406394 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elevatebio, Inc. 200 Smith Street Waltham, MA 02451 #: 35407980 Category: 02	0101	Sampling spigot after pH neutralization system			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Embassy Suites Hotel/Waltham 550 Winter Street Waltham, MA 02451 #: 35007573 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Evident Scientific 48 Woerd Avenue Waltham, MA 02453 #: 35103245 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Extended Stay America 52 Fourth Avenue Waltham, MA 02451 #: 35102477 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Extended Stay America #9846 32 Fourth Avenue Waltham, MA 02451 #: 35102476 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Failla & DeFrancesco Family Dentistry 976 Main Street Waltham, MA 02451 #: 35406400 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Foster-Miller, Inc. dba QinetiQ North America, Inc. Technology 358 Second Avenue Building 2 Waltham, MA 02451 #: 35103148 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Waltham 879 Main Street Waltham, MA 02451 #: 35406398 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hilton Garden Inn Boston_Waltham 450 Totten Pond Road Waltham, MA 02451 #: 35101868 Category: 02	0101	Spigot on the final discharge line from the washers.			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Oil and Grease pH						
Hyatt House Boston_Waltham 54 Fourth Avenue Waltham, MA 02451 #: 35102475 Category: 02	0101	Hotel laundry discharge.			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Mercury (Total) Oil and Grease Zinc (Total) pH						
ImmunoGen, Inc. 830 Winter Street Waltham, MA 02451 #: 35409880 Category: 02	0101	Sampling spigot after the pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Jeffrey S. Cummings, DMD 520 Main Street Waltham, MA 02452 #: 35406391 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John F. Giglio DMD, Inc. 66 South Street Waltham, MA 02453 #: 35406395 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Markforged, Inc. 60 Tower Road Waltham, MA 02452 #: 35406784 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mighty Squirrel Brewing Company 411 Waverley Oaks Road Suite 100 Waltham, MA 02452 #: 35406822 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Minerva Biotechnologies Corporation 40 Bear Hill Road Waltham, MA 02451 #: 35103507 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Modalis Therapeutics 43 Foundry Avenue Waltham, MA 02453 #: 35407078 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Moody Street Dental Group 52 Elm Street Waltham, MA 02453 #: 35406389 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
My Dental Waltham 314 Moody Street Suite B Waltham, MA 02453 #: 35406385 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
NanoLab, Inc. 22 Bedford Street Waltham, MA 02453 #: 35403986 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
New England Donor Services, Inc. 60 First Avenue Waltham, MA 02451 #: 35403338 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Northway Biotech Inc. 828 Winter Street Waltham, MA 02451 #: 35408338 Category: 02	0101	Sampling spigot after the pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
PPF OFF 828-830 Winter Street, LLC 830 Winter Street Waltham, MA 02451 #: 35408826 Category: 02	0101	Sampling spigot after the pH Neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Quantum Pathology, LLC 303 Bear Hill Road Waltham, MA 02451 #: 35404439 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Regis College 235 Wellesley Street Weston, MA 02493-0000 #: 35102895 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Repligen Corporation 41 Seyon Street Building 1-100 Waltham, MA 02453 #: 35102962 Category: 02	0101	SPIGOT ON NEUTRALIZATION SYSTEM DISCHARGE LINE			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Copper (Total) Formaldehyde Mercury (Total) Nickel (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Robert Bosch LLC 101 First Avenue Waltham, MA 02451 #: 35100506 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
SSG Hospitality dba Courtyard by Marriott 387 Winter Street Waltham, MA 02451 #: 35102943 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Simpson Gumpertz & Heger Inc. 480 Totten Pond Road Waltham, MA 02451 #: 35102980 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Stratasys Ltd. 309 Waverly Oaks Road Waltham, MA 02452 #: 35404612 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
T. Sona Tacvorian, DMD 29 Spruce Street Suite 1-1 Waltham, MA 02453 #: 35407881 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tam, Tang & Sham P.C. dba Waltham Dental Center 85 River Street #2 Waltham, MA 02453 #: 35406397 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tecogen, Inc. 45 First Avenue Waltham, MA 02451 #: 35005726 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wal-Lex Dental Associates 1077 Lexington Street Suite 201 Waltham, MA 02452 #: 35406374 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Waltham Dental Group 32 South Street Suite 202 Waltham, MA 02451 #: 35406386 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Waltham Family Dental, PC 30 Grant Street Waltham, MA 02453 #: 35407882 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Waverley Oaks Dental, Inc. 465 Waverley Oaks Road Suite 208 Waltham, MA 02452 #: 35406388 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ARE - 480 Arsenal Street, LLC 480 Arsenal Street Watertown, MA 02472 #: 36103717 Category: 02	0101	Sample spigots on the discharge line after the pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions	
ARE-MA Region No. 75 LLC (4 Kingsbury Ave) 4 Kingsbury Avenue Watertown, MA 02472 #: 36409811 Category: 02	0101	Zinc (Total)						No Enforcement Actions	
		pH							
		Sampling spigot after the pH neutralization system		No Discharge Violations					
		Semi-Annual Self-Monitoring							
		Copper (Total)							
		Lead (Total)							
		Mercury (Total)							
		TTO (Volatile Organic Fraction)							
		Zinc (Total)							
		pH							
ARE-MA Region No. 75, LLC (200 Talcott Ave) 200 Talcott Avenue Watertown, MA 02472 #: 36409370 Category: 02	0101	sampling port after pH neutralization system	0101	sampling port after pH neutralization system				21-Nov-2023 Notice of Violation	
		Semi-Annual Self-Monitoring		30-Aug-2023	Formaldehyde	16	mg/l	DYMX < 9	
		Copper (Total)							
		Formaldehyde							
		Lead (Total)							
		Mercury (Total)							
		Nickel (Total)							
		TTO (Extractable Organic Fraction)							
		TTO (Volatile Organic Fraction)							
	Zinc (Total)								
	pH								
ARE-MA Region No. 75, LLC (300 N Beacon St) 300 N Beacon Street Watertown, MA 02472 #: 36409184 Category: 02	0101	lab wastewater standpipe after pH neutralization system	0101	lab wastewater standpipe after pH neutralization system				12-Jan-2024 Notice of Violation	
		Semi-Annual Self-Monitoring		12-Dec-2023	Chloroform (Trichloromethane)	1.5	mg/l	DYMX < 1	
		Arsenic (Total)							
		Cadmium (Total)							
		Chromium (Total)							
		Color							
		Copper (Total)							
		Cyanide (Total)							
		Formaldehyde							
	Lead (Total)								
	Mercury (Total)								
	Nickel (Total)								
	Odor (T.O.N.)								
	Selenium (Total)								
	Silver (Total)								
	TTO(Extractable Organic Fraction)								
	TTO (Volatile Organic Fraction)								
	Temperature								
	Zinc (Total)								
	pH								
Aldatu Biosciences 313 Pleasant Street Floor 1 W Watertown, MA 02472 #: 36409009 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
All Dental Center 21 Main Street Watertown, MA 02472 #: 36406408 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Dental Watertown 171 Watertown Street Watertown, MA 02472 #: 36407647 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arkuda Therapeutics 200 Arsenal Yards Boulevard Suite 220 Watertown, MA 02472 #: 36408235 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arranta Bio MA, LLC 650 Pleasant Street Watertown, MA 02472 #: 36408642 Category: 02	0101	Process wastewater after pH neutralization system.			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Mercury (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Atrius Health - Harvard Vanguard Medical Associates 485 Arsenal Street Watertown, MA 02272 #: 36102779 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BRE-BMR Grove LLC 65 Grove Street Watertown, MA 02472 #: 36408012 Category: 02	0101	Laboratory wastewater from 1st & 3rd floors			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0102	Laboratory wastewater from 1st, 2nd, & 3rd floors						
		Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Barclay Water Management, Inc. 80 Coolidge Avenue Watertown, MA 02472 #: 36002494 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Berkeley Pleasant St. Owner, LLC 64 Pleasant Street Watertown, MA 02472 #: 36409836 Category: 02	0101	Laboratory wastewater	No Discharge Violations				No Enforcement Actions	
	Annual	Self-Monitoring Copper (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Bon Ton Rug Cleansers, Inc. 81 -85 Coolidge Hill Road Watertown, MA 02472 #: 36002175 Category: 02	0201	The floor drain beside the automated carpet cleaner	No Discharge Violations				No Enforcement Actions	
	Quarterly	Self-Monitoring Oil and Grease TTO (Volatile Organic Fraction) pH						
C4 Therapeutics, Inc. 490 Arsenal Way Watertown, MA 02472 #: 36406070 Category: 02	0101	R&D lab wastewater	No Discharge Violations				No Enforcement Actions	
	Semi-Annual	Self-Monitoring Cadmium (Total) Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0102	R&D lab wastewater						
	Semi-Annual	Self-Monitoring Cadmium (Total) Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Cambrian Innovation Inc. 150 Coolidge Avenue Watertown, MA 02472 #: 36403605 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridge Scientific Lab Space 200 -201 Dexter Avenue Watertown, MA 02472 #: 36407017 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Charles M Seitz DDS 1047 Belmont Street Watertown, MA 02472 #: 36406401 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
David M Drucker DDS 491 Main Street Watertown, MA 02472 #: 36406428 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Diagonal Therapeutics 200 Arsenal Yards Boulevard Watertown, MA 02472 #: 36409947 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Domenic D'Amico DMD PC 359 Main Street Watertown, MA 02472 #: 36406413 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Enanta Pharmaceuticals, Inc. 500 Arsenal Street Watertown, MA 02472 #: 36102888 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fantasia, Failla & DeFrancesco Family Dentistry 293 Mount Auburn Street Watertown, MA 02472 #: 36406411 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joseph J Salusti DMD PC 118 Main Street Watertown, MA 02472 #: 36406402 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Karekine Matossian DMD 222 Waverly Avenue Watertown, MA 02472 #: 36406409 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Landmark Bio 300 N Beacon Street Watertown, MA 02472 #: 36409367 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Leon B Bastajian DDS 521 Mount Auburn Street Suite 207 Watertown, MA 02472 #: 36406419 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Luminous Dental LLC 63 Mount Auburn Street Watertown, MA 02472 #: 36406422 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lyra Therapeutics, Inc. 480 Arsenal Way Watertown, MA 02472 #: 36103648 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mack Dental 15 Summer Street Watertown, MA 02472 #: 36406405 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mark J Strokowski DMD 326 Belmont Street Watertown, MA 02472 #: 36406424 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mayani Dental Watertown LLC 6 Mount Auburn Street Watertown, MA 02472 #: 36406433 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newly Weds Foods, Inc. 70 -80 Grove Street Watertown, MA 02472 #: 36101065 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pediatric Dental Arts 521 Mount Auburn Street Suite 104 Watertown, MA 02472 #: 36406430 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peter A Zucker DDS 95 Mount Auburn Street Watertown, MA 02472 #: 36406435 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Premier Dental Care 377 Main Street Watertown, MA 02472 #: 36406426 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pulpdent Corporation 80 Oakland Street Watertown, MA 02472 #: 36007274 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Radiation Monitoring Devices, Inc. 44 Hunt Street Watertown, MA 02472 #: 36005477 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
SQZ Biotechnologies Company 200 Arsenal Yards Boulevard Suite 210 Watertown, MA 02472 #: 36408074 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Samvel Martirosyan DMD Inc. 164 Galen Street Watertown, MA 02472 #: 36406406 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sweet Cream Corporation 128 Arlington Street Watertown, MA 02472 #: 36403490 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
TNT Dental Care PC 230 Main Street Watertown, MA 02472 #: 36406410 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tectonic Therapeutic 490 Arsenal Way Suite 210 Watertown, MA 02472 #: 36408860 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Toyota of Watertown 149 Arsenal Street Watertown, MA 02472 #: 36301610 Category: 02	0101	Pipe in the Fire Panel Room that flows into the oil/water separator			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Cadmium (Total)						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Zinc (Total) pH						
Watertown Family Dental 190 Mount Auburn Street Suite A-2 Watertown, MA 02472 #: 36406407 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
William V Byrne DMD 148 Main Street Watertown, MA 02472 #: 36406404 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Andrew J Toyias DDS 490 Washington Street Wellesley, MA 02482 #: 37406452 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 230 Worcester Street Wellesley, MA 02481 #: 37005430 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Au Blanc Aesthetics 1 Hollis Street Suite 140 Wellesley, MA 02481 #: 37406444 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Babson College 231 Forest Street Babson Park Wellesley, MA 02457 #: 37005429 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Babson Executive Conference Center One Woodland Hill Drive Wellesley, MA 02457 #: 37102424 Category: 02	0101	Flume situated in vault in mechanical room adjacent to laundry room			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Oil and Grease pH						
Faridoon Zamani, DMD, PC 310 Washington Street Suite 208 Wellesley, MA 02481 #: 37407296 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gary S. Wetreich DDS, PC 1 Washington Street Suite 204 Wellesley, MA 02481 #: 37406437 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Hirshberg Dental Group 65 William Street Wellesley, MA 02481 #: 37406454 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jeffrey A Harrison DMD PC 258 Washington Street Wellesley, MA 02481 #: 37406441 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John Owen DMD 332 Washington Street Suite 300 Wellesley, MA 02481 #: 37409291 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Longfellow Pond Groundwater Treatment Facility 272 Worcester Street Wellesley, MA 02481 #: 37101759 Category: 02	0101	4-inch filter backwash/sludge line			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Total Suspended Solids Copper (Total) Nickel (Total) pH						
	0102	Discharge pipe from chlorine analyzer near lab bench						
	Annual	Self-Monitoring pH						
Maewall Dental Care 358 Washington Street Wellesley, MA 02481 #: 37406448 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Maria E Cardenas DMD 332 Washington Street Suite 365 Wellesley, MA 02481 #: 37406447 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Morses Pond Groundwater Treatment Facility 100 Turner Road Extension Wellesley, MA 02481 #: 37101760 Category: 02	0101	4-inch sludge line from waste basins			No Discharge Violations			No Enforcement Actions
	Monthly	Self-Monitoring Total Suspended Solids Arsenic (Total) Arsenic (Total) Copper (Total) Copper (Total) Nickel (Total) Nickel (Total) PFAS Pollutant Group pH pH						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
	0102	2-inch analyzer discharge line						
	Annual	Self-Monitoring pH						
New Generation Dental Center 1 Washington Street Suite 306 Wellesley, MA 02481 #: 37406438 Category: D1		No Reporting Requirements	No Discharge Violations				No EnforcementActions	
Newton Wellesley Outpatient Surgery Center 25 Washington Street Wellesley, MA 02481 #: 37404682 Category: 02	0101	Utensil Washers A&B	No Discharge Violations				No EnforcementActions	
	Semi-Annual	Self-Monitoring Copper (Total) Lead (Total) Nickel (Total) Zinc (Total) pH						
Peter W. Brodie DMD PC and Matthew R. Fantasia DMD PC 372 Washington Street Wellesley, MA 02481 #: 37406449 Category: D1		No Reporting Requirements	No Discharge Violations				No EnforcementActions	
Premier Dental Group of Wellesley, PC 70 Walnut Street Floor 1 Wellesley, MA 02481 #: 37407284 Category: D1		No Reporting Requirements	No Discharge Violations				No EnforcementActions	
Wellesley Avenue Groundwater Treatment Facility 409 Wellesley Avenue Wellesley, MA 02481 #: 37101761 Category: 02	0101	Filter backwash sludge from waste basins	No Discharge Violations				No EnforcementActions	
	Monthly	Self-Monitoring Total Suspended Solids Arsenic (Total) Copper (Total) Lead (Total) Nickel (Total) Zinc (Total) pH						
	0102	Laboratory discharge						
	Annual	Self-Monitoring pH						
Wellesley College 106 Central Street Wellesley, MA 02481 #: 37005432 Category: 02	0103	Discharge from Science CenterpHadjustment system	No Discharge Violations				No Enforcement Actions	
	Semi-Annual	Self-Monitoring Copper (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Zinc (Total) pH						
	0106	KSC basement laundry room						
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Wellesley Dental Arts 31 Washington Street Suite A Wellesley, MA 02481 #: 37406443 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Dental Associates 148 Linden Street Suite B-3 Wellesley, MA 02482 #: 37406440 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Dental Group 5 Seaward Road Wellesley, MA 02481 #: 37406453 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Dental Studio 332 Washington Street Suite 240 Wellesley, MA 02481 #: 37409290 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Dialysis LLC 195 Worcester Street Wellesley, MA 02481 #: 37404325 Category: 10	No Reporting Requirements				No Discharge Violations		22-Apr-2024	Notice of Noncompliance
Wellesley Endodontics PC 40 Grove Street Suite 420 Wellesley, MA 02482 #: 37406450 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Family Dental 298 Washington Street Wellesley, MA 02481 #: 37406445 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Hills Dental 332 Washington Street Suite 330 Wellesley, MA 02481 #: 37406446 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Wellesley Square Dental 1 Hollis Street Suite 340 Wellesley, MA 02482 #: 37406436 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
A Beautiful Smile Dentistry 1864 Centre Street West Roxbury, MA 02132 #: 56407649 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ace Dental West Roxbury LLC 1840 Center Street West Roxbury, MA 02132 #: 56406465 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Banknote Corporation (ABCorp) 225 Rivermoor Street West Roxbury, MA 02132 #: 56006941 Category: 10		No Reporting Requirements			No Discharge Violations		06-Feb-2024	Notice of Noncompliance
Ari Family Dental 1819 Centre Street West Roxbury, MA 02132 #: 56406468 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 291 Independence Drive West Roxbury, MA 02467 #: 56101738 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bankhead & Groipen DDS PC 399 Belgrade Avenue West Roxbury, MA 02132 #: 56406473 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
City of Boston - Gardner Street Landfill 315 Gardner Street West Roxbury, MA 02132 #: 56102744 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fadi Metri & Associates 28 Corey Street West Roxbury, MA 02132 #: 56406469 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Family Dentistry of West Roxbury 5230 Washington Street West Roxbury, MA 02132 #: 56406474 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Gentle Dental West Roxbury 1852 Centre Street West Roxbury, MA 02132 #: 56406466 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
JL Dental Associates 1892 Center Street West Roxbury, MA 02132 #: 56406467 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
L David Gassiraro DDS 725 Veterans of Foreign Wars Parkway West Roxbury, MA 02132 #: 56406476 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
McLaughlin Family Dentist 59 Beach Street West Roxbury, MA 02132 #: 56406475 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Reliant Dental Group PC 1996 Centre Street Suite 201 West Roxbury, MA 02132 #: 56409096 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard J Shea DMD 335 Corey Street West Roxbury, MA 02132 #: 56406471 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Timothy N. Smith DMD 12 Spring Street West Roxbury, MA 02131 #: 56406458 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
West Roxbury Dental Arts 1811 Centre Street West Roxbury, MA 02132 #: 56406464 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Captain Marden's Seafoods 35 Perwal Street Westwood, MA 02090 #: 38102816 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dedham-Westwood Water District (White Lodge WTP) 154 University Avenue Westwood, MA 02090 #: 38101064 Category: 02	0101 Monthly	Discharge line in the underground waste tank chamber Self-Monitoring Total Suspended Solids Cadmium (Total) Chromium (Total)			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Copper (Total)						
		Lead (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Dental Arts of Westwood 100 High Street Level Lower Westwood, MA 02090 #: 38406477 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fresenius Kidney Care - Westwood 90 Glacier Drive Westwood, MA 02090 #: 38007115 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
OS 690 Canton Street Associates LLC 690 Canton Street Westwood, MA 02090 #: 38409908 Category: 02	0101	Spigot on the discharge line of the pH neutralization system in West Room 005			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0102	Spigot on the discharge line of the pH neutralization system in East Room 024						
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Westwood Dental Partners 541 High Street Suite 3 Westwood, MA 02090 #: 38406480 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Westwood Dentistry 327 Washington Street Westwood, MA 02090 #: 38406478 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
iLove Dental Care 541 High Street Level LL1 Westwood, MA 02090 #: 38406479 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ace Dental Group 1025 Main Street South Weymouth, MA 02190 #: 39406291 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Advanced Dental Centers 544 Main Street Weymouth, MA 02190 #: 39406489 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Antech Diagnostics 595 Columbian Street Weymouth, MA 02190 #: 39102702 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arbor Inn LLC 750 Bridge Street Weymouth, MA 02191 #: 39405338 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Associated Dental Group of Weymouth 500 Pond Street South Weymouth, MA 02190 #: 39406296 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Barrel House Z, LLC 95 Woodrock Road Weymouth, MA 02189 #: 39405399 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beyond Dental Health of Weymouth 851 Main Street Suite 8 Weymouth, MA 02188 #: 39409312 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brady Enterprises, Inc. 167 Moore Road East Weymouth, MA 02189 #: 39002044 Category: 10		No Reporting Requirements			No Discharge Violations		06-Oct-2023	Notice of Noncompliance
Columbian Square Dental 59 Columbian Street Weymouth, MA 02190 #: 39408755 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Comfort Dental Weymouth 47 Washington Street Weymouth, MA 02188 #: 39406488 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DaVita - Weymouth Dialysis Center 330 Libbey Industrial Parkway Suite 900 Weymouth, MA 02188 #: 39101150 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
David F. Grace, DMD 1125 Washington Street East Weymouth, MA 02189 #: 39407473 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Deluxe Family Dental Care 83 Broad Street Weymouth, MA 02188 #: 39406493 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Aid 1 PC 884 Washington Street Suite 130 Weymouth, MA 02189 #: 39409173 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentistry for Children PC 851 Main Street Suite 3 South Weymouth, MA 02190 #: 39406298 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Richard M. Nadler 94 Washington Street Suite 1 Weymouth, MA 02188 #: 39409310 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elias Badran DDS 73 Pleasant Street Weymouth, MA 02190 #: 39406492 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
FCS Boston, Inc. dba Chemstation - Boston 96 Moore Road Weymouth, MA 02189 #: 39103307 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Iona Dental, PC (dba Meridian Dental Associates) 1650 Main Street Weymouth, MA 02190 #: 39406486 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Jonathan Alihosseini DMD 33 Union Street Suite 6 South Weymouth, MA 02190 #: 39406295 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pauline J McDonough DDS 1355 Pleasant Street Weymouth, MA 02189 #: 39406485 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peter J McDonald DDS 147 Pleasant Street South Weymouth, MA 02190 #: 39406294 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
QCDC Weymouth #1944 (aka Fresenius Kidney Care) 2 West Street 1 Weymouth, MA 02190 #: 39103169 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard E Wolfert DDS 1121 Main Street Suite 2 South Weymouth, MA 02190 #: 39406292 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Shore Dentistry 696 Main Street South Weymouth, MA 02190 #: 39406299 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Star Litho, Inc. 360 Libbey Industrial Parkway Weymouth, MA 02189 #: 39009317 Category: 10		No Reporting Requirements			No Discharge Violations		06-Oct-2023 Notice of Noncompliance	
Stetson Dental Care 561 Main Street Weymouth, MA 02190 #: 39406491 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
T. EN Stone & Webster Process Technology, Inc. 56 Woodrock Road East Weymouth, MA 02189 #: 39001933 Category: 01	0101 Annual	Styrene unit decant water Self-Monitoring TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions
Thomas M Decoste DDS 293 Libbey Parkway Suite A-100 Weymouth, MA 02189 #: 39406487 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
US Renal Care Weymouth 587 Washington Street Weymouth, MA 02188 #: 39405398 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Unident Group Inc. 527 Main Street Weymouth, MA 02190 #: 39409238 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vitamin Sea Brewing LLC 30 Moore Road Weymouth, MA 02189 #: 39406798 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Weymouth Dental Associates 130 Broad Street Weymouth, MA 02188 #: 39406484 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Weymouth Dentistry and Braces 35 Pleasant Street Weymouth, MA 02190 #: 39409313 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Weymouth Family Dental Care 1125 Washington Street Weymouth, MA 02189 #: 39406483 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Weymouth Smiles Dental 536 Broad Street Suite 1 Weymouth, MA 02189 #: 39406490 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
AAE Embroidery & Screen Printing, Inc. 789 Woburn Street Unit 2 Wilmington, MA 01887 #: 40407963 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Advanced Imaging, Inc. 234 Ballardvale Street Wilmington, MA 01887 #: 40103659 Category: G1	0101	PHOTO			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Silver (Total)						
Agfa Corporation 187 Ballardvale Street Wilmington, MA 01887 #: 40005698 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Analog Devices 831 Woburn Street Wilmington, MA 01887 #: 40007290 Category: 02	0201	sampling spigot on discharge line of the pH neutralization system			No Discharge Violations			No Enforcement Actions
	Semi-Annual Self-Monitoring	Chromium (+6) Copper (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
Biondo & Foley Dental Group 188 Main Street Suite 200 Wilmington, MA 01887 #: 4006494 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Gas Company dba National Grid 326 Ballardvale Street Wilmington, MA 01887 #: 40102909 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Charles River Laboratories 251 Ballardvale Street Wilmington, MA 01887 #: 40000924 Category: 02	0501	standpipe on the discharge line after pH neutralization in Bldg 18			No Discharge Violations			No Enforcement Actions
	One Time	One-time Permit Sampling PFAS Pollutant Group pH Biochemical Oxygen Demand (5 Day) Chromium (Total) Copper (Total) Nickel (Total) Total Suspended Solids pH						
	1001	outdoor standpipe behind Building 12						
	One Time	One-time Permit Sampling PFAS Pollutant Group pH Copper (Total) Formaldehyde Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	1101	spigot on the discharge line after pH neutralization in Building 22						
	One Time	One-time Permit Sampling PFAS Pollutant Group pH Biochemical Oxygen Demand (5 Day) Formaldehyde						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
ChemGenes Corporation 33 Industrial Way Wilmington, MA 01887 #: 40103037 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DJKDMD, PC 102 Lowell Street Wilmington, MA 01887 #: 40409322 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Deborah A Edgerly DMD 299 Main Street Wilmington, MA 01887 #: 40406496 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dee-Ray Inc. 919 Main Street Wilmington, MA 01887 #: 40100403 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Forever Family Dental PLLC 25 Lowell Street Wilmington, MA 01887 #: 40406495 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
HP Hood R&D 800 Research Drive Wilmington, MA 01887 #: 40102074 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Happy Sunny Dental LLC dba Smile Life Dental 211 Lowell Street Unit K Wilmington, MA 01887 #: 40409321 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kirkwood Printing Company, Inc. 904 Main Street Wilmington, MA 01887 #: 40006245 Category: G1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MKS Instruments, Inc. 90 Industrial Way Wilmington, MA 01887 #: 40102397 Category: 02	0101	pH neutralization system discharge line			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Aluminum Chromium (Total) Copper (Total) Nickel (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Zinc (Total) pH						
Monogram Gourmet Foods, LLC (301 Ballardvale) 301 Ballardvale Street Wilmington, MA 01887 #: 40407227 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
New England Dental Group - Wilmington 206 Ballardvale Street Wilmington, MA 01887 #: 40409323 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Screenprint/Dow 200 Research Drive Wilmington, MA 01887 #: 40101635 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Silver Lake Dental 96 Main Street Wilmington, MA 01887 #: 40406498 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smyth Companies LLC-The Dow Division 271 Ballardvale Street Wilmington, MA 01887 #: 40005632 Category: 02	0104	SCREENPRINT AREA Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
Wilmington Dental Studio 230 Lowell Street Suite 1E Wilmington, MA 01887 #: 40409320 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Xenon Corporation 37 Upton Drive Wilmington, MA 01887 #: 40103386 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elene Avgherinos DDS 576 Main Street Winchester, MA 01890 #: 41406504 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Fiorillo Dentistry 955 Main Street Suite 205 Winchester, MA 01890 #: 41406509 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Janis Moriarty DMD 607 Main Street Winchester, MA 01890 #: 41406505 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Middlesex Endodontics 47 Shore Road Suite 2 Winchester, MA 01890 #: 41406502 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nabil R Ibrahim DDS, PLLC 10 Converse Place Suite 102 Winchester, MA 01890 #: 41406499 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pablo Bella Dental 259 Swanton Street Winchester, MA 01890 #: 41406501 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Russell Hill Dental PC 955 Main Street Suite 201 Winchester, MA 01890 #: 41406510 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smile Boutique 49 Church Street Winchester, MA 01890 #: 41406503 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Thomas Russo DDS 63 Shore Road Suite 13 Winchester, MA 01890 #: 41406506 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
U.S. Food and Drug Administration 109 Holton Street Winchester, MA 01890 #: 41003788 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Winchester Hospital 41 Highland Avenue Winchester, MA 01890 #: 41005764 Category: 02	0102	Equalization tank for Central Material Services	0102	Equalization tank for Central Material Services	6-Dec-2023 pH	5.24	S.U.	Grab/ Ph
		Semi-Annual Self-Monitoring Copper (Total) Zinc (Total) pH						> 5.5

02-Jan-2024 Notice of Violation

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
	0106	Sampling spigot on limestone chip tank discharge line						
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Winchester Water Treatment Plant 345 S Border Road Winchester, MA 01890 #: 41103460 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Winchester and Reading Pediatric Dentistry LLC 955 Main Street Suite 101/102 Winchester, MA 01890 #: 41406508 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
AP Dental Center 113 Revere Street Suite 1 Winthrop, MA 02152 #: 42406511 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brooks Dental 54 Woodside Avenue Winthrop, MA 02152 #: 42406309 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Harborside Dental 313 Main Street Winthrop, MA 02152 #: 42406514 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Varinos Dental Associates of Winthrop PC 155 Veterans Road Winthrop, MA 02152 #: 42406512 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Winthrop Dental 249 Washington Avenue Winthrop, MA 02152 #: 42406513 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
3-D Matrix, Inc. 25 -K Olympia Avenue Suite 600 Woburn, MA 01801 #: 43404097 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
ARE -MA Region No. 20, LLC 19 Presidential Way Woburn, MA 01801 #: 43404639 Category: 02	0101	pH ADJUSTMENT SYSTEM OUTLET	0101	pH ADJUSTMENT SYSTEM OUTLET			14-Sep-2023 Notice of Violation 13-Nov-2023 Notice of Violation	
	Semi-Annual Self-Monitoring		30-Oct-2023	pH	12.11	S.U. Grab/ Ph < 12		
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Active Surfaces Inc. 34 Commerce Way Woburn, MA 01801 #: 43409926 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Advanced Dentistry LLC 65 Pleasant Street Woburn, MA 01801 #: 43406322 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Agape Dentist 576 Main Street Woburn, MA 01801 #: 43406318 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Agrivida Inc. 78 E Olympia Avenue Woburn, MA 01801 #: 43103617 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Air Liquide - Advanced Technologies LLC 35 A Cabot Road Woburn, MA 01801 #: 43103321 Category: 02	0101	Area sink located in the Extrusion Lab					No Enforcement Actions	
	Semi-Annual Self-Monitoring							
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0102	Discharge line of area sink limestone chip tank in Fiber Rinsing Area						
	Semi-Annual Self-Monitoring							

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Alden-Hauk, Inc. 215 Salem Street Unit G Woburn, MA 01801 #: 43102113 Category: 10	0103	TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	Area sink located in Coating Area							
	Semi-Annual Self-Monitoring							
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Alsym Energy 82 Cummings Park Woburn, MA 01801 #: 43408680 Category: 02	0101	Final discharge line of wet chemistry under sink chip tank				07-Jul-2023 Notice of Violation		
	Semi-Annual Self-Monitoring							
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
Silver (Total)								
TTO (Extractable Organic Fraction)								
TTO (Volatile Organic Fraction)								
Zinc (Total)								
pH								
0102	Final discharge line on the pH neutralization system							
Semi-Annual Self-Monitoring								
	Cadmium (Total)							
	Chromium (Total)							
	Copper (Total)							
	Lead (Total)							
	Mercury (Total)							
	Nickel (Total)							
	Oil and Grease							
	Silver (Total)							
	TTO (Extractable Organic Fraction)							
	TTO (Volatile Organic Fraction)							
	Zinc (Total)							
	pH							
No Reporting Requirements		No Discharge Violations				No Enforcement Actions		

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Arnasi Group 12 Gill Street Woburn, MA 01801 #: 43409864 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aspen Dental 3 Elm Street Woburn, MA 01801 #: 43406316 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Azurity Pharmaceuticals 8 Cabot Road Suite 3000 Woburn, MA 01801 #: 43405053 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BD Interventional Surgery Group 160 New Boston Street Woburn, MA 01801 #: 43100484 Category: 02	0103	Equipment cleaning from Avitene manufacturing process			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Oil and Grease TTO (Volatile Organic Fraction) pH						
Best Western Plus New Englander 1 Rainin Road Woburn, MA 01801 #: 43101878 Category: 02	0101	LAUNDRY ROOM			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						
Boston Electrometallurgical Corp. 6 -C Gill Street Woburn, MA 01801 #: 43406952 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brannen Brothers Flutemakers, Inc. 58 Dragon Court Woburn, MA 01801 #: 43100193 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
CONTINUUS Pharmaceuticals, Inc. 256 W Cummings Park Woburn, MA 01801 #: 43409198 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
CSM CY Woburn, LLC dba Courtyard by Marriott - Woburn 700 Unicorn Park Drive Woburn, MA 01801 #: 43404614 Category: 02	0101	Laundry Room			No Discharge Violations			No Enforcement Actions
	Semi-Annual	Self-Monitoring Copper (Total)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						
Cambridge Polymer Group, Inc. 100 Trade Center Drive Suite 200 & 150 Woburn, MA 01801 #: 43403813 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cardone Family Dental 800 West Cummings Park Suite 1050 Woburn, MA 01801 #: 43406324 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Comera Life Sciences Inc. 12 Gill Street Suite 4650 Woburn, MA 01801 #: 43404852 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Connolly Printing, LLC 17 -B Gill Street Woburn, MA 01801 #: 43403800 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Covaris, Inc. 14 Gill Street Unit H Woburn, MA 01801 #: 43404152 Category: 10		No Reporting Requirements			No Discharge Violations		06-Jul-2023	Notice of Noncompliance
Crowne Plaza Boston-Woburn 15 Middlesex Canal Park Road Woburn, MA 01801 #: 43101822 Category: 02	0101	Laundry room discharge to floor trough drain Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
DaVita Dialysis - Woburn 23 Warren Avenue Suite 195 Woburn, MA 01801 #: 43103330 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Healthcare of Woburn PC 90 Pleasant Street Woburn, MA 01801 #: 43406325 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dentology 444 Washington Street Suite 301 Woburn, MA 01801 #: 43407984 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Discovery Life Sciences, LLC 6 Henshaw Street Woburn, MA 01801 #: 43102759 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
E.V. Yeuell, Inc. 17 Gill Street Woburn, MA 01801 #: 43005201 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
F T Dental Corp 444 Washington Street Suite 312 Woburn, MA 01801 #: 43406317 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fairfield Inn by Marriott Woburn 285 Mishawum Road Woburn, MA 01801 #: 43101816 Category: 02	0101	Flume on discharge line of washers	0101	Flume on discharge line of washers			14-Sep-2023 Notice of Noncompliance 19-Apr-2024 Notice of Violation	
	Semi-Annual Self-Monitoring		21-Feb-2024	Zinc (Total)	1.75	mg/l DYMx < 1		
	Copper (Total)							
	Lead (Total)							
	Mercury (Total)							
	Oil and Grease							
	Zinc (Total)							
	pH							
Fanikos Salib Dental Associates 7 Alfred Street Suite 125 Woburn, MA 01801 #: 43406323 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Four Corners Dental Care 237 Lexington Street Suite 210 Woburn, MA 01801 #: 43406313 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Woburn 474 Main Street Woburn, MA 01801 #: 43409271 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Genturi, Inc. 8 Cabot Road Suite 3400&4400 Woburn, MA 01801 #: 43405106 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Glycosyn LLC 6 -H Gill Street Woburn, MA 01801 #: 43404785 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gradiant Corporation 11 Sixth Road Unit C Woburn, MA 01801 #: 43404254 Category: 10		No Reporting Requirements			No Discharge Violations		30-Nov-2023	Notice of Noncompliance
Hela Novel Metals 150 New Boston Street Suite A Woburn, MA 01801 #: 43407668 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Insultab, Inc. 45 Industrial Parkway Woburn, MA 01801 #: 43000746 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ionic Materials 10 -L Commerce Way Woburn, MA 01801 #: 43403915 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joseph G. DiTullio DMD 8 Cedar Street Suite 41 Woburn, MA 01801 #: 43409230 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joseph's Catering Inc. 30 Torrice Drive Woburn, MA 01801 #: 43409231 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kayem Foods 14 Industrial Park Woburn, MA 01801 #: 43101035 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lord Hobo Brewing Company LLC 5 Draper Street Woburn, MA 01801 #: 43404515 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MRL Inc. 160 New Boston Street Woburn, MA 01801 #: 43404185 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
McCall Family Dental 14 Winn Street Woburn, MA 01801 #: 43406311 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Medtronic dba Covidien LP 12 Gill Street Suite 3500 Woburn, MA 01801 #: 43403369 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nanoimaging Services 4 Gill Street Suite C Woburn, MA 01801 #: 43408337 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
OPKO Diagnostics LLC 4 Constitution Way Suite E, F & G Woburn, MA 01801 #: 43103581 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Optowares, Inc. 15 Presidential Way Woburn, MA 01801 #: 43409170 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Organix Chemistry Solutions LLC 240 Salem Street Woburn, MA 01801 #: 43101987 Category: 02	0102	Discharge Line After pH Adjustment Tank			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
PKC Pharmaceuticals, Inc. 165 -T New Boston Street Woburn, MA 01801 #: 43005939 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pace Analytical Services, LLC 22 Cummings Park Drive Woburn, MA 01801 #: 43404401 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Peak Event Services 36 Cabot Road Woburn, MA 01801 #: 43409860 Category: 02	0101	Laundry effluent from six industrial washing machines			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----			
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions		
Phoenix Tailings, Inc. 8-B Henshaw Avenue Woburn, MA 01801 #: 43408243 Category: 10	0102	Zinc (Total)								
		pH								
	Semi-Annual Self-Monitoring	Copper (Total)								
		Lead (Total)								
		Mercury (Total)								
		Oil and Grease								
		TTO (Extractable Organic Fraction)								
		TTO (Volatile Organic Fraction)								
		Zinc (Total)								
		pH								
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions		
		Practical Applications, Inc. 8 Adele Road Woburn, MA 01801 #: 43102504 Category: 10		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
			Semi-Annual Self-Monitoring	Copper (Total)						
				Lead (Total)						
Mercury (Total)										
Oil and Grease										
TTO (Extractable Organic Fraction)										
TTO (Volatile Organic Fraction)										
Zinc (Total)										
pH										
No Reporting Requirements					No Discharge Violations			No Enforcement Actions		
Purinomia Biotech Inc. 2 -E Gill Street Woburn, MA 01801 #: 43407679 Category: 10				No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
	Semi-Annual Self-Monitoring			Copper (Total)						
				Lead (Total)						
		Mercury (Total)								
		Oil and Grease								
		TTO (Extractable Organic Fraction)								
		TTO (Volatile Organic Fraction)								
		Zinc (Total)								
		pH								
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions		
		Quad/Graphics Commercial & Specialty, LLC 110 Commerce Way Building J Woburn, MA 01801 #: 43404380 Category: 10		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
			Semi-Annual Self-Monitoring	Copper (Total)						
				Lead (Total)						
Mercury (Total)										
Oil and Grease										
TTO (Extractable Organic Fraction)										
TTO (Volatile Organic Fraction)										
Zinc (Total)										
pH										
No Reporting Requirements					No Discharge Violations			No Enforcement Actions		
Radiant Dentistry of Woburn 186 Cambridge Road Suite 12 Woburn, MA 01801 #: 43406312 Category: D1				No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
	Semi-Annual Self-Monitoring			Copper (Total)						
				Lead (Total)						
		Mercury (Total)								
		Oil and Grease								
		TTO (Extractable Organic Fraction)								
		TTO (Volatile Organic Fraction)								
		Zinc (Total)								
		pH								
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions		
		Red Roof Plus+ Woburn i0238 19 Commerce Way Woburn, MA 01801 #: 43101814 Category: 02	0101	LAUNDRY ROOM			No Discharge Violations		14-Sep-2023 Notice of Noncompliance	
			Semi-Annual Self-Monitoring	Copper (Total)						
				Lead (Total)						
Mercury (Total)										
Oil and Grease										
TTO (Extractable Organic Fraction)										
TTO (Volatile Organic Fraction)										
Zinc (Total)										
pH										
No Reporting Requirements					No Discharge Violations			No Enforcement Actions		

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Residence Inn by Marriott 300 Presidential Way Woburn, MA 01801 #: 43404861 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Rohrstein Corporation 70 Olympia Avenue Woburn, MA 01801 #: 43000378 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Signal Communications Corporation 4 Wheeling Avenue Woburn, MA 01801 #: 43101480 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Solid Energy Systems LLC 34 Commerce Way Suite A&B Woburn, MA 01801 #: 43409902 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Solid Energy Systems, Inc. 35 -B Cabot Road Woburn, MA 01801 #: 43405119 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Something Sweet Without Wheat 19 Sixth Road Woburn, MA 01801 #: 43404233 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sonesta Select Boston Woburn 240 Mishawum Road Woburn, MA 01801 #: 43101815 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Throne Depot 25 Republic Road North Billerica, MA 01862 #: 43403481 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tufts Dental and Lennon Dental Group LLC 620 Main Street Woburn, MA 01801 #: 43406320 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Verdoux Inc. 1 -B Gill Street Woburn, MA 01801 #: 43408453 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2023 and 06/30/2024

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Woburn Dental Associates 26 Warren Avenue Woburn, MA 01801 #: 43406314 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Woburn Dental Group, PC 109 Montvale Avenue Woburn, MA 01801 #: 43406310 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Woburn Family Dental 5 Cummings Park Drive Woburn, MA 01801 #: 43406319 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Woburn Hospitality LLC 14 Hill Street Woburn, MA 01801 #: 43404753 Category: 02	0101	LAUNDRY ROOM			No Discharge Violations		06-Feb-2024	Notice of Noncompliance
	Semi-Annual Self-Monitoring							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						

Appendix C

Significant Industrial Users In Significant Noncompliance

Summary of Industries in SNC for Violations

Between 04/01/2023 and 06/30/2024

SIU Status: Y

Bedford

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
03103701	Y	Cubic PV, Inc.	1-Jul-23 31-Dec-23	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
03403799	Y	Entegris, Inc.	1-Oct-23 31-Mar-24	B	B. Discharge - TRC Violation - 33% +
			1-Jan-24 30-Jun-24	B	B. Discharge - TRC Violation - 33% +
03103123	Y	Thermo Fisher Scientific	1-Oct-23 31-Mar-24	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
			1-Jan-24 30-Jun-24	B	B. Discharge - TRC Violation - 33% +

Boston (Dwntn)

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
45005703	Y	Beth Israel Deaconess Medical Center	1-Jul-23 31-Dec-23	B	B. Discharge - TRC Violation - 33% +
45006015	Y	Boston University Medical Campus	1-Apr-23 30-Sep-23	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
			1-Jul-23 31-Dec-23	B	B. Discharge - TRC Violation - 33% +
			1-Jan-24 30-Jun-24	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
45005962	Y	Harvard University - Longwood Campus	1-Apr-23 30-Sep-23	B	B. Discharge - TRC Violation - 33% +
45004825	Y	Trustees of Boston University-Charles River Campus	1-Oct-23 31-Mar-24	A	A. Discharge - Chronic Violation - 66% +
			1-Jan-24 30-Jun-24	A	A. Discharge - Chronic Violation - 66% +

Braintree

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
--------------------	------------	----------------------	---------------	------------	------------------

Summary of Industries in SNC for Violations

Between 04/01/2023 and 06/30/2024

SIU Status: Y

Braintree

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
06409245	Y	Life Instruments Corporation	1-Apr-23 30-Sep-23	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
06102545	Y	Ryder Transportation Services	1-Jan-24 30-Jun-24	B	B. Discharge - TRC Violation - 33% +

Brighton

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
46005935	Y	Steward St. Elizabeth's Medical Center	1-Oct-23 31-Mar-24	B	B. Discharge - TRC Violation - 33% +
				F3	F3. Reporting - Self-Monitoring SNC Late or Missing
			1-Jan-24 30-Jun-24	B	B. Discharge - TRC Violation - 33% +

Cambridge

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
09403820	Y	Alnylam Pharmaceuticals, Inc.	1-Apr-23 30-Sep-23	B	B. Discharge - TRC Violation - 33% +
			1-Jul-23 31-Dec-23	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +

Dorchester

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
48100569	Y	University of Massachusetts, Boston	1-Apr-23 30-Sep-23	B	B. Discharge - TRC Violation - 33% +
			1-Jul-23 31-Dec-23	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
			1-Oct-23 31-Mar-24	B	B. Discharge - TRC Violation - 33% +

Summary of Industries in SNC for Violations

Between 04/01/2023 and 06/30/2024

SIU Status: Y

Everett

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
13006291	Y	Hi-Tech Plating/The Tinning Company	1-Jan-24 30-Jun-24	A B	A. Discharge - Chronic Violation - 66% + B. Discharge - TRC Violation - 33% +
13000351	Y	The Leavitt Corporation	1-Jul-23 31-Dec-23	A B	A. Discharge - Chronic Violation - 66% + B. Discharge - TRC Violation - 33% +

Framingham

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
14005736	Y	Metrowest Medical Center - Framingham Union Hospital	1-Oct-23 31-Mar-24	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
14102115	Y	P.P. Manufacturing Corporation	1-Oct-23 31-Mar-24	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

Jamaica Plain

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
51005715	Y	Brigham & Women's Faulkner Hospital	1-Oct-23 31-Mar-24	B	B. Discharge - TRC Violation - 33% +
51102177	Y	MBTA - Arborway Maintenance	1-Apr-23 30-Sep-23	B	B. Discharge - TRC Violation - 33% +

Lexington

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
17100088	Y	M.I.T. Lincoln Laboratory	1-Apr-23 30-Sep-23	B	B. Discharge - TRC Violation - 33% +

Summary of Industries in SNC for Violations

Between 04/01/2023 and 06/30/2024

SIU Status: Y

Milton

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
21006031	Y	Beth Israel Deaconess Hospital-Milton Inc.	1-Apr-23 30-Sep-23	B	B. Discharge - TRC Violation - 33% +
				F3	F3. Reporting - Self-Monitoring SNC Late or Missing
			1-Jan-24 30-Jun-24	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +

Needham

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
23002853	Y	Fortune Metal Finishing Corp.	1-Jan-24 30-Jun-24	B	B. Discharge - TRC Violation - 33% +
23002892	Y	Microwave Development Labs, Inc.	1-Jan-24 30-Jun-24	B	B. Discharge - TRC Violation - 33% +

Norwood

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
25101050	Y	Goldman Kolber, LLC (GK Jewelry Inc.)	1-Apr-23 30-Sep-23	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
			1-Oct-23 31-Mar-24	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

Somerville

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
30103290	Y	Century Linen East LLC	1-Apr-23 30-Sep-23	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

South Boston

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
--------------------	------------	----------------------	---------------	------------	------------------

Summary of Industries in SNC for Violations

Between 04/01/2023 and 06/30/2024

SIU Status: Y

South Boston

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
55103065	Y	Massachusetts Department of Transportation (S.Bos VB #1&5)	1-Apr-23 30-Sep-23	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

Waltham

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
35004157	Y	Giner, Inc.	1-Apr-23 30-Sep-23	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
				F3	F3. Reporting - Self-Monitoring SNC Late or Missing
			1-Jul-23 31-Dec-23	B	B. Discharge - TRC Violation - 33% +
			1-Oct-23 31-Mar-24	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

West Roxbury

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
56005702	Y	VA Boston Healthcare System	1-Jul-23 31-Dec-23	B	B. Discharge - TRC Violation - 33% +
			1-Oct-23 31-Mar-24	B	B. Discharge - TRC Violation - 33% +

Weymouth

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
39102335	Y	Great Pond Water Treatment Plant	1-Apr-23 30-Sep-23	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
			1-Oct-23 31-Mar-24	A	A. Discharge - Chronic Violation - 66% +
				F3	F3. Reporting - Self-Monitoring SNC Late or Missing
			1-Jan-24 30-Jun-24	A	A. Discharge - Chronic Violation - 66% +

Summary of Industries in SNC for Violations

Between 04/01/2023 and 06/30/2024

SIU Status: Y

Weymouth

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
				F3	F3. Reporting - Self-Monitoring SNC Late or Missing

Wilmington

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
40004688	Y	Covestro, LLC	1-Apr-23 30-Sep-23	B	B. Discharge - TRC Violation - 33% +
			1-Jul-23 31-Dec-23	B	B. Discharge - TRC Violation - 33% +

SNC A Count:	14
SNC B Count:	33
SNC E Count:	0
SNC F Count:	14
SNC H Count:	0

Appendix D

Former Significant Industrial Users

SIU's In Previous Fiscal Year

These Industries Were SIU's in FY 2023 But Not in FY 2024

<u>FACILITY</u>	<u>IND_NAME</u>	<u>Address</u>	<u>Reason Deleted</u>
03004344	N2 Biomedical, LLC	One Patriots Park Bedford, MA 01730	433
14404514	Boston Heart Diagnostics	175 Crossing Boulevard Suite 100 Framingham, MA 01702	Compliance achieved without pretreatment
16100468	Preferred Services Company, Inc.	52 Plymouth Street Holbrook, MA 02343	Flow no longer greater than 25,000gpd. Average daily
19000222	Boston Group	400 Riverside Avenue Medford, MA 02155	OOB
25102934	TE Connectivity	63 Nahatan Street Norwood, MA 02062	TE Connectivity is an SIU, regulated by 40 CFR 433 fo
32406522	Plain Street Water Treatment Plant	742 Plain Street Stoughton, MA 02072	Flow is now <25k
43003757	Aero Brazing Corp.	223 New Boston Street Woburn, MA 01801	OOB OOB

Appendix E

Gas/Oil Separator Warning Letters



TRAPS Enforcement Actions Between Dates

Enforcement Actions Between 7/1/2023 6/30/2024

Newton

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Enforcement Date</u>
Newton	Newton South High School	140 Brandeis Road	24301081	WARN	07/12/2023

Quincy

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Enforcement Date</u>
Quincy	South Shore Car Wash	384 Centre Street	26301269	WARN	07/18/2023
Quincy	JN Auto Service Inc	250 Centre Street	26403402	WARN	07/24/2023
Quincy	Liberty St Automotive Services	15 Liberty Street	26301365	WARN	07/28/2023
Quincy	C&L Auto Body	45 Copeland Street	26301276	WARN	08/16/2023
Quincy	Parkway Mobil	1269 Furnace Brook Parkway	26301289	WARN	08/22/2023
Quincy	Quincy Fire Station #2	311 Hancock Street	26301297	WARN	08/24/2023
Quincy	Quincy Fire Station Engine 7	86 Huckins Avenue	26301309	WARN	08/25/2023
Quincy	Sullivan Tire	1132 Hancock Street	26301305	WARN	09/12/2023

Randolph

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Enforcement Date</u>
Randolph	AutoTuner	146 S Main Street	27403254	WARN	09/20/2023
Randolph	Exquisite Autobody/Randolph Center Autobody	90 Pleasant Street	27300896	WARN	09/20/2023
Randolph	Jiffy Lube	26 Warren Street	27401653	WARN	10/16/2023

Reading

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Enforcement Date</u>
Reading	Rt 128 Honda	88 Walkers Brook Drive	28402621	WARN	09/28/2023

Revere

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Enforcement Date</u>
Revere	Master Auto Repair	1027 Broadway	29301393	WARN	11/13/2023
Revere	Squire Road Auto Service	184 Squire Road	29301405	WARN	11/20/2023
Revere	European Collision Works	787 North Shore Road	29401775	WARN	03/19/2024

Walpole

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Enforcement Date</u>
Walpole	Allegiance Trucks, Inc.	2181 Providence Highway	34300036	WARN	10/05/2023

Total Trap Enforcement Actions Per Report: 17

Appendix F

Penalties Assessed and Collected

Penalties Assessed and Collected

Between 7/1/2023 and 6/30/2024

SIU

<u>Facility ID</u>	<u>Company</u>	<u>Municipality</u>	<u>Amount Assessed</u>	<u>Amount Collected</u>
09003755	Harvard University - Cambridge Campus	Cambridge	\$30,100.00	\$30,100.00
32004859	Tradebe Treatment and Recycling of Stoughton, LLC	Stoughton		\$60,000.00
Totals:			\$30,100.00	\$90,100.00

Non-SIU

<u>Facility ID</u>	<u>Company</u>	<u>Municipality</u>	<u>Amount Assessed</u>	<u>Amount Collected</u>
45404976	Hotel Indigo Boston Garden	Boston (Dwntn)		\$10,000.00
45404976	Hotel Indigo Boston Garden	Boston (Dwntn)		\$10,000.00
45404976	Hotel Indigo Boston Garden	Boston (Dwntn)		\$10,000.00
45404976	Hotel Indigo Boston Garden	Boston (Dwntn)		\$10,000.00
25101808	Norwood Hospitality, LLC	Norwood	\$40,000.00	
Totals:			\$70,1000.00	\$40,000.00

Combined SIU & Non-SIU Totals: \$70,100.00 \$130,100.00

Appendix G

TRAC Staff

TRAC Staff

October 2024

Director's Office

Dam	Matthew	Director, TRAC
Johnson	Kenneth	Admin Coordinator

Field Operations & Permitting

Yarossi	Peter	Senior Program Manager
Vacant		Program Manager, Construction Permitting
McKenna	Kevin	Project Manager
Francesconi	Ralph	Project Manager
Vacant		Oil-Gas Separator Traps Inspector (Septage)
Cruz	Ramon	Oil-Gas Separator Traps Inspector (Septage)
Vacant		Oil-Gas Separator Traps Inspector (Septage)
Burns	Richard	Sr. Field Inspector, PC&PS
Winn	Harold	Sr. Field Inspector, Water/Wastewater
Vacant		Field Inspector, Water/Wastewater
Donlon	Sean	Field Inspector, Water/Wastewater

Enforcement/MIS

McGrath	Tracy	Senior Program Manager, Compliance
Halloran	Thomas	Project Manager, PIMS
McMann	Monica	Compliance Coordinator
Mastin	Jon	Compliance Coordinator
Vacant		Compliance Coordinator
Gerade	Scott	Compliance Coordinator
Meggison	Tori	Data Management Supervisor
Lanza	Chris	Administrative Systems Coordinator
Vacant		Records Coordinator

Inspections/Permitting

Vacant		Program Manager, Inspections and Permitting
Thomas	Kattia	Project Manager, Permitting
Simmerman	Keary	Project Manager, Inspections
Ng	Lanna	Industrial Coordinator
Heckmann	Timothy	Industrial Coordinator
Chapman	Lisa	Industrial Coordinator
Cunningham	Kenneth	Industrial Coordinator
Johnson	Emily	Industrial Coordinator
Riley	George	Industrial Coordinator
Mallon	Alexandria	Industrial Coordinator
Rounds	Molly	Industrial Coordinator
Capraro	Dennis	Industrial Coordinator

Sampling

Owen	Shawn	Program Manager, Monitoring
Rabideau	Robert	Sr. Sampling Associate
Barbaro	Paul	Sr. Sampling Associate
Pokuah	Ellen	Sampling Associate
D'Iorio	Michael	Sampling Associate
Harley	Julian	Sampling Associate
Vacant		Sampling Associate
Rodenhiser	Jason	Sampling Associate
Johnson	Alicia	Sampling Associate
Leuchte	Eric	Sampling Associate
Moscho	Michael	Sampling Associate
Blomerth	Erin	Sampling Associate
Upton	Michael	Sampling Associate
Guarente	Nicholas	Sampling Associate

Appendix H

Priority Pollutant Scan Results and Comparison of Influent and Effluent to Established Standards for Deer Island

Table H-1
Average Influent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Metals (ug/L)															
SILVER	0.113	0.203	0.123	0.383	0.342	0.302	0.136	0.0737	0.111	0.125	0.273	0.275	0.196	0.646	34 of 44
ALUMINUM	391	681	431	1040	744	734	490	465	493	200	487	293	515	1670	44 of 44
ARSENIC	0.4	0.895	0.472	0.751	0.4	1.45	0.525	0.4	0.942	0.4	0.4	0.4	0.595	1.45	13 of 44
BORON	125	125	125	125	125	125	125	125	125	125	125	125	125	125	0 of 44
BERYLLIUM	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0 of 44
CADMIUM		0.196	0.15	0.303	0.23	0.186	0.164	0.175	0.202	0.139	0.133	0.17	0.184	0.488	40 of 40
CHROMIUM	1.5	2.94	1.17	3.82	2.48	2.51	2.25	2.1	1.7	1.26	1.56	2.33	2.09	6.36	42 of 44
COPPER	29.5	30.1	32.5	84.7	72	46.5	11.8	23.5	34.4	22.7	30	40.4	36.4	115	41 of 44
IRON	1280	1510	1220	2510	2570	1990	1370	1090	1470	812	1180	1360	1470	4070	44 of 44
MERCURY	0.0502	0.0648	0.0232	0.1	0.148	0.0729	0.0387	0.0334	0.0293	0.0275	0.0503	1.01	0.129	1.09	33 of 44
MOLYBDENUM	5.13	3.62	4.44	5.86	9.55	4.87	2.69	3.09	6.36	3.81	7.3	9.85	5.41	11.7	44 of 44
NICKEL	2.76	1.43	1.52	2.67	2.58	2.57	1.07	0.913	2.23	0.731	1.01	1.32	1.67	4.2	40 of 44
LEAD	2.79	5.43	2.11	5.9	5.73	4.24	1.47	1.65	2.3	1.65	1.24	7.64	3.43	10.6	33 of 44
ANTIMONY	25	25	25	25	25	25	25	25	25	25	25	25	25	25	0 of 44
SELENIUM	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.834	0.48	1	3 of 44
THALLIUM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 44
ZINC	82.2	122	83.2	198	177	141	72.4	79.6	90.4	58.1	79	91.1	102	320	44 of 44
Cyanide (ug/L)															
CYANIDE	11.7	15.2	17.2	21.1	31	19.4	25.7	10	10	10	36.8	24.7	18.3	37.1	22 of 48
FOG and PHC (mg/L)															
PETROLEUM HYDROCARBONS	1.12	1.23	2.16	1.68	2.68	2.5	1.55	2.34	1.74	1.44	2.54	4.4	2.01	6.59	48 of 48
FATS OIL AND GREASE	24.9	19.5	20.5	17.2	28.8	22.1	15.6	164	23.3	16.5	24.3	30	33.9	312	46 of 46
Conventional Parameters (mg/L)															
BIOCHEMICAL OXYGEN DEMAND	92.2	93.5	100	144	196	114	88.9	118	92.9	79.5	157	186	116	305	636 of 642
CHEMICAL OXYGEN DEMAND	239	242	249	346	422	223	184	273	188	193	369	366	260	598	662 of 662
TOTAL SUSPENDED SOLIDS	117	113	112	175	181	112	84.8	114	89.9	93.3	195	227	127	428	645 of 645
Nutrients (mg/L)															
AMMONIA	23.6	21.8	22.1	30.3	37.1	19.8	14.7	27.6	21.1	18	29.3	28.6	23.2	40.8	104 of 104
NITRATE	0.463	0.317	0.404	0.667	0.242	0.726	1.09	0.145	0.165	0.222	0.207	0.515	0.465	2.14	94 of 104
NITRITE	0.699	0.293	0.301	0.236	0.151	0.254	0.255	0.183	0.198	0.22	0.149	0.335	0.267	0.766	101 of 104
TOTAL KJELDAHL NITROGEN	29.8	31.1	28.8	45.8	46.7	26.9	19.7	40.6	29	24.8	36.9	47.3	32	57	104 of 104
ORTHOPHOSPHATE	1.55	1.87	1.51	2.25	2.98	1.4	0.934	1.97	1.43	1.49	2.19	2.35	1.72	3.32	104 of 104
TOTAL PHOSPHORUS	3.63	2.92	2.95	4.79	5.45	2.91	1.86	4.23	2.78	2.56	4.34	4.89	3.37	6.18	104 of 104
Pesticides and PCBs (ug/L)															
4,4'-DDD	0.000502	0.000558	0.000491	0.00485	0.0555	0.047	0.0047	0.00628	0.000495	0.000499	0.000488	0.000509	0.00706	0.105	2 of 44
4,4'-DDE	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
4,4'-DDT	0.000502	0.000558	0.000491	0.00485	0.0555	0.047	0.0047	0.00628	0.000495	0.000499	0.000488	0.000509	0.00706	0.105	2 of 44
ALDRIN	0.000502	0.000558	0.000491	0.00485	0.0555	0.047	0.0047	0.00628	0.000495	0.000499	0.000488	0.000509	0.00706	0.105	2 of 44
ALPHA-BHC	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
ALPHA-CHLORDANE	0.00189	0.00515	0.0063	0.00485	0.0555	0.047	0.0047	0.00628	0.00121	0.00125	0.00143	0.00131	0.00847	0.105	14 of 44
AROCLOR-1016	0.0251	0.0279	0.0246	0.00485	0.005	0.047	0.0047	0.00635	0.0248	0.025	0.0244	0.0255	0.0204	0.047	2 of 44
AROCLOR-1221	0.0502	0.0558	0.0491	0.00485	0.005	0.047	0.0047	0.00635	0.0495	0.0499	0.0488	0.0509	0.0374	0.0678	2 of 44
AROCLOR-1232	0.0251	0.0279	0.0246	0.00485	0.005	0.047	0.0047	0.00635	0.0248	0.025	0.0244	0.0255	0.0204	0.047	2 of 44
AROCLOR-1242	0.0251	0.0279	0.0246	0.00485	0.005	0.047	0.0047	0.00635	0.0248	0.025	0.0244	0.0255	0.0204	0.047	2 of 44
AROCLOR-1248	0.0251	0.0279	0.0246	0.00485	0.005	0.047	0.0047	0.00635	0.0248	0.025	0.0244	0.0255	0.0204	0.047	2 of 44

Table H-1
Average Influent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Pesticides and PCBs (ug/L) (cont.)															
AROCOR-1254	0.0251	0.0279	0.0246	0.00485	0.005	0.047	0.0047	0.00635	0.0248	0.025	0.0244	0.0255	0.0204	0.047	2 of 44
AROCOR-1260	0.0251	0.0279	0.0246	0.00485	0.005	0.047	0.0047	0.00635	0.0248	0.025	0.0244	0.0255	0.0204	0.047	2 of 44
BETA-BHC	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
CHLORDANE (TECHNICAL)	0.0502	0.0558	0.0491	0.024	0.288	0.23	0.023	0.0317	0.0495	0.0499	0.0488	0.0509	0.068	0.548	2 of 44
DELTA-BHC	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
DIELDRIN	0.000402	0.00113	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00707	0.105	3 of 44
ENDOSULFAN I	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
ENDOSULFAN II	0.000502	0.000558	0.000491	0.00485	0.0555	0.047	0.0047	0.00628	0.000495	0.000499	0.000488	0.000509	0.00706	0.105	2 of 44
ENDOSULFAN SULFATE	0.000502	0.000558	0.000491	0.00485	0.0555	0.047	0.0047	0.00628	0.000495	0.000499	0.000488	0.000509	0.00706	0.105	2 of 44
ENDRIN	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
ENDRIN ALDEHYDE	0.000502	0.000558	0.000491	0.00485	0.0555	0.047	0.0047	0.00628	0.000495	0.000499	0.000488	0.000509	0.00706	0.105	2 of 44
ENDRIN KETONE	0.000502	0.000558	0.000491	0.00485	0.0555	0.047	0.0047	0.00628	0.000495	0.000499	0.000488	0.000509	0.00706	0.105	2 of 44
GAMMA-BHC	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
GAMMA-CHLORDANE	0.00099	0.0025	0.00112	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.00135	0.000407	0.00742	0.105	6 of 44
HEPTACHLOR	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
HEPTACHLOR EPOXIDE	0.000402	0.000447	0.000393	0.00485	0.0555	0.047	0.0047	0.00628	0.000396	0.000399	0.000391	0.000407	0.00699	0.105	2 of 44
HEXACHLOROBENZENE	~	~	~	~	~	~	~	~	0.000396	0.000402	0.000391	0.000407	0.000399	0.000418	0 of 14
METHOXYCHLOR	0.00502	0.00558	0.00491	0.0485	0.555	0.047	0.047	0.0628	0.00495	0.00499	0.00488	0.00509	0.0535	1.05	2 of 44
TOTAL AMP PCBs	~	0.0294	~	0.0114	~	0.00323	~	0.00244	~	0.00614	~	0.00552	0.0117	0.0766	20 of 20
TOXAPHENE	0.0502	0.0558	0.0491	0.097	1.11	0.94	0.094	0.124	0.0495	0.0499	0.0488	0.0509	0.168	2.11	2 of 44
Pesticides and PCBs (ug/L) - low detection limit methods															
2,4'-DDD	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
2,4'-DDE	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
2,4'-DDT	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
4,4'-DDD	~	0.00104	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000396	0.00146	1 of 20
4,4'-DDE	~	0.00156	~	0.000357	~	0.000655	~	0.000202	~	0.00185	~	0.00113	0.00116	0.00297	13 of 20
4,4'-DDT	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
ALDRIN	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
ALPHA-CHLORDANE	~	0.00453	~	0.00519	~	0.00335	~	0.00314	~	0.00327	~	0.00404	0.004	0.00528	20 of 20
BZ 101 PENTACHLOROBIPHENYL	~	0.0018	~	0.00142	~	0.000775	~	0.000202	~	0.000332	~	0.00148	0.00105	0.00354	17 of 20
BZ 105 PENTACHLOROBIPHENYL	~	0.000316	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000229	0.000543	1 of 20
BZ 118 PENTACHLOROBIPHENYL	~	0.005	~	0.000207	~	0.000533	~	0.000202	~	0.0005	~	0.000466	0.00145	0.0136	11 of 20
BZ 126 PENTACHLOROBIPHENYL	~	0.00692	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.00175	0.0203	1 of 20
BZ 128 HEXACHLOROBIPHENYL	~	0.000177	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.00032	0.000215	0.000434	2 of 20
BZ 138 HEXACHLOROBIPHENYL	~	0.00132	~	0.00437	~	0.000568	~	0.000944	~	0.000965	~	0.000815	0.00156	0.00461	20 of 20
BZ 153 HEXACHLOROBIPHENYL	~	0.00112	~	0.00364	~	0.000721	~	0.000566	~	0.000892	~	0.000845	0.00135	0.00384	20 of 20
BZ 170 HEPTACHLOROBIPHENYL	~	0.00154	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000509	0.00419	1 of 20
BZ 18 TRICHLOROBIPHENYL	~	0.00522	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.00135	0.0152	1 of 20
BZ 180 HEPTACHLOROBIPHENYL	~	0.000737	~	0.000292	~	0.000196	~	0.000202	~	0.000466	~	0.000672	0.000483	0.000838	11 of 20
BZ 187 HEPTACHLOROBIPHENYL	~	0.000497	~	0.00106	~	0.000181	~	0.000222	~	0.000324	~	0.000244	0.000452	0.00124	15 of 20
BZ 195 OCTACHLOROBIPHENYL	~	0.000238	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000211	0.000308	1 of 20
BZ 206 NONACHLOROBIPHENYL	~	0.000177	~	0.000207	~	0.000196	~	0.00026	~	0.0027	~	0.000209	0.000867	0.00459	5 of 20
BZ 209 DECACHLOROBIPHENYL	~	0.000618	~	0.000375	~	0.000145	~	0.000319	~	0.000201	~	0.000453	0.000372	0.000943	10 of 20
BZ 28 TRICHLOROBIPHENYL	~	0.000235	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000211	0.000301	1 of 20
BZ 44 TETRACHLOROBIPHENYL	~	0.000427	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000255	0.000873	1 of 20
BZ 52 TETRACHLOROBIPHENYL	~	0.0014	~	0.00055	~	0.000377	~	0.000274	~	0.000355	~	0.000647	0.000666	0.00299	20 of 20
BZ 66 TETRACHLOROBIPHENYL	~	0.00215	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.00065	0.00602	1 of 20
BZ 77 TETRACHLOROBIPHENYL	~	0.000846	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000351	0.00213	1 of 20
BZ 8 DICHLOROBIPHENYL	~	0.00069	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000315	0.00166	1 of 20

Table H-1
Average Influent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Pesticides and PCBs (ug/L) - low detection limit methods (cont.)															
CIS-NONACHLOR	~	0.00122	~	0.000974	~	0.000406	~	0.000513	~	0.00117	~	0.000516	0.000916	0.0019	18 of 20
DDMU	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
DIELDRIN	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
ENDRIN	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
GAMMA-BHC	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
GAMMA-CHLORDANE	~	0.00341	~	0.00337	~	0.00155	~	0.00152	~	0.012	~	0.0033	0.00534	0.0175	20 of 20
HEPTACHLOR	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
HEPTACHLOR EPOXIDE	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
HEXACHLOROBENZENE	~	0.00201	~	0.00343	~	0.00162	~	0.00136	~	0.000616	~	0.00112	0.00164	0.00394	20 of 20
MIREX	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
OXYCHLORDANE	~	0.000207	~	0.000207	~	0.000196	~	0.000202	~	0.000201	~	0.000209	0.000204	0.000219	0 of 20
TOTAL CHLORDANE	~	0.00827	~	0.0101	~	0.00558	~	0.00491	~	0.00713	~	0.00575	0.00732	0.0112	20 of 20
TOTAL DDT	~	0.00243	~	0.000357	~	0.000655	~	0.000202	~	0.00185	~	0.00113	0.00136	0.00321	13 of 20
TRANS-NONACHLOR	~	0.00373	~	0.00488	~	0.00223	~	0.00177	~	0.00387	~	0.00171	0.00333	0.00637	20 of 20
Semivolatile Organics (ug/L)															
1,2,4-TRICHLOROBENZENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
1,2-DIPHENYLHYDRAZINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2,2'-OXYBIS(1-CHLOROPROPANE)	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2,4,5-TRICHLOROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2,4,6-TRICHLOROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2,4-DICHLOROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2,4-DIMETHYLPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2,4-DINITROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2,4-DINITROTOLUENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2,6-DINITROTOLUENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2-CHLORONAPHTHALENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2-CHLOROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2-METHYL-4,6-DINITROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2-METHYLNAPHTHALENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2-METHYLPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2-NITROANILINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
2-NITROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
3,3'-DICHLOROBENZIDINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
3-NITROANILINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
4-BROMOPHENYL PHENYL ETHER	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
4-CHLORO-3-METHYLPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
4-CHLOROANILINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
4-CHLOROPHENYL PHENYL ETHER	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
4-METHYLPHENOL	1.97	2.04	1.94	2	37.9	1.97	1.94	2.32	1.96	2.03	12.6	16.1	6.34	47.2	7 of 44
4-NITROANILINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
4-NITROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
ACENAPHTHENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
ACENAPHTHYLENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
ANILINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44

Table H-1
Average Influent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Semivolatile Organics (ug/L)															
ANTHRACENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BENZIDINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BENZO(A)ANTHRACENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BENZO(A)PYRENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BENZO(B)FLUORANTHENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BENZO(G,H,I)PERYLENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BENZO(K)FLUORANTHENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BENZOIC ACID	13.1	13.4	39.4	37.3	139	42.3	17.3	2.32	83.5	14.2	88	104	46.3	150	30 of 44
BENZYL ALCOHOL	1.97	8.43	1.94	7.93	33.7	1.97	7.54	2.32	15.4	2.03	22.7	28	10.8	43	15 of 44
BIS(2-CHLOROETHOXY)METHANE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BIS(2-CHLOROETHYL)ETHER	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BIS(2-ETHYLHEXYL)PHTHALATE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
BUTYLBENZYLPHTHALATE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
CARBAZOLE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
CHRYSENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
DIBENZO(A,H)ANTHRACENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
DIBENZOFURAN	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
DIETHYLPHTHALATE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
DIMETHYLPHTHALATE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
DI-N-BUTYLPHTHALATE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
DI-N-OCTYLPHTHALATE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
FLUORANTHENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
FLUORENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
HEXACHLOROBENZENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
HEXACHLOROBUTADIENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
HEXACHLOROCYCLOPENTADIENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
HEXACHLOROETHANE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
INDENO(1,2,3-CD)PYRENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
ISOPHORONE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
NAPHTHALENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
N-DECANE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
NITROBENZENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
N-NITROSODIMETHYLAMINE (NDMA)	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
N-NITROSODI-N-PROPYLAMINE (NDPA)	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
N-NITROSODIPHENYLAMINE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
N-OCTADECANE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
PENTACHLOROPHENOL	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
PHENANTHRENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
PHENOL	1.97	2.04	1.94	2	20.2	1.97	1.94	2.32	1.96	2.03	2.01	1.99	3.22	25.9	3 of 44
PYRENE	1.97	2.04	1.94	2	1.96	1.97	1.94	2.32	1.96	2.03	2.01	1.99	2	2.32	0 of 44
Polyaromatic Hydrocarbons - low detection limit methods															
1-METHYLNAPHTHALENE	~	0.0617	~	0.0468	~	0.0361	~	0.048	~	0.0262	~	0.0286	0.0412	0.0635	20 of 20
1-METHYLPHENANTHRENE	~	0.0148	~	0.0262	~	0.00992	~	0.00947	~	0.0133	~	0.0153	0.0154	0.0308	20 of 20
2,3,5-TRIMETHYLNAPHTHYLENE	~	0.0192	~	0.0283	~	0.0105	~	0.0163	~	0.0153	~	0.0131	0.0177	0.0303	20 of 20
2,6-DIMETHYLNAPHTHALENE	~	0.025	~	0.0458	~	0.0184	~	0.0286	~	0.0265	~	0.0314	0.0297	0.054	20 of 20
2-METHYLNAPHTHALENE	~	0.0585	~	0.0482	~	0.0384	~	0.0424	~	0.0311	~	0.0304	0.0419	0.0663	20 of 20
ACENAPHTHENE	~	0.051	~	0.0552	~	0.0373	~	0.0389	~	0.0364	~	0.0398	0.0438	0.0573	20 of 20
ACENAPHTHYLENE	~	0.0134	~	0.0291	~	0.0127	~	0.0164	~	0.0312	~	0.0184	0.0218	0.0368	20 of 20

Table H-1
Average Influent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Polyaromatic Hydrocarbons - low detection limit methods (cont.)															
ANTHRACENE	~	0.0175	~	0.0298	~	0.0123	~	0.00814	~	0.0134	~	0.0233	0.018	0.034	20 of 20
BENZO(A)ANTHRACENE	~	0.0335	~	0.048	~	0.0144	~	0.00689	~	0.0227	~	0.0337	0.0289	0.0603	20 of 20
BENZO(A)PYRENE	~	0.0327	~	0.0413	~	0.0138	~	0.00904	~	0.0285	~	0.0274	0.0283	0.0522	20 of 20
BENZO(B)FLUORANTHENE	~	0.0477	~	0.0605	~	0.0233	~	0.0112	~	0.0295	~	0.0371	0.0377	0.0794	20 of 20
BENZO(E)PYRENE	~	0.029	~	0.0352	~	0.0107	~	0.00584	~	0.022	~	0.0233	0.0235	0.044	20 of 20
BENZO(G,H,I)PERYLENE	~	0.0267	~	0.0611	~	0.0334	~	0.00706	~	0.0247	~	0.00819	0.0276	0.0754	17 of 20
BENZO(K)FLUORANTHENE	~	0.0126	~	0.0148	~	0.00421	~	0.00274	~	0.00593	~	0.00702	0.00866	0.0171	20 of 20
BENZOTHAZOLE	~	0.317	~	0.34	~	0.328	~	0.431	~	1.85	~	0.504	0.768	1.9	20 of 20
BIPHENYL	~	0.0107	~	0.0113	~	0.0072	~	0.0088	~	0.00729	~	0.00772	0.00896	0.0126	20 of 20
C1-CHRYSENES	~	0.0378	~	0.0483	~	0.017	~	0.0103	~	0.0153	~	0.0248	0.0271	0.0573	19 of 20
C1-DIBENZOTHIOPHENES	~	0.0345	~	0.0606	~	0.0265	~	0.0186	~	0.0411	~	0.042	0.0395	0.0622	20 of 20
C1-FLUORANTHENES/PYRENES	~	0.0248	~	0.0501	~	0.021	~	0.0112	~	0.0255	~	0.0339	0.029	0.0642	19 of 20
C1-FLUORENES	~	0.0531	~	0.0689	~	0.0358	~	0.038	~	0.0493	~	0.0765	0.0555	0.0778	20 of 20
C1-NAPHTHALENES	~	0.0698	~	0.0558	~	0.0434	~	0.0549	~	0.0324	~	0.0366	0.0487	0.0751	20 of 20
C1-PHENANTHRENES/ANTHRACENES	~	0.0577	~	0.192	~	0.0416	~	0.122	~	0.065	~	0.0752	0.09	0.286	20 of 20
C2-CHRYSENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.000501	~	0.000521	0.000511	0.000547	0 of 20
C2-DIBENZOTHIOPHENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.000501	~	0.000521	0.000511	0.000547	0 of 20
C2-FLUORANTHENES/PYRENES	~	0.0129	~	0.0225	~	0.00889	~	0.00446	~	0.0089	~	0.0115	0.012	0.0279	19 of 20
C2-FLUORENES	~	0.0747	~	0.135	~	0.0649	~	0.0499	~	0.0551	~	0.0805	0.0773	0.142	20 of 20
C2-NAPHTHALENES	~	0.0638	~	0.0946	~	0.0412	~	0.0686	~	0.0474	~	0.0436	0.0601	0.0965	20 of 20
C2-PHENANTHRENES/ANTHRACENES	~	0.0357	~	0.0627	~	0.0222	~	0.024	~	0.0301	~	0.0332	0.0361	0.0705	20 of 20
C3-CHRYSENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.000501	~	0.000521	0.000511	0.000547	0 of 20
C3-DIBENZOTHIOPHENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.0019	~	0.000521	0.000883	0.00344	2 of 20
C3-FLUORANTHENES/PYRENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.000501	~	0.000521	0.000511	0.000547	0 of 20
C3-FLUORENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.00134	~	0.000521	0.000732	0.0021	1 of 20
C3-NAPHTHALENES	~	0.0496	~	0.0722	~	0.0281	~	0.0562	~	0.046	~	0.0402	0.0498	0.074	20 of 20
C3-PHENANTHRENES/ANTHRACENES	~	0.0325	~	0.192	~	0.0411	~	0.0712	~	0.127	~	0.0857	0.0971	0.378	15 of 20
C4-CHRYSENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.000501	~	0.000521	0.000511	0.000547	0 of 20
C4-NAPHTHALENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.000501	~	0.000521	0.000511	0.000547	0 of 20
C4-PHENANTHRENES/ANTHRACENES	~	0.000518	~	0.000518	~	0.00049	~	0.000506	~	0.000501	~	0.000521	0.000511	0.000547	0 of 20
CHRYSENE	~	0.0432	~	0.0567	~	0.0158	~	0.0102	~	0.0249	~	0.0313	0.0332	0.0703	20 of 20
DIBENZO(A,H)ANTHRACENE	~	0.00452	~	0.000518	~	0.00049	~	0.00119	~	0.00235	~	0.0062	0.00288	0.00767	10 of 20
DIBENZOFURAN	~	0.0149	~	0.0255	~	0.0118	~	0.0146	~	0.0122	~	0.0182	0.0162	0.0272	20 of 20
DIBENZOTHIOPHENE	~	0.0147	~	0.0209	~	0.0102	~	0.00854	~	0.00912	~	0.0134	0.0131	0.0235	20 of 20
FLUORANTHENE	~	0.0867	~	0.134	~	0.0454	~	0.0266	~	0.0536	~	0.0854	0.0763	0.166	20 of 20
FLUORENE	~	0.0327	~	0.0429	~	0.0224	~	0.0269	~	0.0225	~	0.0335	0.0304	0.0433	20 of 20
INDENO(1,2,3-CD)PYRENE	~	0.0891	~	0.287	~	0.127	~	0.106	~	0.0375	~	0.092	0.114	0.288	20 of 20
NAPHTHALENE	~	0.121	~	0.085	~	0.0933	~	0.0923	~	0.0668	~	0.0698	0.0875	0.145	20 of 20
PERYLENE	~	0.0153	~	0.0286	~	0.0146	~	0.0242	~	0.0128	~	0.0137	0.0174	0.0299	20 of 20
PHENANTHRENE	~	0.103	~	0.163	~	0.0637	~	0.0619	~	0.0721	~	0.121	0.1	0.188	20 of 20
PYRENE	~	0.0771	~	0.145	~	0.0497	~	0.0275	~	0.0518	~	0.0772	0.0745	0.179	20 of 20
Volatile Organics (ug/L)															
1,1,1-TRICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,1,2,2-TETRACHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,1,2-TRICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,1-DICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,1-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,2-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48

Table H-1
Average Influent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Volatile Organics (ug/L) (cont.)															
1,2-DICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,2-DICHLOROPROPANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,3-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,4-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
2-BUTANONE	3.72	1.54	4.52	2.48	4.53	2.88	0.5	0.5	0.5	0.5	2.17	0.5	1.79	6.62	15 of 48
2-CHLOROETHYL VINYL ETHER	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
2-HEXANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
4-METHYL-2-PENTANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
ACETONE	166	270	119	114	98.8	172	149	193	209	81.5	796	98.2	209	1250	48 of 48
ACROLEIN	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0 of 48
ACRYLONITRILE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
BENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
BROMODICHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
BROMOFORM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
BROMOMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CARBON DISULFIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CARBON TETRACHLORIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CHLOROFORM	0.5	1.72	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.635	3.57	1 of 48
CHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CIS-1,2-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CIS-1,3-DICHLOROPROPENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
DIBROMOCHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
ETHYLBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
M,P-XYLENE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0 of 48
METHYLENE CHLORIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
O-XYLENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
STYRENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
TETRACHLOROETHENE	2.75	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	3.2	2.08	0.993	5.18	3 of 48
TOLUENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	3.94	0.733	7.37	1 of 48
TRANS-1,2-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
TRANS-1,3-DICHLOROPROPENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
TRICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
TRICHLOROFLUOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
VINYL ACETATE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
VINYL CHLORIDE	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0 of 48

Notes: Where parameters were below detection levels, one half of the method detection limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations.

The annual average concentration is the flow-weighted average of all data points. The maximum concentration is the highest concentration observed in the monitoring year.

Pesticides and PCBs** and Polyaromatic Hydrocarbons** tested with more sensitive methods which are not EPA-approved for permit compliance.

~ No data

Table H-2
Comparison of Treatment Plant Influent With Threshold Inhibition Levels
Deer Island Treatment Plant Data - Fiscal Year 2024

Parameter	EPA Inhibition Levels		Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
	Activated Sludge	Anaerobic Digestion												
	(ug/L)	(ug/L)												
Average Concentration (ug/L)														
Arsenic	100	1600	0.4	0.895	0.472	0.751	0.4	1.45	0.525	0.4	0.942	0.4	0.4	0.4
Cadmium	1000	20000		0.196	0.15	0.303	0.23	0.186	0.164	0.175	0.202	0.139	0.133	0.17
Chromium	1000	130000	1.5	2.94	1.17	3.82	2.48	2.51	2.25	2.1	1.7	1.26	1.56	2.33
Copper	1000	40000	29.5	30.1	32.5	84.7	72	46.5	11.8	23.5	34.4	22.7	30	40.4
Cyanide	100	4000	11.7	15.2	17.2	21.1	31	19.4	25.7	10	10	10	36.8	24.7
Lead	100	340000	2.79	5.43	2.11	5.9	5.73	4.24	1.47	1.65	2.3	1.65	1.24	7.64
Mercury	100	NA	0.0502	0.0648	0.0232	0.1	0.148	0.0729	0.0387	0.0334	0.0293	0.0275	0.0503	1.01
Nickel	1000	10000	2.76	1.43	1.52	2.67	2.58	2.57	1.07	0.913	2.23	0.731	1.01	1.32
Silver	250	13000	0.113	0.203	0.123	0.383	0.342	0.302	0.136	0.0737	0.111	0.125	0.273	0.275
Zinc	300	400000	82.2	122	83.2	198	177	141	72.4	79.6	90.4	58.1	79	91.1

Values that are bold and underlined are inhibition level exceedances

NA No Applicable Criteria

Table H-3
Average Effluent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Metals (ug/L)															
SILVER	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	2 of 48
ALUMINUM	42.6	42.5	37.8	30.1	38.3	41.9	18.9	31.5	165.0	93.9	45.0	39.2	58.7	302.0	41 of 48
ARSENIC	0.4	0.4	0.4	0.4	0.4	1.7	0.4	0.4	0.4	0.4	0.4	0.4	0.5	1.9	2 of 24
BORON	125	125	125	125	125	125	125	125	125	125	125	125	125	125	0 of 24
BERYLLIUM	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0 of 24
CADMIUM	0.02	0.0186	0.0205	0.015	0.019	0.0361	0.0417	0.0344	0.091	0.0746	0.015	0.0302	0.0396	0.12	21 of 48
CHROMIUM	0.447	0.35	0.35	0.35	0.35	0.35	0.35	0.888	0.804	0.591	0.35	0.35	0.486	1.24	8 of 48
COPPER	3.43	3.97	4.55	3.36	4.64	5.88	4.38	5.72	6.43	5.85	4.18	4.59	4.88	8.57	48 of 48
IRON	237	301	243	201	354	185	177	222	475	271	296	301	277	687	24 of 24
MERCURY	0.00278	0.00544	0.00224	0.00247	0.0029	0.00333	0.00286	0.00338	0.00507	0.00632	0.00494	0.0056	0.0042	0.0101	48 of 48
MOLYBDENUM	5.48	4.32	4.28	3.95	5.38	5.16	3.67	4.3	5.09	3.01	5.34	5.47	4.48	6.97	48 of 48
NICKEL	2.25	1.24	1.8	1.39	1.36	2.18	0.35	0.35	1.52	0.463	0.35	0.689	1.09	3.76	29 of 48
LEAD	0.474	0.744	0.505	0.509	0.525	0.54	0.526	0.565	1.63	1.15	0.536	0.533	0.755	2.73	15 of 48
ANTIMONY	25	25	25	25	25	25	25	25	25	25	25	25	25	25	0 of 24
SELENIUM	0.45	0.45	0.45	0.45	0.45		0.45	0.45	0.45	0.45	0.45	0.779	0.474	1.11	1 of 22
THALLIUM	0.5	0.5	0.5	0.5	0.5	0.5	0.698	0.5	0.5	0.5	0.5	0.5	0.525	1	0 of 25
ZINC	18.7	17.4	13.8	15.4	15.6	17.6	14.6	22.2	32	29.5	14.3	17	20.5	43.4	49 of 49
Cyanide (ug/L)															
CYANIDE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	0 of 23
FOG and PHC (mg/L)															
PETROLEUM HYDROCARBON	0.368	0.37	0.356	0.42	0.346	1.23	0.351	0.372	0.359	0.35	0.371	0.354	0.457	3.53	1 of 63
FATS OIL AND GREASE	0.06	0.0593	0.059	0.06	0.0577	0.423	0.0499	0.231	0.0584	0.0579	1.05	0.326	0.19	4.4	5 of 64
Conventional Parameters (mg/L)															
BIOCHEMICAL OXYGEN DEMAND	12.1	12.4	12.4	16.1	16.4	17	20	21.4	17.6	19.5	17.8	18.5	16.9	62.7	352 of 353
CHEMICAL OXYGEN DEMAND	56.5	54.6	52.5	65.9	76	55.2	54.6	73.6	59.6	48.5	64.6	71.5	59.6	118	365 of 365
TOTAL SUSPENDED SOLIDS	8.51	8.24	7.72	7.81	8.14	10.8	13.7	16.8	12	8.82	11	10.3	10.5	48	368 of 368
Nutrients (mg/L)															
AMMONIA	21.4	19.6	22.3	26.5	31.8	20	15.4	23.5	18.1	13	26.4	26.4	21	40.9	89 of 89
NITRATE	0.623	0.774	0.216	0.503	0.434	1.4	0.83	1.06	0.347	0.478	0.41	0.826	0.661	2.86	64 of 64
NITRITE	0.591	0.468	0.461	0.426	0.396	0.982	0.818	0.62	1.15	1.53	0.417	0.705	0.758	1.91	64 of 64
TOTAL KJELDAHL NITROGEN	19.9	22	25.2	28.4	34.2	20	16	27.2	20.2	17.3	27.2	29	22.9	39.6	65 of 65
ORTHOPHOSPHATE	1.32	1.65	1.4	2.13	2.35	1.08	0.758	1.69	0.833	0.758	1.36	1.93	1.33	2.9	52 of 52
TOTAL PHOSPHORUS	1.56	1.4	1.88	2.62	2.77	1.43	1.18	2.31	1.2	1.03	1.86	2.38	1.68	3.32	52 of 52
Pesticides and PCBs (ug/L)															
4,4'-DDD	0.000532	0.000495	0.0005	0.0047	0.005	0.0047	0.0047	0.005	0.0005	0.0005	0.000485	0.00049	0.00211	0.005	0 of 12
4,4'-DDE	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
4,4'-DDT	0.000532	0.000495	0.0005	0.0047	0.005	0.0047	0.0047	0.005	0.0005	0.0005	0.000485	0.00049	0.00211	0.005	0 of 12
ALDRIN	0.000532	0.000495	0.0005	0.0047	0.005	0.0047	0.0047	0.005	0.0005	0.0005	0.000485	0.00049	0.00211	0.005	0 of 12
ALPHA-BHC	0.000426	0.000396	0.0004	0.01	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00245	0.01	0 of 12
ALPHA-CHLORDANE	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
AROCLOR-1016	0.0266	0.0248	0.025	0.0047	0.005	0.0047	0.0047	0.005	0.025	0.025	0.0242	0.0242	0.0174	0.0266	0 of 12
AROCLOR-1221	0.0532	0.0495	0.05	0.0047	0.005	0.0047	0.0047	0.005	0.05	0.05	0.0485	0.0485	0.0331	0.0532	0 of 12
AROCLOR-1232	0.0266	0.0248	0.025	0.0047	0.005	0.0047	0.0047	0.005	0.025	0.025	0.0242	0.0242	0.0174	0.0266	0 of 12
AROCLOR-1242	0.0266	0.0248	0.025	0.0047	0.005	0.0047	0.0047	0.005	0.025	0.025	0.0242	0.0242	0.0174	0.0266	0 of 12
AROCLOR-1248	0.0266	0.0248	0.025	0.0047	0.005	0.0047	0.0047	0.005	0.025	0.025	0.0242	0.0242	0.0174	0.0266	0 of 12

**Average Effluent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Pesticides and PCBs (ug/L) (cont.)															
AROCOR-1254	0.0266	0.0248	0.025	0.0047	0.005	0.0047	0.0047	0.005	0.025	0.025	0.0242	0.0242	0.0174	0.0266	0 of 12
AROCOR-1260	0.0266	0.0248	0.025	0.0047	0.005	0.0047	0.0047	0.005	0.025	0.025	0.0242	0.0242	0.0174	0.0266	0 of 12
BETA-BHC	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
CHLORDANE (TECHNICAL)	0.0532	0.0495	0.05	0.023	0.025	0.023	0.023	0.025	0.05	0.05	0.0485	0.0485	0.0402	0.0532	0 of 12
DELTA-BHC	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
DIELDRIN	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
ENDOSULFAN I	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
ENDOSULFAN II	0.000532	0.000495	0.0005	0.0047	0.005	0.0047	0.0047	0.005	0.0005	0.0005	0.000485	0.00049	0.00211	0.005	0 of 12
ENDOSULFAN SULFATE	0.000532	0.000495	0.0005	0.0047	0.005	0.0047	0.0047	0.005	0.0005	0.0005	0.000485	0.00049	0.00211	0.005	0 of 12
ENDRIN	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
ENDRIN ALDEHYDE	0.000532	0.000495	0.0005	0.0047	0.005	0.0047	0.0047	0.005	0.0005	0.0005	0.000485	0.00049	0.00211	0.005	0 of 12
ENDRIN KETONE	0.000532	0.000495	0.0005	0.0047	0.005	0.0047	0.0047	0.005	0.0005	0.0005	0.000485	0.00049	0.00211	0.005	0 of 12
GAMMA-BHC	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
GAMMA-CHLORDANE	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
HEPTACHLOR	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
HEPTACHLOR EPOXIDE	0.000426	0.000396	0.0004	0.0047	0.005	0.0047	0.0047	0.005	0.0004	0.0004	0.000388	0.00039	0.00205	0.005	0 of 12
HEXACHLOROBENZENE	0.000426	0.000396	0.0004	0.0024	0.0025	0.0024	0.0047	0.0025	0.0004	0.0004	0.000388	0.00039	0.00135	0.0047	0 of 12
METHOXYCHLOR	0.00532	0.00495	0.005	0.047	0.05	0.047	0.047	0.05	0.005	0.005	0.00485	0.00485	0.0211	0.05	0 of 12
TOTAL AMP PCBs	0.00147	0.00159	0.000913	0.00085	0.000427	0.00053	0.00441	0.000791	0.000925	0.00141	0.000927	0.00086	0.00131	0.00485	48 of 48
TOXAPHENE	0.0532	0.0495	0.05	0.094	0.1	0.094	0.094	0.1	0.05	0.05	0.0485	0.0485	0.0673	0.1	0 of 12
Pesticides and PCBs (ug/L) - low detection limit methods															
2,4'-DDD	0.000102	0.0001	0.000101	0.0001	0.00012	0.00016	0.000168	0.000222	0.0000999	9.88E-05	0.00054	0.00128	0.000236	0.00219	21 of 48
2,4'-DDE	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	0.00016	0.000104	0.000249	2 of 48
2,4'-DDT	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000701	9.88E-05	0.0000993	9.9E-05	0.000163	0.00106	3 of 48
4,4'-DDD	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
4,4'-DDE	0.000138	0.000258	0.000239	0.0001	0.000103	0.00019	0.0000942	0.000099	0.000425	0.000305	0.000178	0.00019	0.00021	0.000497	27 of 48
4,4'-DDT	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
ALDRIN	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
ALPHA-CHLORDANE	0.000794	0.00102	0.000953	0.00101	0.000419	0.00049	0.000695	0.00109	0.000989	0.00146	0.00136	0.00128	0.00101	0.00183	48 of 48
BZ 101 PENTACHLOROBIPHENYL	0.000171	0.000202	0.000121	0.00012	8.74E-05	0.00014	0.000314	0.000202	0.000174	0.000901	0.000178	0.00019	0.000286	0.0031	45 of 48
BZ 105 PENTACHLOROBIPHENYL	0.000102	0.0001	0.000101	9.5E-05	0.000103	8.6E-05	0.000287	9.41E-05	0.0000999	9.88E-05	0.0000993	9.9E-05	0.000114	0.000309	8 of 48
BZ 118 PENTACHLOROBIPHENYL	0.000435	0.00038	0.0000633	8.1E-05	6.69E-05	8.5E-05	0.000228	6.99E-05	0.0000931	5.31E-05	0.000119	0.00016	0.000147	0.00086	40 of 48
BZ 126 PENTACHLOROBIPHENYL	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
BZ 128 HEXACHLOROBIPHENYL	6.98E-05	0.0001	0.000101	0.0001	8.78E-05	9.9E-05	0.000274	0.000099	0.0000999	9.88E-05	0.0000957	9.9E-05	0.000112	0.000319	8 of 48
BZ 138 HEXACHLOROBIPHENYL	0.000139	0.000196	0.000102	0.00014	0.000117	0.0001	0.000337	0.000125	0.000187	0.000177	0.000126	0.00012	0.000161	0.000352	48 of 48
BZ 153 HEXACHLOROBIPHENYL	0.000109	0.000167	0.0000932	0.00012	0.000119	8.2E-05	0.000331	0.000113	0.000185	0.00015	0.00012	0.00012	0.000147	0.000357	48 of 48
BZ 170 HEPTACHLOROBIPHENYL	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.000242	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	0.000112	0.000328	4 of 48
BZ 18 TRICHLOROBIPHENYL	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
BZ 180 HEPTACHLOROBIPHENYL	0.000102	0.000141	0.000101	0.0001	0.000103	9.9E-05	0.000287	0.000099	0.000129	0.000125	0.000125	0.00013	0.000131	0.000324	13 of 48
BZ 187 HEPTACHLOROBIPHENYL	6.04E-05	9.37E-05	0.0000764	9.4E-05	6.39E-05	7.8E-05	0.000295	5.69E-05	0.000111	7.16E-05	0.0000666	6.8E-05	0.000096	0.000333	35 of 48
BZ 195 OCTACHLOROBIPHENYL	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.000251	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	0.000113	0.000267	4 of 48
BZ 206 NONACHLOROBIPHENYL	0.000203	0.000174	0.000301	0.00014	0.000103	9.3E-05	0.000303	0.000099	0.00012	9.88E-05	0.0000993	9.9E-05	0.000149	0.000397	20 of 48
BZ 209 DECACHLOROBIPHENYL	0.000152	0.000204	0.000108	8.2E-05	0.000104	5.2E-05	0.000323	7.95E-05	0.0000924	9.88E-05	0.000107	9.9E-05	0.000126	0.000343	34 of 48
BZ 28 TRICHLOROBIPHENYL	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
BZ 44 TETRACHLOROBIPHENYL	0.000115	0.0001	0.000101	8.8E-05	0.000103	9.9E-05	0.000209	0.000114	0.0000999	9.88E-05	0.0000993	9.9E-05	0.00011	0.000243	15 of 48
BZ 52 TETRACHLOROBIPHENYL	9.42E-05	0.000144	0.0000962	8E-05	6.25E-05	6.7E-05	0.000168	8.64E-05	0.0000999	9.88E-05	0.000187	0.00015	0.000112	0.00024	40 of 48
BZ 66 TETRACHLOROBIPHENYL	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.000206	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	0.000109	0.000286	4 of 48
BZ 77 TETRACHLOROBIPHENYL	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.00035	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	0.000121	0.000395	4 of 48
BZ 8 DICHLOROBIPHENYL	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48

**Average Effluent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Pesticides and PCBs (ug/L) - low detection limit methods (cont.)															
CIS-NONACHLOR	8.94E-05	0.000113	0.0000824	8.8E-05	6.71E-05	9E-05	0.000103	0.00022	0.000237	0.000453	0.000133	0.00011	0.000177	0.000759	34 of 48
DDMU	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
DIELDRIN	0.000102	0.0001	0.000101	0.0001	0.000103	0.00037	0.000443	0.000655	0.0000999	9.88E-05	0.0000993	9.9E-05	0.000195	0.000837	10 of 48
ENDRIN	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
GAMMA-BHC	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
GAMMA-CHLORDANE	0.00126	0.000588	0.000538	0.00044	0.000103	9.9E-05	0.000221	0.000273	0.00123	0.00298	0.000765	0.0006	0.000942	0.00368	40 of 48
HEPTACHLOR	0.000147	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	0.000103	0.000274	3 of 48
HEPTACHLOR EPOXIDE	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
HEXACHLOROBENZENE	0.000209	0.000286	0.000259	0.00033	0.000302	0.00034	0.000184	0.0003	0.000555	0.00025	0.000395	0.0004	0.000319	0.000637	48 of 48
MIREX	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
OXYCHLORDANE	0.000102	0.0001	0.000101	0.0001	0.000103	9.9E-05	0.0000942	0.000099	0.0000999	9.88E-05	0.0000993	9.9E-05	9.97E-05	0.000108	0 of 48
TOTAL CHLORDANE	0.00122	0.00135	0.00139	0.00139	0.000675	0.00083	0.00104	0.00166	0.0016	0.00229	0.00165	0.00154	0.00147	0.00305	48 of 48
TOTAL DDT	0.000138	0.000258	0.000239	0.0001	0.00012	0.00028	0.000168	0.000222	0.0011	0.000305	0.000718	0.00159	0.000442	0.00229	39 of 48
TRANS-NONACHLOR	0.000303	0.000331	0.000435	0.00038	0.000256	0.00035	0.000347	0.000563	0.000609	0.000819	0.000287	0.00026	0.000451	0.00122	48 of 48
Semivolatile Organics (ug/L)															
1,2,4-TRICHLOROBENZENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
1,2-DIPHENYLHYDRAZINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2,2'-OXYBIS(1-CHLOROPROPANE)	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2,4,5-TRICHLOROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2,4,6-TRICHLOROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2,4-DICHLOROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2,4-DIMETHYLPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2,4-DINITROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2,4-DINITROTOLUENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2,6-DINITROTOLUENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2-CHLORONAPHTHALENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2-CHLOROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2-METHYL-4,6-DINITROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2-METHYLNAPHTHALENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2-METHYLPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2-NITROANILINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
2-NITROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
3,3'-DICHLOROBENZIDINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
3-NITROANILINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
4-BROMOPHENYL PHENYL ETHER	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
4-CHLORO-3-METHYLPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
4-CHLOROANILINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
4-CHLOROPHENYL PHENYL ETHER	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
4-METHYLPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
4-NITROANILINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
4-NITROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
ACENAPHTHENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
ACENAPHTHYLENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
ANILINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23

**Average Effluent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Semivolatile Organics (ug/L) (cont.)															
ANTHRACENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BENZIDINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BENZO(A)ANTHRACENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BENZO(A)PYRENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BENZO(B)FLUORANTHENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BENZO(G,H,I)PERYLENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BENZO(K)FLUORANTHENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BENZOIC ACID	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BENZYL ALCOHOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BIS(2-CHLOROETHOXY)METHANE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BIS(2-CHLOROETHYL)ETHER	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BIS(2-ETHYLHEXYL)PHTHALATE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
BUTYLBENZYLPHTHALATE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
CARBAZOLE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
CHRYSENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
DIBENZO(A,H)ANTHRACENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
DIBENZOFURAN	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
DIETHYLPHTHALATE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
DIMETHYLPHTHALATE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
DI-N-BUTYLPHTHALATE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
DI-N-OCTYLPHTHALATE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
FLUORANTHENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
FLUORENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
HEXACHLOROBENZENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
HEXACHLOROBUTADIENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
HEXACHLOROCYCLOPENTADIENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
HEXACHLOROETHANE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
INDENO(1,2,3-CD)PYRENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
ISOPHORONE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
NAPHTHALENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
N-DECANE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
NITROBENZENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
N-NITROSODIMETHYLAMINE (NDMA)	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
N-NITROSODI-N-PROPYLAMINE (NDPA)	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
N-NITROSODIPHENYLAMINE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
N-OCTADECANE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
PENTACHLOROPHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
PHENANTHRENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
PHENOL	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
PYRENE	1.97	1.92	1.95	1.97	1.97	1.95	1.91	1.96	1.97	1.98	1.95	2	1.96	2	0 of 23
Polyaromatic Hydrocarbons (ug/L) - low detection limit methods															
1-METHYLNAPHTHALENE	0.00264	0.0021	0.0021	0.00158	0.00244	0.00204	0.00253	0.00176	0.00443	0.00679	0.00167	0.00264	0.00309	0.0101	46 of 46
1-METHYLPHENANTHRENE	0.00195	0.00179	0.00189	0.0018	0.00213	0.00219	0.00144	0.000995	0.00254	0.00239	0.0018	0.00247	0.00197	0.00351	46 of 46
2,3,5-TRIMETHYLNAPHTHYLENE	0.00371	0.00334	0.00429	0.00398	0.00409	0.00329	0.00322	0.00342	0.00478	0.0035	0.00336	0.00466	0.00377	0.00724	46 of 46
2,6-DIMETHYLNAPHTHALENE	0.00191	0.00183	0.0016	0.00177	0.00376	0.00231	0.00341	0.00243	0.00529	0.00449	0.00195	0.00341	0.003	0.00744	46 of 46
2-METHYLNAPHTHALENE	0.00443	0.00424	0.00212	0.00265	0.00286	0.00467	0.0062	0.00288	0.0108	0.00731	0.00378	0.0026	0.00506	0.0127	46 of 46
ACENAPHTHENE	0.00952	0.00745	0.00546	0.00558	0.00529	0.00755	0.00766	0.00721	0.013	0.0103	0.00651	0.00609	0.00812	0.0151	46 of 46
ACENAPHTHYLENE	0.000537	0.000399	0.000251	0.00077	0.000249	0.00058	0.000747	0.000468	0.0016	0.000247	0.00275	0.002	0.00088	0.00825	28 of 46

**Average Effluent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Polyaromatic Hydrocarbons (ug/L) - low detection limit methods (cont.)															
ANTHRACENE	0.00253	0.00258	0.00161	0.0017	0.002	0.00227	0.00168	0.000737	0.00349	0.00402	0.00261	0.00235	0.00247	0.00747	46 of 46
BENZO(A)ANTHRACENE	0.00202	0.00272	0.00192	0.00227	0.00276	0.00295	0.00142	0.00157	0.0071	0.00472	0.0032	0.00412	0.00331	0.00866	46 of 46
BENZO(A)PYRENE	0.00202	0.00225	0.0025	0.00241	0.00288	0.00318	0.00145	0.00204	0.00702	0.00479	0.00256	0.00406	0.00332	0.0106	46 of 46
BENZO(B)FLUORANTHENE	0.00288	0.00374	0.00283	0.00305	0.00348	0.0036	0.00199	0.00262	0.0121	0.0082	0.00688	0.00565	0.00529	0.0177	46 of 46
BENZO(E)PYRENE	0.00172	0.00218	0.0011	0.00139	0.00181	0.00171	0.00097	0.00157	0.00602	0.0039	0.002	0.00376	0.00259	0.0087	46 of 46
BENZO(G,H,I)PERYLENE	0.00111	0.00144	0.000933	0.00113	0.00187	0.00214	0.00117	0.00153	0.00771	0.00326	0.00161	0.00186	0.00241	0.013	46 of 46
BENZO(K)FLUORANTHENE	0.000796	0.000932	0.00068	0.00084	0.00078	0.00078	0.00047	0.000777	0.00333	0.00251	0.0052	0.00469	0.00194	0.0182	45 of 46
BENZOTHAZOLE	0.09	0.0932	0.0851	0.095	0.145	0.0783	0.165	0.096	0.175	0.0998	0.166	0.13	0.118	0.223	46 of 46
BIPHENYL	0.00119	0.00105	0.00133	0.0011	0.00115	0.00145	0.00119	0.00109	0.00214	0.00114	0.00125	0.00077	0.00126	0.00263	45 of 46
C1-CHRYSENES	0.00209	0.00245	0.00213	0.00257	0.00433	0.003	0.00184	0.00187	0.00575	0.00463	0.0031	0.00401	0.00326	0.00792	46 of 46
C1-DIBENZOTHIOPHENES	0.00434	0.00449	0.00465	0.00464	0.00513	0.0046	0.00397	0.00419	0.00618	0.00704	0.0077	0.00811	0.00555	0.0101	46 of 46
C1-FLUORANTHENES/PYRENES	0.00353	0.0039	0.0042	0.00411	0.00649	0.00473	0.00222	0.0023	0.00734	0.00559	0.0045	0.00595	0.00459	0.011	46 of 46
C1-FLUORENES	0.00787	0.00695	0.00792	0.00824	0.0089	0.00788	0.00779	0.00662	0.0115	0.00851	0.00847	0.00936	0.00837	0.013	46 of 46
C1-NAPHTHALENES	0.00528	0.00475	0.00371	0.00365	0.00413	0.00478	0.00625	0.00467	0.0111	0.00839	0.00498	0.00383	0.00595	0.0135	46 of 46
C1-PHENANTHRENES/ANTHRACENES	0.013	0.0121	0.0124	0.0123	0.0156	0.014	0.0108	0.0117	0.0158	0.0146	0.0161	0.0169	0.0137	0.0192	46 of 46
C2-CHRYSENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.000248	0.00025	0.000249	0.000263	0 of 46
C2-DIBENZOTHIOPHENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.000248	0.00025	0.000249	0.000263	0 of 46
C2-FLUORANTHENES/PYRENES	0.00198	0.00221	0.00199	0.00209	0.00438	0.00247	0.00113	0.00128	0.00487	0.00291	0.00227	0.0026	0.00251	0.00722	46 of 46
C2-FLUORENES	0.00615	0.00638	0.00874	0.00644	0.0088	0.00817	0.00758	0.00686	0.0118	0.00988	0.00964	0.0109	0.0086	0.0153	46 of 46
C2-NAPHTHALENES	0.0058	0.00542	0.00477	0.00565	0.00684	0.0058	0.00814	0.00461	0.0135	0.00906	0.00419	0.00521	0.00698	0.0159	46 of 46
C2-PHENANTHRENES/ANTHRACENES	0.00415	0.00539	0.0071	0.00543	0.00928	0.00535	0.00462	0.00455	0.00705	0.00848	0.00741	0.00798	0.0064	0.0112	46 of 46
C3-CHRYSENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.00117	0.00025	0.000324	0.00392	1 of 46
C3-DIBENZOTHIOPHENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.000248	0.00025	0.000249	0.000263	0 of 46
C3-FLUORANTHENES/PYRENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.000248	0.00025	0.000249	0.000263	0 of 46
C3-FLUORENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.000248	0.00025	0.000249	0.000263	0 of 46
C3-NAPHTHALENES	0.0117	0.00946	0.012	0.0112	0.00964	0.00847	0.0108	0.013	0.0174	0.0149	0.0099	0.0117	0.0122	0.0201	46 of 46
C3-PHENANTHRENES/ANTHRACENES	0.00326	0.00475	0.00508	0.00459	0.0137	0.00458	0.00439	0.00499	0.00734	0.00942	0.0101	0.00775	0.00655	0.0165	46 of 46
C4-CHRYSENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.000248	0.00025	0.000249	0.000263	0 of 46
C4-NAPHTHALENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.000248	0.00025	0.000249	0.000263	0 of 46
C4-PHENANTHRENES/ANTHRACENES	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.000249	0.000247	0.000248	0.00025	0.000249	0.000263	0 of 46
CHRYSENE	0.00295	0.00388	0.00266	0.0029	0.00377	0.00376	0.00192	0.00233	0.0125	0.00716	0.00442	0.00528	0.00493	0.0148	46 of 46
DIBENZO(A,H)ANTHRACENE	0.000254	0.00025	0.000251	0.00026	0.000249	0.00025	0.000236	0.000248	0.00166	0.00111	0.000248	0.00038	0.000544	0.00235	7 of 46
DIBENZOFURAN	0.00672	0.00548	0.00545	0.00517	0.00723	0.00726	0.00556	0.00285	0.0066	0.00493	0.00514	0.00499	0.00548	0.0111	46 of 46
DIBENZOTHIOPHENE	0.00376	0.00352	0.00276	0.00294	0.00283	0.00321	0.00269	0.00185	0.00421	0.00294	0.00271	0.00284	0.00305	0.00591	46 of 46
FLUORANTHENE	0.0111	0.0128	0.00978	0.0109	0.0119	0.0152	0.00603	0.00535	0.0246	0.0146	0.0109	0.0128	0.0127	0.0335	46 of 46
FLUORENE	0.00764	0.0068	0.00566	0.00605	0.00749	0.00862	0.00672	0.00321	0.00926	0.00628	0.0056	0.00542	0.00655	0.0138	46 of 46
INDENO(1,2,3-CD)PYRENE	0.00497	0.00653	0.00487	0.0046	0.00779	0.00201	0.00688	0.00794	0.0188	0.0115	0.00731	0.00484	0.00807	0.0284	46 of 46
NAPHTHALENE	0.00504	0.00617	0.00318	0.00345	0.00456	0.00611	0.00923	0.00468	0.0189	0.0126	0.00561	0.00278	0.00785	0.025	46 of 46
PERYLENE	0.00227	0.00249	0.00213	0.00224	0.00309	0.0031	0.00151	0.00265	0.00339	0.00262	0.00231	0.00318	0.00257	0.00421	46 of 46
PHENANTHRENE	0.0152	0.0162	0.0108	0.011	0.0118	0.0167	0.0101	0.00544	0.0233	0.0143	0.0128	0.0137	0.0138	0.031	46 of 46
PYRENE	0.00988	0.0114	0.0107	0.0107	0.013	0.0132	0.00557	0.00527	0.0195	0.0134	0.0117	0.0149	0.0118	0.0268	46 of 46
Volatile Organics (ug/L)															
1,1,1-TRICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,1,2,2-TETRACHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,1,2-TRICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,1-DICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,1-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,2-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24

**Average Effluent Concentrations
Deer Island Wastewater Treatment Plant - Fiscal Year 2024**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Volatile Organics (ug/L) (cont.)															
1,2-DICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,2-DICHLOROPROPANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,3-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,4-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
2-BUTANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
2-CHLOROETHYL VINYL ETHER	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
2-HEXANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
4-METHYL-2-PENTANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
ACETONE	1	1	1	1	1	1	1	1	1	25.2	8.61	1	5.96	42.8	2 of 24
ACROLEIN	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0 of 24
ACRYLONITRILE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
BENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
BROMODICHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
BROMOFORM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
BROMOMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CARBON DISULFIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CARBON TETRACHLORIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CHLOROFORM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CIS-1,2-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CIS-1,3-DICHLOROPROPENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
DIBROMOCHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
ETHYLBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
M,P-XYLENE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0 of 24
METHYLENE CHLORIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
O-XYLENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
STYRENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TETRACHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TOLUENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TRANS-1,2-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TRANS-1,3-DICHLOROPROPENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TRICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TRICHLOROFLUOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
VINYL ACETATE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
VINYL CHLORIDE	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0 of 24

Notes: Where parameters were below detection levels, one half of the method detection limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations.
The annual average concentration is the flow-weighted average of all data points. The maximum concentration is the highest concentration observed in the monitoring year.

Table H-4
Comparison of Treatment Plant Effluent
With Acute Water Quality Criteria*
Deer Island Treatment Plant - Fiscal Year 2024

Instream Concentration (ug/L)**													
Parameter	Acute Criterion (ug/L)	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
Arsenic	69	0.0080	0.0080	0.0080	0.0080	0.0080	0.0372	0.0080	0.0080	0.0080	0.0080	0.0080	0.0080
Cadmium	33	0.0007	0.0006	0.0007	0.0003	0.0006	0.0016	0.0012	0.0009	0.0024	0.0021	0.0003	0.0010
Chromium	A	0.0143	0.0070	0.0070	0.0070	0.0070	0.0070	0.0070	0.0180	0.0248	0.0206	0.0070	0.0070
Copper	4.8	0.0922	0.1050	0.1200	0.0744	0.1172	0.1540	0.0932	0.1366	0.1714	0.1504	0.0936	0.0946
Cyanide	1.0	0.2000	0.2000	0.2000	0.2000	0.2000	0.2000	0.2000	0.2000	0.2000	0.2000	0.2000	0.2000
Lead	210	0.0120	0.0200	0.0120	0.0120	0.0120	0.0120	0.0120	0.0120	0.0546	0.0460	0.0120	0.0120
Mercury	1.8	0.0001	0.0002	0.0000	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0002	0.0001	0.0001
Nickel	74	0.0528	0.0384	0.0392	0.0302	0.0340	0.0752	0.0070	0.0070	0.0372	0.0157	0.0070	0.0218
Silver	0.95	0.0009	0.0021	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009	0.0018	0.0009	0.0009
Zinc	90	0.3980	0.3860	0.3000	0.3420	0.3980	0.4060	0.3600	0.4660	0.8360	0.8680	0.3120	0.3720

Values that are bold and underlined are criteria exceedances.

For below detection levels, half the method detection limit is used when estimating concentrations to compare with water quality standards.

A No applicable criteria

* EPA National Recommended Water Quality Criteria as incorporated into the Mass WQS [314 CMR 4.05(5)]

** Instream concentration calculated by dividing the maximum effluent concentration by 50, the dilution allowed in the permit for acute criterion compliance.

*** Instream concentration calculated by dividing the monthly average effluent concentration by 70, the dilution allowed in the permit for chronic criterion compliance.

Table H-5
Comparison of Treatment Plant Effluent
With Chronic Water Quality Criteria*
Deer Island Treatment Plant - Fiscal Year 2024

Instream Concentration (ug/L)***													
Parameter	Chronic Criterion (ug/L)	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
Arsenic	36	0.0057	0.0057	0.0057	0.0057	0.0057	0.0247	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057
Cadmium	7.9	0.0003	0.0003	0.0003	0.0002	0.0003	0.0005	0.0006	0.0005	0.0013	0.0011	0.0002	0.0004
Chromium	A	0.0064	0.0050	0.0050	0.0050	0.0050	0.0050	0.0050	0.0127	0.0115	0.0084	0.0050	0.0050
Copper	3.1	0.0490	0.0567	0.0650	0.0480	0.0663	0.0840	0.0626	0.0817	0.0919	0.0836	0.0597	0.0656
Cyanide	1.0	0.1429	0.1429	0.1429	0.1429	0.1429	0.1429	0.1429	0.1429	0.1429	0.1429	0.1429	0.1429
Lead	8.1	0.0068	0.0106	0.0072	0.0073	0.0075	0.0077	0.0075	0.0081	0.0233	0.0164	0.0077	0.0076
Mercury	0.94	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001	0.0001	0.0001	0.0001
Nickel	8.2	0.0321	0.0177	0.0257	0.0199	0.0194	0.0311	0.0050	0.0050	0.0217	0.0066	0.0050	0.0098
Silver	A	0.0006	0.0008	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0008	0.0006	0.0006
Zinc	81	0.2671	0.2486	0.1971	0.2200	0.2229	0.2514	0.2086	0.3171	0.4571	0.4214	0.2043	0.2429

Values that are bold and underlined are criteria exceedances.

For below detection levels, half the method detection limit is used when estimating concentrations to compare with water quality standards.

A No applicable criteria

* EPA National Recommended Water Quality Criteria as incorporated into the Mass WQS [314 CMR 4.05(5)]

** Instream concentration calculated by dividing the maximum effluent concentration by 50, the dilution allowed in the permit for acute criterion compliance.

*** Instream concentration calculated by dividing the monthly average effluent concentration by 70, the dilution allowed in the permit for chronic criterion compliance.

Appendix I

Priority Pollutant Scan Results and Comparison of Influent and Effluent to Established Standards for Clinton

Table I-1
Average Influent Concentrations
Clinton Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Metals and Cyanide (ug/L)															
SILVER	1	~	~	1	~	~	1	~	~	1	~	~	1	1	0 of 4
ALUMINUM	45	~	~	198	~	~	45	~	~	45	~	~	80.6	198	1 of 4
ARSENIC	2.34	~	~	3.59	~	~	3.03	~	~	2.91	~	~	2.98	3.59	4 of 4
CADMIUM	1	~	~	1	~	~	1	~	~	1	~	~	1	1	0 of 4
CHROMIUM	2	~	~	2	~	~	2	~	~	2	~	~	2	2	0 of 4
COPPER	24.3	~	~	45.7	~	~	5	~	~	10.2	~	~	19.9	45.7	3 of 4
MERCURY	0.0125	~	~	0.048	~	~	0.0125	~	~	0.0125	~	~	0.0208	0.048	1 of 4
MOLYBDENUM	7.5	~	~	7.5	~	~	7.5	~	~	7.5	~	~	7.5	7.5	0 of 4
NICKEL	5.5	~	~	2.5	~	~	2.5	~	~	2.5	~	~	3.14	5.5	1 of 4
LEAD	0.6	~	~	1.83	~	~	0.6	~	~	0.6	~	~	0.886	1.83	1 of 4
ZINC	56.7	~	~	92	~	~	43.9	~	~	55.2	~	~	60.7	92	4 of 4
CYANIDE	10	~	~	10	~	~	10	~	~	10	~	~	10	10	0 of 4
Nutrients (mg/L)															
AMMONIA	18.9	30.7	23.4	22.9	23.2	13	14.1	22.2	16.2	12.8	27.2	36.9	20.5	41.4	52 of 52
TOTAL PHOSPHORUS	5.28	5.06	6.23	5.83	5.73	3.17	8.19	6.57	6.11	3.08	6.5	7.34	5.62	13	43 of 43
Conventional Parameters (mg/L)															
CHEMICAL OXYGEN DEMAND	260	382	339	307	347	160	305	388	258	267	342	378	301	625	54 of 54
BIOCHEMICAL OXYGEN DEMAND	83.6	142	118	117	154	80.8	130	151	97	135	162	152	123	214	50 of 51
TOTAL SUSPENDED SOLIDS	239	310	281	191	294	110	270	277	216	144	204	272	226	545	52 of 52

Notes: Where parameters were below detection levels, one half of the method detection limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations.
The annual average concentration is the flow-weighted average of all data points. The maximum concentration is the highest concentration observed in the monitoring year.
~ No data

Table I-2
Comparison of Treatment Plant Influent With Threshold Inhibition Levels
Clinton Treatment Plant Data - Fiscal Year 2023

Parameter	EPA Inhibition Levels		Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
	Activated Sludge	Anaerobic Digestion												
	(ug/L)	(ug/L)												
Average Concentration (ug/L)														
Arsenic	100	1600	2.34	~	~	3.59	~	~	3.03	~	~	2.91	~	~
Cadmium	1000	20000	1	~	~	1	~	~	1	~	~	1	~	~
Chromium	1000	130000	2	~	~	2	~	~	2	~	~	2	~	~
Copper	1000	40000	24.3	~	~	45.7	~	~	5	~	~	10.2	~	~
Cyanide	100	4000	10	~	~	10	~	~	10	~	~	10	~	~
Lead	100	340000	0.6	~	~	1.83	~	~	0.6	~	~	0.6	~	~
Mercury	100	A	0.0125	~	~	0.048	~	~	0.0125	~	~	0.0125	~	~
Nickel	1000	10000	5.5	~	~	2.5	~	~	2.5	~	~	2.5	~	~
Silver	250	13000	1	~	~	1	~	~	1	~	~	1	~	~
Zinc	300	400000	56.7	~	~	92	~	~	43.9	~	~	55.2	~	~

Values that are bold and underlined are inhibition level exceedances

A No applicable criteria

~ No data

Table I-3
Average Effluent Concentrations
Clinton Wastewater Treatment Plant - Fiscal Year 2024

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
Metals and Cyanide (ug/L)															
SILVER	0.0625	~	~	0.0625	~	~	0.0625	~	~	0.0625	~	~	0.0625	0.0625	0 of 12
ALUMINUM	6.15	~	~	3.13	~	~	4.06	~	~	3.13	~	~	3.99	7.5	3 of 12
ARSENIC	0.156	~	~	0.156	~	~	0.291	~	~	0.156	~	~	0.192	0.434	2 of 12
CADMIUM	0.0627	~	~	0.0313	~	~	0.0548	~	~	0.0313	~	~	0.0439	0.0812	4 of 12
CHROMIUM	2	~	~	2	~	~	2	~	~	2	~	~	2	2	0 of 12
COPPER	6.3	7.76	8.68	5.72	6.2	7.19	4.77	5.83	6.75	5.58	7.34	6.99	5.96	8.68	24 of 24
MERCURY	0.0125	~	~	0.0217	~	~	0.0125	~	~	0.0125	~	~	0.0148	0.0276	2 of 12
MOLYBDENUM	1.76	~	~	1.6	~	~	1.65	~	~	2.11	~	~	1.79	2.41	12 of 12
NICKEL	4.34	~	~	3.51	~	~	3.12	~	~	3.84	~	~	3.67	4.46	12 of 12
LEAD	0.0841	~	~	0.0469	~	~	0.067	~	~	0.0469	~	~	0.0599	0.119	3 of 12
ZINC	12	~	~	8.37	~	~	17.9	~	~	10.4	~	~	12.2	18.5	12 of 12
CYANIDE	10	~	~	10	~	~	10	~	~	10	~	~	10	10	0 of 12
Nutrients (mg/L)															
AMMONIA	0.0781	0.1	0.1	0.0658	0.1	0.1	0.0752	0.128	0.195	0.102	0.1	0.112	0.0981	0.316	18 of 63
ORTHOPHOSPHATE	0.0226	0.0213	0.0225	0.0206	0.0819	0.0478	0.0299	0.0249	0.0197	0.0223	0.0224	0.0383	0.0299	0.12	408 of 418
TOTAL PHOSPHORUS	0.0669	0.0458	0.0302	0.0535	0.148	0.141	0.0875	0.0714	0.0437	0.0348	0.0317	0.0564	0.0567	0.182	44 of 44
Conventional Parameters (mg/L)															
CHEMICAL OXYGEN DEMAND	21.2	22.2	20.5	20	23	20	21.6	20.5	20	20.8	24.5	21.7	21.2	31	23 of 54
BIOCHEMICAL OXYGEN DEMAND	1.72	1.69	1.87	1.35	2.1	2.57	2.05	1.3	1.9	1.8	1.38	1.47	1.8	3.79	31 of 52
TOTAL SUSPENDED SOLIDS	1.23	1.47	1.4	1.44	3.19	3.8	4.16	2.87	2.86	3.02	2.86	2.36	2.59	5.1	49 of 52

Notes: Where parameters were below detection levels, one half of the method detection limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations. The annual average concentration is the flow-weighted average of all data points. The maximum concentration is the highest concentration observed in the monitoring year.
~ No data

Table I-4
Comparison of Treatment Plant Effluent
With Acute Water Quality Criteria*
Clinton Treatment Plant - Fiscal Year 2024

Instream Concentration (ug/L)**

Parameter	Acute Criterion (ug/L)	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
Aluminum	368	4.6875	~	~	1.9531	~	~	4.0563	~	~	1.9531	~	~
Arsenic	340	0.0975	~	~	0.0975	~	~	0.2713	~	~	0.0975	~	~
Cadmium	0.79	0.0508	~	~	0.0195	~	~	0.0401	~	~	0.0195	~	~
Chromium	258	1.2500	~	~	1.2500	~	~	1.2500	~	~	1.2500	~	~
Copper[†]	25.7	4.4000	4.8500	5.4250	3.9375	3.8750	4.4938	4.1500	3.6438	4.2188	3.6188	4.5875	4.3688
Cyanide	22	6.2500	~	~	6.2500	~	~	6.2500	~	~	6.2500	~	~
Lead	22.2	0.0644	~	~	0.0293	~	~	0.0744	~	~	0.0293	~	~
Mercury	1.4	0.0078	~	~	0.0173	~	~	0.0078	~	~	0.0078	~	~
Nickel	207	2.7875	~	~	2.2625	~	~	2.1313	~	~	2.4625	~	~
Silver	0.6090	0.0391	~	~	0.0391	~	~	0.0391	~	~	0.0391	~	~
Zinc	51.6	7.8125	~	~	5.6500	~	~	11.5625	~	~	6.7500	~	~

Values that are bold and underlined are criteria exceedances

For below detection levels, half the method detection limit is used when estimating concentrations to compare with water quality standards.

* EPA National Recommended Water Quality Criteria as incorporated into the Mass WQS [314 CMR 4.05(5)(e)]

** Instream concentration calculated by dividing the maximum effluent concentration by 1.6, the dilution allowed in the permit for acute criterion compliance.

*** Instream concentration calculated by dividing the monthly average effluent concentration by 1.6, the dilution allowed in the permit for chronic criterion compliance.

[†] MassDEP established site specific criterion (314 CMR 4.00, Table 28)

[^] Not detected. Calculated using half method detection limit.

A No applicable criteria

~ No data

**Table I-5
Comparison of Treatment Plant Effluent
With Chronic Water Quality Criteria*
Clinton Treatment Plant - Fiscal Year 2024**

Instream Concentration (ug/L)***													
Parameter	Chronic Criterion (ug/L)	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
Aluminum	200	3.8438	~	~	1.9563	~	~	2.5375	~	~	1.9563	~	~
Arsenic	150	0.0975	~	~	0.0975	~	~	0.1819	~	~	0.0975	~	~
Cadmium	0.13	0.0392	~	~	0.0196	~	~	0.0343	~	~	0.0196	~	~
Chromium	33.55	1.2500	~	~	1.2500	~	~	1.2500	~	~	1.2500	~	~
Copper [†]	18.1	3.9375	4.8500	5.4250	3.5750	3.8750	4.4938	2.9813	3.6438	4.2188	3.4875	4.5875	4.3688
Cyanide [^]	5.20	<u>6.2500</u>	~	~	<u>6.2500</u>	~	~	<u>6.2500</u>	~	~	<u>6.2500</u>	~	~
Lead	0.8652	0.0526	~	~	0.0293	~	~	0.0419	~	~	0.0293	~	~
Mercury	0.77	0.0078	~	~	0.0136	~	~	0.0078	~	~	0.0078	~	~
Nickel	22.9	2.7125	~	~	2.1938	~	~	1.9500	~	~	2.4000	~	~
Silver	A	0.0391	~	~	0.0391	~	~	0.0391	~	~	0.0391	~	~
Zinc	52.0	7.5000	~	~	5.2313	~	~	11.1875	~	~	6.5000	~	~

Values that are bold and underlined are criteria exceedances

For below detection levels, half the method detection limit is used when estimating concentrations to compare with water quality standards.

* EPA National Recommended Water Quality Criteria as incorporated into the Mass WQS [314 CMR 4.05(5)(e)]

** Instream concentration calculated by dividing the maximum effluent concentration by 1.6, the dilution allowed in the permit for acute criterion compliance.

*** Instream concentration calculated by dividing the monthly average effluent concentration by 1.6, the dilution allowed in the permit for chronic criterion compliance.

[†] MassDEP established site specific criterion (314 CMR 4.00, Table 28)

[^] Not detected. Calculated using half method detection limit.

A No applicable criteria

~ No data

Appendix J

Effluent Toxicity Tests

Deer Island Wastewater Treatment Plant, Toxicity Test Results, FY24

	Mysid* Acute	Arbacia** Chronic	Menidia*** Acute	Menidia*** Chronic
Limit	50%	1.5%	50%	1.5%
July 2023	> 100	100	> 100	6.25
August	> 100	100	> 100	50
September	> 100	100	> 100	25
October	> 100	100	> 100	25
November	> 100	100	> 100	50
December	> 100	100	> 100	50
January 2024	> 100	25	> 100	50
February	> 100	50	> 100	50
March	> 100	100	> 100	50
April	> 100	100	> 100	100
May	> 100	100	80.7	25
June	> 100	100	> 100	100

*Mysid is *Americamysis bahia*, a marine animal similar to a shrimp.

**Arbacia is *Arbacia punctulata*, a sea urchin. Chronic test measures fertilization.

***Menidia is *Menidia beryllina*, a small fish. Chronic test measures growth.

Clinton Wastewater Treatment Plant, Toxicity Test Results, FY24

	Acute	Chronic
Limit	100%	62.5%
July 2023	>100	100
October	>100	100
January 2024	>100	100
April	54.1	12.5

*The toxicity tests use *Ceriodaphnia dubia*, a freshwater daphnid shrimp.

The chronic test measures reproduction.

Appendix K

Comparison of Sludge Quality to EPA and State Standards

Residuals Quality

EPA and the MassDEP regulate the quality of sewage biosolids intended for beneficial use. At the federal level, these products are governed by the Clean Water Act. These regulations establish quality criteria for several metals and for the degree of pathogen reduction. Federal and state regulations have adopted a two-tiered approach to biosolids regulation. Products meeting the strictest standards for all parameters (MassDEP Type I) may be distributed or marketed with few restrictions. Products meeting only the less-prohibitive Type II standards may be used as fertilizer, but additional distribution, use restrictions and management practices apply. FY24, MWRA's biosolids met all state and federal limits.

Federal and state limits for the distribution of biosolids as a MassDEP Type I Sludge with no limitations for land application are outlined in the tables below.

Federal Limits (40 CFR 503.13, Table 3)

Pollutant	Monthly Average Concentrations (milligrams per kilogram, dry weight)
Arsenic	41
Cadmium	39
Chromium	1,200
Copper	1,500
Lead	300
Mercury	17
Nickel	420
Selenium	36
Zinc	2,800

Massachusetts Limits for Type I Sludge (310 CMR 32.12, Table 32.12(2)(a))

Pollutant	Maximum Allowable Concentrations (milligrams per kilogram, dry weight)
Boron (water soluble)	300
Cadmium	14
Chromium (total)	1,000
Copper	1,000
Lead	300
Mercury	10
Molybdenum	40
Nickel	200
Zinc	2,500

MWRA BIOSOLID PELLET METALS ANALYSIS JULY '23 THROUGH JUNE '24

All concentrations are expressed in mg/kg dry weight basis

	Jul '23	Aug '23	Sep '23	Oct '23	Nov '23	Dec '23	Jan '24	Feb '24	Mar '24	Apr '24	May '24	Jun '24
ARSENIC	3.6	3.8	4.1	4.2	6.0	9.7	7.1	4.3	3.4	3.1	3.1	2.9
BORON	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CADMIUM	3.4	3.4	3.5	3.5	3.4	3.2	3.5	4.1	3.6	3.2	2.9	2.6
CHROMIUM	53.7	55.3	52.3	51.2	47.1	45.8	55.2	56.0	52.3	58.4	61.9	63.6
COPPER	520.2	493.0	532.0	515.0	517.0	474.0	475.8	492.5	519.5	508.3	474.5	515.8
LEAD	86.8	108.5	103.9	87.7	72.4	73.4	88.2	83.8	76.8	81.5	77.3	86.9
MERCURY	1.1	1.3	1.4	1.2	1.2	1.2	1.1	1.5	1.2	1.2	1.2	2.2
MOLYBDENUM	27.4	23.2	20.9	21.5	28.9	27.7	20.8	15.8	16.8	14.8	17.1	20.0
NICKEL	26.2	26.3	26.6	23.9	22.6	20.7	20.7	26.8	24.5	28.6	29.3	29.0
SELENIUM	4.2	3.8	3.2	4.1	5.7	9.2	6.4	3.7	3.8	3.7	5.8	5.1
ZINC	1134.0	1125.0	1127.5	1105.0	1130.0	1044.3	1001.2	946.8	1002.0	982.0	986.5	1095.0

Appendix L

Summary of EPA Program Statistics Summary Report Form

- Metropolitan Boston
- Clinton

EPA Region 1 Annual Pretreatment Report Summary Sheet

July 1, 2023 — June 30, 2024

POTW Name:

Massachusetts Water Resources Authority – Deer Island

NPDES Permit #:

MA01103284

Pretreatment Report Period Start Date:

7/1/2023

Pretreatment Report Period End Date:

6/30/2024

of Significant Industrial Users (SIUs):

177

of SIUs Without Control Mechanisms:

0

of SIUs not Inspected:

0

of SIUs not Sampled:

5*

of SIUs in Significant Noncompliance (SNC)
With Pretreatment Standards:

29

of SIUs in SNC with Reporting Requirements:

6

of SIUs in SNC with Pretreatment Compliance
Schedule:

0

of SIUs in SNC Published in Newspaper:

28

of SIUs with Compliance Schedules:

2

of Violation Notices Issued to SIUs:

95

of Administrative Orders Issued to SIUs:

19

of Civil Suits Filed Against SIUs:

0

of Criminal Suits Filed Against SIUs:

0

of Categorical Industrial Users:

68

of CIUs in SNC:

8

*Discharging SIUs were not sampled because: they did not discharge during the year (three industries), were still under construction during the entire fiscal year (two industries).

Penalties

Total Dollar Amount of Penalties Collected:

\$130100.00

of IUs from which Penalties have been collected:

90,100.00

Local Limits

Date of Most Recent Technical Evaluation
Of Local Limits:

September 2001

Date of Most Recent Adoption of Technically
Based Local Limits:

June 20, 2003

Pollutant

Limit (mg/l)

MAHL (lb/day)

See Appendix M.

EPA Region 1 Annual Pretreatment Report Summary Sheet

July 1, 2023 — June 30, 2024

POTW Name:

Massachusetts Water Resources Authority – Clinton

NPDES Permit #:

MAG590033

Pretreatment Report Period Start Date:

7/1/2023

Pretreatment Report Period End Date:

6/30/2024

of Significant Industrial Users (SIUs):

3

of SIUs Without Control Mechanisms:

0

of SIUs not Inspected:

0

of SIUs not Sampled:

0

of SIUs in Significant Noncompliance (SNC)
With Pretreatment Standards:

0

of SIUs in SNC with Reporting Requirements:

0

of SIUs in SNC with Pretreatment Compliance
Schedule:

0

of SIUs in SNC Published in Newspaper:

0

of SIUs with Compliance Schedules:

0

of Violation Notices Issued to SIUs:

0

of Administrative Orders Issued to SIUs:

0

of Civil Suits Filed Against SIUs:

0

of Criminal Suits Filed Against SIUs:

0

of Categorical Industrial Users:

1

of CIUs in SNC:

0

Penalties

Total Dollar Amount of Penalties Collected:

0

of IUs from which Penalties have been collected:

0

Local Limits

Date of Most Recent Technical Evaluation
Of Local Limits:

June 2023

Date of Most Recent Adoption of Technically
Based Local Limits:

June 20, 2003

Pollutant	Limit (mg/l)	MAHL (lb/day)
See Appendix M.		

Metropolitan (DITP)

Appendix M



Local Limits

Metropolitan Area

Corrected MAHLs based on DITP Recycle Stream Loadings
(2001)

Discharge Limitations/Local Limits from the MWRA Sewer
Use Rules and Regulations (Metropolitan Area)

Clinton Area

Discharge Limitations/Local Limits from the MWRA Sewer
Use Rules and Regulations (specific to Clinton)

TABLE 3-II
MWRA LOCAL LIMITS DEVELOPMENT
CORRECTED MAHLS BASED ON DITP RECYCLE
STREAM LOADINGS (a)

	Prelim Calculated MAHL (lbs/day)	Corrected MAHL (lbs/day)	
2-Chloronaphthalene	5,081,832	5,081,832	
4,4'-DDT	0.201	0.201	
Antimony	7,584,824	7,584,824	
Arsenic	11.8	12.2	(a)
Benzidine	0.640	0.640	
Boron	2,592	2,773	(a)
Cadmium	2.71	2.86	(a)
Chromium, Hexavalent	3,247	3,247	
Chromium, Total	216	219	(a)
Copper	173	201	(a)
Cyanide	34.1	34.1	
Dioxins	16,234	1.65x10 ⁵	(b)
Fluoranthene	437,274	437,274	
Hexachlorobutadiene	59,091	59,091	
Lead	43.7	50.3	(a)
Mercury	1.51	1.58	(a)
Molybdenum	29.5	34.5	(a)
Nickel	89.4	92.2	(a)
Nitrogen, Total	95,750	95,750	
PCBs	0.201	0.201	
Pentachlorophenol	171	171	
Petroleum Hydrocarbons	167,936	167,936	
Phenanthrene	1,623,381	1,623,381	
Phenol	129,870	129,870	
Selenium	25.9	26.1	(a)
Silver	105	105	
Trichloroethylene	67.6	67.6	
Zinc	500	500	

Notes:

MAHLs were corrected for the pollutants that appear in bold.

(a) MAHLs were corrected for pollutants with MAHLs that are dependent on sludge criteria. Corrections were made to account for the effects of DITP recycle stream loadings.

(b) The Prelim calculated MAHL is not correct for dioxin, and Prelim could not be used to calculate the correct MAHL due to the very stringent dioxin water quality criteria (1.4x10⁻⁸), which could not be entered into Prelim correctly. Therefore, the corrected MAHL for dioxins was manually calculated.



September 2001

10.24 : Specific Discharge Limitations/Local Limits

- (1) Any discharge of the following materials is prohibited:
- (a) Into the Metropolitan Sewerage Service Area:
 - 1. Mercury (enforced at 0.001 mg/l);
 - 2. Polychlorinated Biphenyls (PCBs);
 - 3. Pesticides, unless the Authority determines upon request that the substance is acceptable for Discharge to the Sanitary Sewer under the criteria for exclusion or exemption in 40 CFR Parts 152 and 455, or that the substance is otherwise acceptable to Discharge, and that the substance would not otherwise violate 360 CMR 10.021 through 310 CMR 10.024; and
 - 4. Hexachlorobutadiene.
 - (b) Into the Clinton Sewerage Service Area:
 - 1. Mercury (enforced at 0.001 mg/l);
 - 2. Polychlorinated Biphenyls (PCBs);
 - 3. Pesticides, unless the Authority determines upon request that the substance is acceptable for discharge to the sanitary sewer under the criteria for exclusion or exemption in 40 CFR Parts 152 and 455, or that the substance is otherwise acceptable to discharge, and that the substance would not otherwise violate 360 CMR 10.021 through 310 CMR 10.024;
 - 4. Hexachlorobutadiene; and
 - 5. Substances listed in 360 CMR 10.000: *Appendix C*.
- (2) Any discharge of the following materials shall not exceed the daily maximum limit for that material:
- (a) Into the Metropolitan Sewerage Service Area:

<u>Material</u>	<u>Daily Maximum Limit (mg/l)</u>
Acrolein	0.15
Antimony (total)	10.0
Arsenic (total)	0.5
Benzene	0.3
Cadmium (total)	0.1
Chromium (hexavalent)	0.5
Chromium (total)	1.0
Copper (total)	1.0
Cyanide (total)	0.5
Formaldehyde	9.0
Lead (total)	0.2
Nickel (total)	1.0
Phenol	5.0
Selenium (total)	5.0
Silver (total)	2.0
Each Toxic Organic	1.0, unless elsewhere limited in 360 CMR 10.000 for the Metropolitan Sewerage Service Area
Total Toxic Organics	5.0
Vinyl Chloride	0.02
Vinylidene Chloride	0.3
Zinc (total)	1.0

10.024: continued

(b) Into the Clinton Sewerage Service Area:

<u>Material</u>	<u>Daily Maximum Limit mg/l</u>
Acrolein	0.5
Aluminum (total)	30.0
Arsenic (total)	0.5
Benzene	0.4
Bis(2-ethylhexyl)phthalate	0.2
Bromomethane	0.2
Cadmium (total)	0.5
Carbon disulfide	0.6
Carbon tetrachloride	0.1
Chromium (hexavalent)	1.0
Chromium (total)	5.0
Copper (total)	1.0
Cyanide (total)	1.0
Cyclohexane	0.6
1,1-Dichloroethylene	0.2
cis-1,3-Dichloropropene	0.6
trans-1,3-Dichloropropene	0.1
2,4-Dinitrotoluene	0.2
Formaldehyde	9.0
Hexachloroethane	0.2
Lead (total)	0.2
Nickel (total)	2.0
Nitrosamines	0.1
N-Nitrosodibutylamine	0.1
N-Nitrosodiethylamine	0.1
N-Nitrosodimethylamine	0.2
N-Nitrosodiphenylamine	0.5
Pentachlorobenzene	0.2
Selenium (total)	1.0
Silver (total)	1.0, except 2.0 for a Group Permit for Photo Processing and Printing Operations, and a Combined Permit
1,2,4,5-Tetrachlorobenzene	0.1
Trichlorofluoromethane	0.3
Each Toxic Organic	1.0, unless elsewhere limited in 360 CMR 10.000 for the Clinton Sewerage Service Area
Total Toxic Organics	5.0
Zinc	5.0

- (3) The Daily Maximum Limit shall be determined on the basis of a Composite Sample, except a Grab Sample or Samples may be used in the following circumstances:
- (a) for a batch discharge, when the Grab Sample would be fairly representative of the batch as a whole;
 - (b) for pollutants that are not amenable to composite sampling of an industrial wastestream by use of an automatic wastewater sampler, such as hexavalent chromium and volatile organics; or
 - (c) when the Authority determines it is not feasible or appropriate to take a Composite Sample, such as when the discharge is of too short duration for automatic composite sampling or the sampling location is inaccessible for an automatic wastewater sampler.

10.24 : continued

A Composite Sample shall be taken at preselected intervals throughout the time in a day (or in a consecutive 24-hour period over two days when there is a continuous discharge of at least 24 hours over the course of the two days) during which the wastewater is discharged, except a shorter time period may be used if that shorter time period encompasses all or most of the wastewater discharge that day (or consecutive 24-hour period when there is a continuous discharge over the course of two days) or if a shorter period is authorized by the Authority. A batch discharge may have a Composite Sample taken throughout the discharge of the batch. A flow proportioned Composite Sample shall be taken, except a time interval Composite Sample may be taken when the Authority determines it is not feasible or appropriate to take a flow proportioned Composite Sample.

If a Grab Sample may appropriately be used, and more than one Grab Sample of a Discharge is taken during the day, the Daily Maximum Limit shall be measured by either the mathematical average of the analytical results of the Grab Samples or the analytical result of a composite of the Grab Samples.

10.25 : Dilution Prohibition

No person shall achieve, or attempt to achieve, compliance with 360 CMR 10.000 by diluting a Discharge instead of using proper pretreatment. The increased use of process water in place of proper treatment shall be considered dilution prohibited by 360 CMR 10.000.

10.26 : Compliance Measurement Location

All limitations imposed by 360 CMR 10.000 shall be applied at the end of the Pretreatment process line, at the end of the process line if there is no Pretreatment, or at or near the discharge location if there is no Pretreatment or process line. This shall not be construed to authorize a Person to introduce a pollutant into a wastestream after the compliance measurement location; rather, a sample taken at the compliance measurement location is intended to measure the pollutants in a discharge to the sewer before dilution of the wastestream.

Where it deems appropriate, the Authority may by permit or order impose alternative limits or compliance measurement locations to assure compliance with 360 CMR 10.000 and with federal, state, and local requirements. This may include use of the Combined Wastestream Formula when authorized by EPA regulations or use of a dilution factor when more than one stream is combined.

The Authority may require samples from individual process waste streams whether such waste streams are pretreated prior to discharge or not. The Authority may require that compliance measurement locations be clearly marked and/or photographed.

APPENDIX A: METROPOLITAN SEWERAGE SERVICE AREA TOXIC ORGANICS

<u>CAS #</u>	<u>NAME</u>
107-13-1	Acrylonitrile
75-25-2	Bromoform
75-27-4	Bromodichloromethane
74-83-9	Bromomethane
75-15-0	Carbon Disulfide
56-23-5	Carbon Tetrachloride
108-90-7	Chlorobenzene
75-00-3	Chloroethane
110-75-8	2-Chloroethyl Vinyl Ether (mixed)
67-66-3	Chloroform
74-87-3	Chloromethane
124-48-1	Dibromochloromethane
75-34-3	1,1 -Dichloroethane
107-06-2	1,2-Dichloroethane
156-60-5	t-1,2-Dichloroethene
78-87-5	1,2-Dichloropropane
10061-01-5	c-1,3-Dichloropropene
10061-02-6	t-1,3-Dichloropropene
75718	Dichlorodifluoromethane
100-41-4	Ethylbenzene
75-09-2	Methylene Chloride
100-42-5	Styrene
79-34-5	1,1,2,2-Tetrachloroethane
127-18-4	Tetrachloroethene
108-88-3	Toluene
71-55-6	1,1,1-Trichloroethane
79-00-5	1,1,2-Trichloroethane
79016	Trichloroethylene
75-69-4	Trichlorofluoromethane
108-05-4	Vinyl Acetate
1330-20-7	Xylene (total)
83-32-9	Acenaphthene
208-96-8	Acenaphthylene
120-12-7	Anthracene
92-87-5	Benzidine
56-55-3	Benzo(A) Anthracene
205-99-2	Benzo(B) Fluoranthene
207-08-9	Benzo(K) Fluoranthene
191-24-2	Benzo(GHI) Perylene
50-32-8	Benzo(A) Pyrene
85-68-7	Benzyl Butyl Phthalate
111-91-1	Bis (2-Chloroethoxy) Methane
111-44-4	Bis (2-Chloroethyl) Ether
117-81-7	Bis (2-Ethylhexyl) Phthalate
101-55-3	4-Bromophenyl Phenyl Ether
106-47-8	4-Chloroaniline
91-58-7	2-Chloronaphthalene
95578	2-Chlorophenol
7005-72-3	4-Chlorophenyl Phenyl Ether
218-01-9	Chrysene
53-70-3	Dibenzo (A,H) Anthracene
132-64-9	Dibenzo Furan
95-50-1	1,2-Dichlorobenzene
541-73-1	1,3-Dichlorobenzene
106-46-7	1,4-Dichlorobenzene

9/6/19

360 CMR - 90.18

The text of the regulations published in the electronic version of the Massachusetts Register is unofficial and for informational purposes only. The official version is the printed copy which is available from the State Bookstore at <http://www.sec.state.ma.us/spr/sprcat/catidx.htm>.

APPENDIX A: continued

<u>CAS #</u>	<u>NAME</u>
91-94-1	3,3'-Dichlorobenzidine
120832	2,4-Dichlorophenol
84-66-2	Diethyl Phthalate
105679	2,4-Dimethylphenol
131-11-3	Dimethyl Phthalate
84-74-2	Di-n-butyl Phthalate
51285	2,4-Dinitrophenol
534-52-1	2-Methyl-4,6-Dinitrophenol
121-14-2	2,4-Dinitrotoluene
606-20-2	2,6-Dinitrotoluene
117-84-0	Di-n-octyl Phthalate
122-66-7	1,2-Diphenylhydrazine
206-44-0	Fluoranthene
86-73-7	Fluorene
118-74-1	Hexachlorobenzene
87-68-3	Hexachlorobutadiene
67-72-1	Hexachloroethane
193-39-5	Indeno (1,2,3-cd) Pyrene
78-59-1	Isophorone
91-57-6	2-Methylnaphthalene
95-48-7	2-Methylphenol (o-Cresol)
108-39-4	3-Methylphenol (m-Cresol)
106-44-5	4-Methylphenol (p-Cresol)
91-20-3	Naphthalene
98-95-3	Nitrobenzene
88755	2-Nitrophenol
62-75-9	N-Nitrosodimethylamine
621-64-7	N-Nitroso-di-n-Propylamine
95-95-4	2,4,5-Trichlorophenol
88062	2,4,6-Trichlorophenol
75-07-0	Acetaldehyde
107-18-6	Allyl alcohol
107-05-1	Allyl chloride
628-63-7	Amyl acetate
62-53-3	Aniline
100-47-0	Benzonitrile
100-44-7	Benzyl chloride
123-86-4	Butyl acetate
1395-284-6	Butylamine
417-030-3	Crotonaldehyde
110-82-7	Cyclohexane
119-4-65-6	Dichlorobenil
75-99-0	2,2-Dichloropropionic acid
109-89-7	Diethyl amine
99-65-0	1,3-Dinitrobenzene
124-40-3	Dimethylamine
106-89-8	Epichlorohydrin
107-15-3	Ethylene diamine
106-93-4	Ethylene dibromide
98-01-1	Furfural
78-79-5	Isoprene
4250-446-1	Isopropanolamine dodecylbenzenesulfonate
115-32-2	Kelthane
203-265-7	Mercaptodimethur

APPENDIX A: continued

<u>CAS #</u>	<u>NAME</u>
74-93-1	Methyl mercaptan
80-62-6	Methyl methacrylate
75-04-7	Monoethyl amine
74-89-5	Monomethyl amine
1338-24-5	Napthenic acid
1321-12-6	Nitrotoluene
75-44-5	Phosgene
75-56-9	Propylene oxide
108-60-1	2,2'-Oxybis(1-Chloropropane)
91-22-5	Quinoline
108-46-3	Resorcinol
27323-41-7	Triethanolamine dodecylbenzenesulfonate
121-44-8	Triethylamine
75-50-3	Trimethylamine
1300-71-6	Xylenol

APPENDIX D: PESTICIDES

<u>CAS #</u>	<u>Name</u>
93-76-5	2,4,5-T
93-72-1	2,4,5-TP (Silvex)
94-75-7	2,4-D (2,4-Dichlorophenoxy acetic acid)
72-54-8	4,4'-DDD
72-55-9	4,4'-DDE
50-29-3	4,4'-DDT
309-00-2	Aldrin
319-84-6	<i>alpha</i> -BHC
959-98-8	<i>alpha</i> -Endosulfan
3655-10-7	Amobam
319-85-7	<i>beta</i> -BHC
33213-65-9	<i>beta</i> -Endosulfan
51026-28-9	Busan 40
128-03-0	Busan 85
133-06-2	captan
63-25-2	Carbaryl
1563-66-2	Carbofuran
57-74-9	Chlordane
2921-88-2	Chlorpyrifos
56-72-4	Coumaphos
319-86-8	<i>delta</i> BHC
8065-48-3	Demeton
333-41-5	Diazinon
1918-00-9	Dicamba
not found alone	Dichlorophenoxyacetate
62-73-7	Dichlorvos
60-57-1	Dieldrin
124-40-3	Dimethylamine
85-00-7	Diquat
298044	Disulfoton
330-54-1	Diuron
1031078	Endosulfan Sulfate
72-20-8	Endrin
7421-93-4	Endrin Aldehyde
563-12-1	Ethion
502-55-6	EXD
14484-64-1	Ferbam
98-01-1	Furfural
58899	<i>gamma</i> -BHC (Lindane)
86-50-0	Guthion
76448	Heptachlor
1024573	Heptachlor Epoxide
143-50-0	Kepone
137-41-7	KN Methyl
121-75-5	Malathion
137-42-8	Metham
72-43-5	Methoxychlor
298-00-0	Methyl Parathion
7786-34-7	Mevinphos
315-18-4	Mexacarbate
2385-85-5	Mirex
142-59-6	Nabam
138-93-2	Nabonate
300-76-5	Naled
56-38-2	Parathion
87-86-5	Pentachlorophenol
2312-35-8	Propargite

Appendix D: continued

<u>CAS #</u>	<u>Name</u>
75-56-9	Propylene oxide
121-21-1	Pyrethrins
57-24-9	Strychnine
137-26-8	Thiram
8001-35-2	Toxaphene
52-68-6	Trichlorofon
12122-67-7	Zineb
137-30-4	Ziram

See 360 CMR 10.004 and 360 CMR 10.024(1)(a) and (b).

10.24 Specific Discharge Limitations/Local Limits

(1) Any discharge of the following materials is prohibited:

(a) Into the Metropolitan Sewerage Service Area:

1. Mercury (enforced at 0.001 mg/l);
2. Polychlorinated Biphenyls (PCBs);
3. Pesticides, unless the Authority determines upon request that the substance is acceptable for Discharge to the Sanitary Sewer under the criteria for exclusion or exemption in 40 CFR Parts 152 and 455, or that the substance is otherwise acceptable to Discharge, and that the substance would not otherwise violate 360 CMR 10.021 through 310 CMR 10.024; and
4. Hexachlorobutadiene.

(b) Into the Clinton Sewerage Service Area:

1. Mercury (enforced at 0.001 mg/l);
2. Polychlorinated Biphenyls (PCBs);
3. Pesticides, unless the Authority determines upon request that the substance is acceptable for discharge to the sanitary sewer under the criteria for exclusion or exemption in 40 CFR Parts 152 and 455, or that the substance is otherwise acceptable to discharge, and that the substance would not otherwise violate 360 CMR 10.021 through 310 CMR 10.024;
4. Hexachlorobutadiene; and
5. Substances listed in 360 CMR 10.000: *Appendix C*.

(2) Any discharge of the following materials shall not exceed the daily maximum limit for that material:

(a) Into the Metropolitan Sewerage Service Area:

<u>Material</u>	<u>Daily Maximum Limit (mg/l)</u>
Acrolein	0.15
Antimony (total)	10.0
Arsenic (total)	0.5
Benzene	0.3
Cadmium (total)	0.1
Chromium (hexavalent)	0.5
Chromium (total)	1.0
Copper (total)	1.0
Cyanide (total)	0.5
Formaldehyde	9.0
Lead (total)	0.2
Nickel (total)	1.0
Phenol	5.0
Selenium (total)	5.0
Silver (total)	2.0
Each Toxic Organic	1.0, unless elsewhere limited in 360 CMR 10.000 for the Metropolitan Sewerage Service Area
Total Toxic Organics	5.0
Vinyl Chloride	0.02
Vinylidene Chloride	0.3
Zinc (total)	1.0

10.024: continued

(b) Into the Clinton Sewerage Service Area:

<u>Material</u>	<u>Daily Maximum Limit mg/l</u>
Acrolein	0.5
Aluminum (total)	30.0
Arsenic (total)	0.5
Benzene	0.4
Bis(2-ethylhexyl)phthalate	0.2
Bromomethane	0.2
Cadmium (total)	0.5
Carbon disulfide	0.6
Carbon tetrachloride	0.1
Chromium (hexavalent)	1.0
Chromium (total)	5.0
Copper (total)	1.0
Cyanide (total)	1.0
Cyclohexane	0.6
1,1-Dichloroethylene	0.2
cis-1,3-Dichloropropene	0.6
trans-1,3-Dichloropropene	0.1
2,4-Dinitrotoluene	0.2
Formaldehyde	9.0
Hexachloroethane	0.2
Lead (total)	0.2
Nickel (total)	2.0
Nitrosamines	0.1
N-Nitrosodibutylamine	0.1
N-Nitrosodiethylamine	0.1
N-Nitrosodimethylamine	0.2
N-Nitrosodiphenylamine	0.5
Pentachlorobenzene	0.2
Selenium (total)	1.0
Silver (total)	1.0, except 2.0 for a Group Permit for Photo Processing and Printing Operations, and a Combined Permit
1,2,4,5-Tetrachlorobenzene	0.1
Trichlorofluoromethane	0.3
Each Toxic Organic	1.0, unless elsewhere limited in 360 CMR 10.000 for the Clinton Sewerage Service Area
Total Toxic Organics	5.0
Zinc	5.0

(3) The Daily Maximum Limit shall be determined on the basis of a Composite Sample, except a Grab Sample or Samples may be used in the following circumstances:

- (a) for a batch discharge, when the Grab Sample would be fairly representative of the batch as a whole;
- (b) for pollutants that are not amenable to composite sampling of an industrial wastestream by use of an automatic wastewater sampler, such as hexavalent chromium and volatile organics; or
- (c) when the Authority determines it is not feasible or appropriate to take a Composite Sample, such as when the discharge is of too short duration for automatic composite sampling or the sampling location is inaccessible for an automatic wastewater sampler.

10.24 : continued

A Composite Sample shall be taken at preselected intervals throughout the time in a day (or in a consecutive 24-hour period over two days when there is a continuous discharge of at least 24 hours over the course of the two days) during which the wastewater is discharged, except a shorter time period may be used if that shorter time period encompasses all or most of the wastewater discharge that day (or consecutive 24-hour period when there is a continuous discharge over the course of two days) or if a shorter period is authorized by the Authority. A batch discharge may have a Composite Sample taken throughout the discharge of the batch. A flow proportioned Composite Sample shall be taken, except a time interval Composite Sample may be taken when the Authority determines it is not feasible or appropriate to take a flow proportioned Composite Sample.

If a Grab Sample may appropriately be used, and more than one Grab Sample of a Discharge is taken during the day, the Daily Maximum Limit shall be measured by either the mathematical average of the analytical results of the Grab Samples or the analytical result of a composite of the Grab Samples.

10.25 : Dilution Prohibition

No person shall achieve, or attempt to achieve, compliance with 360 CMR 10.000 by diluting a Discharge instead of using proper pretreatment. The increased use of process water in place of proper treatment shall be considered dilution prohibited by 360 CMR 10.000.

10.26 : Compliance Measurement Location

All limitations imposed by 360 CMR 10.000 shall be applied at the end of the Pretreatment process line, at the end of the process line if there is no Pretreatment, or at or near the discharge location if there is no Pretreatment or process line. This shall not be construed to authorize a Person to introduce a pollutant into a wastestream after the compliance measurement location; rather, a sample taken at the compliance measurement location is intended to measure the pollutants in a discharge to the sewer before dilution of the wastestream.

Where it deems appropriate, the Authority may by permit or order impose alternative limits or compliance measurement locations to assure compliance with 360 CMR 10.000 and with federal, state, and local requirements. This may include use of the Combined Wastestream Formula when authorized by EPA regulations or use of a dilution factor when more than one stream is combined.

The Authority may require samples from individual process waste streams whether such waste streams are pretreated prior to discharge or not. The Authority may require that compliance measurement locations be clearly marked and/or photographed.

APPENDIX B: CLINTON SEWERAGE SERVICE AREA TOXIC ORGANICS

<u>CAS #</u>	<u>Name</u>
83-32-9	Acenaphthene
208-95-8	Acenaphthylene
75-07-0	Acetaldehyde
107-18-6	Allyl alcohol
107-05-1	Allyl chloride
628-63-7	N-Amyl acetate
62-53-3	Aniline
120-12-7	Anthracene
191-24-2	Benzo[g,h,i]perylene
50-32-8	Benzo[a]pyrene
100-47-0	Benzonitrile
100-44-7	Benzyl chloride
111-91-1	Bis(2-chloroethoxy)methane
75-27-4	Bromodichloromethane
75-25-2	Bromoform
101-55-3	4-Bromophenyl phenyl ether
123-86-4	N-Butyl acetate
109-73-9	N-Butylamine
85-68-7	Butylbenzylphthalate
27134-26-5	Chloroaniline
108-90-7	Chlorobenzene
124-48-1	Chlorodibromomethane
59-50-7	p-Chloro-m-cresol
75-00-3	Chloroethane
110-75-8	2-Chloroethylvinyl ether
67-66-3	Chloroform
74-87-3	Chloromethane
91-58-7	2-Chloronaphthalene
95-57-8	2-Chlorophenol
7005-72-3	4-Chlorophenyl phenyl ether
4170-30-3	Crotonaldehyde
132-64-9	Dibenzofuran
1194-65-6	Dichlorobenil
95-50-1	1, 2-Dichlorobenzene
541-73-1	1, 3-Dichlorobenzene
106-46-7	1, 4-Dichlorobenzene
75-71-8	Dichlorodifluoromethane
75-34-3	1,1-Dichloroethane
107-06-2	1,2-Dichloroethane
156-60-5	trans -1,2-Dichloroethylene
120-83-2	2,4-Dichlorophenol
78-87-5	1,2-Dichloropropane
542-75-6	1,3-Dichloropropene
75-99-0	2,2-Dichloropropionic acid
109-89-7	Diethyl amine
84-66-2	Diethylphthalate
105-67-9	2,4-Dimethylphenol
131-11-3	Dimethylphthalate
51-28-5	2,4-Dinitrophenol
84-74-2	Di-n-butylphthalate
534-52-1	4,6-Dinitro-o-cresol
606-20-2	2,6 Dinitrotoluene
117-84-0	Di-n-octyl phthalate
106-89-8	Epichlorohydrin
100-41-4	Ethylbenzene
107-15-3	Ethylene diamine
106-93-4	Ethylene dibromide

APPENDIX B: continued

206-44-0	Fluoranthene
86-73-7	Fluorene
78-59-1	Isophorone
68514-39-6	Isoprene
42504-46-1	Isopropanolamine dodecylbenzenesulfonate
115-32-2	Kelthane
2032-65-7	Mercaptodimethur
534-52-1	2-Methyl-4,6-dinitrophenol
79-09-2	Methylene chloride
74-93-1	Methyl mercaptan
80-62-6	Methyl methacrylate
1321-94-4	Methylnaphthalene
95-48-7	2-Methylphenol
108-39-4	3-Methylphenol
106-44-5	4-Methylphenol
75-04-7	Monoethylamine
74-89-5	Monomethylamine
91-20-3	Naphthalene
1338-24-5	Naphthenic acid
98-95-3	Nitrobenzene
88-75-5	2-Nitrophenol
100-02-7	4-Nitrophenol
930-55-2	N-Nitrosopyrrolidine
1321-12-6	Nitrotoluene
85-01-8	Phenanthrene
108-95-2	Phenol
75-44-5	Phosgene
129-00-0	Pyrene
108-60-1	2,2'-Oxybis(1-Chloropropane)
91-22-5	Quinoline
108-46-3	Resorcinol
128-04-1	Sodium dimethyldithiocarbamate
100-42-5	Styrene
79-34-5	1,1,2,2-Tetrachloroethane
127-18-4	Tetrachloroethylene
108-88-3	Toluene
120-82-1	1,2,4-Trichlorobenzene
71-55-6	1,1,1-Trichloroethane
79-00-5	1,1,2-Trichloroethane
79-01-6	Trichloroethylene
27323-41-7	Triethanolamine dodecylbenzenesulfonate
121-44-8	Triethylamine
75-50-3	Trimethylamine
108-05-4	Vinyl acetate
1300-71-6	Xylenol

See 360 CMR 10.004 and 360 CMR 10.024(2)(b).

APPENDIX C: CLINTON SEWERAGE SERVICE AREA PROHIBITED POLLUTANTS

<u>CAS #</u>	<u>Name</u>
107-13-1	Acrylonitrile
92-87-5	Benzidine
50-32-8	Benzo[a]pyrene
56-55-3	Benzo[a]anthracene
205-99-5	Benzo[b]fluoranthene
207-08-9	Benzo[k]fluoranthene
111-44-4	Bis(2-chloroethyl)ether
218-01-9	Chrysene
53-70-3	Dibenzo[a,h]anthracene
91-94-1	3,3-Dichlorobenzidine
122-66-7	1,2-Diphenylhydrazine
118-74-1	Hexachlorobenzene
608-73-1	Hexachlorocyclo-hexane-Technical
77-47-4	Hexchlorocyclopentadiene
193-39-5	Indeno(1,2,3-cd)pyrene
621-64-7	N-Nitrosodi-n-propylamine
688-73-3	Tributyltin
95-95-4	2,4,5-Trichlorophenol
88-06-2	2,4,6-Trichlorophenol
75-01-4	Vinyl chloride
1330-20-7	Xylene (total)

See 360 CMR 10.024(1)(b).

APPENDIX D: PESTICIDES

<u>CAS #</u>	<u>Name</u>
93-76-5	2,4,5-T
93-72-1	2,4,5-TP (Silvex)
94-75-7	2,4-D (2,4-Dichlorophenoxy acetic acid)
72-54-8	4,4'-DDD
72-55-9	4,4'-DDE
50-29-3	4,4'-DDT
309-00-2	Aldrin
319-84-6	<i>alpha</i> -BHC
959-98-8	<i>alpha</i> -Endosulfan
3655-10-7	Amobam
319-85-7	<i>beta</i> -BHC
33213-65-9	<i>beta</i> -Endosulfan
51026-28-9	Busan 40
128-03-0	Busan 85
133-06-2	captan
63-25-2	Carbaryl
1563-66-2	Carbofuran
57-74-9	Chlordane
2921-88-2	Chlorpyrifos
56-72-4	Coumaphos
319-86-8	<i>delta</i> BHC
8065-48-3	Demeton
333-41-5	Diazinon
1918-00-9	Dicamba
not found alone	Dichlorophenoxyacetate
62-73-7	Dichlorvos
60-57-1	Dieldrin
124-40-3	Dimethylamine
85-00-7	Diquat
298044	Disulfoton
330-54-1	Diuron
1031078	Endosulfan Sulfate
72-20-8	Endrin
7421-93-4	Endrin Aldehyde
563-12-1	Ethion
502-55-6	EXD
14484-64-1	Ferbam
98-01-1	Furfural
58899	<i>gamma</i> -BHC (Lindane)
86-50-0	Guthion
76448	Heptachlor
1024573	Heptachlor Epoxide
143-50-0	Kepone
137-41-7	KN Methyl
121-75-5	Malathion
137-42-8	Metham
72-43-5	Methoxychlor
298-00-0	Methyl Parathion
7786-34-7	Mevinphos
315-18-4	Mexacarbate
2385-85-5	Mirex
142-59-6	Nabam
138-93-2	Nabonate
300-76-5	Naled
56-38-2	Parathion
87-86-5	Pentachlorophenol
2312-35-8	Propargite

Appendix D: continued

<u>CAS #</u>	<u>Name</u>
75-56-9	Propylene oxide
121-21-1	Pyrethrins
57-24-9	Strychnine
137-26-8	Thiram
8001-35-2	Toxaphene
52-68-6	Trichlorofon
12122-67-7	Zineb
137-30-4	Ziram

See 360 CMR 10.004 and 360 CMR 10.024(1)(a) and (b).

**MASSACHUSETTS WATER RESOURCES AUTHORITY
DEER ISLAND**

**33 TAFTS AVENUE
BOSTON, MA 02128**

617-242-6000

WWW.MWRA.COM

