LAST UPDATED **October 14, 2026**

DEER ISLAND TREATMENT PLANT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*

September-2026 DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME / ADDRESS
NAME MWRA
ADDRESS DEER ISLAND
33 TAFTS AVENUE
BOSTON MA 02128

FACILITY MWRA
LOCATION BOSTON MA 02129
ATTN: Rebecca Weidman, Deputy COO

MA0103284	T01 A
PERMIT NUMBER	DISCHARGE NUMBER

MAJOR
(SUBR E)
TUNNEL DISCHARGE

*** NO DISCHARGE ☐ ***

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
26	9	1	26	9	30

PARAMETER		QUANTITY OR LOADING			QUANTITY OR LOADING				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
PH Effluent Gross	SAMPLE MEASUREMENT	******	******		**6.4**	******	**7.0**	SU	**0**	02 / 01	GR
	PERMIT MEASUREMENT	******	******		6.0 MINIMUM	******	9.0 MAXIMUM	SU		Daily	GRAB
Solids, Total Suspended Effluent Gross	SAMPLE MEASUREMENT	******	******		**8.0**	**8.6**	**26.9**	mg/L	**0**	01 / 01	24
	PERMIT MEASUREMENT	******	******		30.0 MO AVG	45.0 WKLY AVG	Req. Mon. DAILY MX	mg/L		Daily	COMP24
Solids, Total Suspended Raw Sewage Influent	SAMPLE MEASUREMENT	******	******		**244.0**	**347.2**	**444.8**	mg/L	**0**	01 / 01	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	Req. Mon. WKLY AVG	Req. Mon. DAILY MX	mg/L		Daily	COMP24
Solids, Settleable Effluent Gross	SAMPLE MEASUREMENT	******	******		******	**0.01**	**0.10**	mL/L		01 / 01	GR
	PERMIT MEASUREMENT	******	******		******	Req. Mon. WKLY AVG	Req. Mon. DAILY MX	mL/L		Daily	GRAB
Nitrogen, ammonia total (as N) Effluent Gross	SAMPLE MEASUREMENT	******	******		**35.36**	******	******	mg/L		07 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	******	mg/L		Once per month	COMP24
Nitrogen, nitrite total (as N) Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.99**	******	******	mg/L		05 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	******	mg/L		Once per month	COMP24
Nitrogen, nitrate total (as N) Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.74**	******	******	mg/L		05 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon MO AVG	******	******	mg/L		Once per month	COMP24

PARAMETER		QUANTITY OR LOADING			QUANTITY OR LOADING				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, Kjeldahl total (as N) Effluent Gross	SAMPLE MEASUREMENT	******	******		**36.65**	******	******	mg/L		05 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	******	mg/L		Once per month	COMP24
Chloride (as Cl) Raw Sewage Influent	SAMPLE MEASUREMENT	******	******		******	******	**1051.8**	mg/L		01 / 01	GR
	PERMIT MEASUREMENT	******	******		******	******	Req. Mon. DAILY MX	mg/L		Daily	GRAB
Arsenic, total (as As) Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		02 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Copper, total recoverable Effluent Gross	SAMPLE MEASUREMENT	******	******		**3.63**	******	**4.57**	µg/L		04 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Coliform, fecal - % samples exceeds limit Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	******	%		03 / 01	GR
	PERMIT MEASUREMENT	******	******		10.0 MAXIMUM	******	******	%		Three per day	GRAB
PCB-1016 Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		0.000045 MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
4, 4'-DDT Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L	**0**	01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24

PARAMETER		QUANTITY OR LOADING			QUANTITY OR LOADING				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Aldrin Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Chlorodane, alpha, whole water Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Chlorodane (tech mix. and metabolites) Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Dieldrin Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Heptachlor Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Heptachlor epoxide Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon.MO	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
PCB-1221 Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L	**0**	01 / 31	24
	PERMIT MEASUREMENT	******	******		0.000045 MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24

PARAMETER		QUANTITY OR LOADING			QUANTITY OR LOADING				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
PCB-1232 Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L	**0**	01 / 31	24
	PERMIT MEASUREMENT	******	******		0.000045 MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
PCB-1242 Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L	**0**	01 / 31	24
	PERMIT MEASUREMENT	******	******		0.000045 MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
PCB-1248 Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L	**0**	01 / 31	24
	PERMIT MEASUREMENT	******	******		0.000045 MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
PCB-1254 Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L	**0**	01 / 31	24
	PERMIT MEASUREMENT	******	******		0.000045 MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
PCB-1260 Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L	**0**	01 / 31	24
	PERMIT MEASUREMENT	******	******		0.000045 MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Polychlorinated biphenyls (PCBs) Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.00053**	******	**0.00089**	µg/L		04 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon.MO	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Hexachlorobenzene Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24

PARAMETER		QUANTITY OR LOADING			QUANTITY OR LOADING				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Gamma chlordane, whole water Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		01 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Flow, in conduit or thru treatment plant Effluent Gross	SAMPLE MEASUREMENT	**265.8**	**724.9**	mgd	******	******	******			99 / 99	RC
	PERMIT MEASUREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	mgd	******	******	******			Continuous	RCORDR
Chlorine, total residual Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L	**0**	03 / 01	GR
	PERMIT MEASUREMENT	******	******		456.0 MO AVG	******	631.0 DAILY MX	µg/L		Three per day	GRAB
Mercury, total (as HG) Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.00189**	******	**0.00334**	µg/L		04 / 31	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	COMP24
Coliform, fecal general Effluent Gross	SAMPLE MEASUREMENT	******	******		******	**7.1**	**16.4**	#/100mL	**0**	03 / 01	GR
	PERMIT MEASUREMENT	******	******		******	14000.0 WKLY GEO	14000.0 DAILY MX	#/100mL		Three per day	GRAB
Coliform, fecal general See Comments	SAMPLE MEASUREMENT	******	******		**'9'**	**'9'**	**'9'**				
	PERMIT MEASUREMENT	******	******		200.0 MO GEO	200.0 MEDIAN	400.0DAILY MX	#/100mL		Three per day	GRAB
Cyanide, total recoverable Effluent Gross	SAMPLE MEASUREMENT	******	******		**10.5**	******	**20.9**	µg/L		02 / 31	GR
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	GRAB

PARAMETER		QUANTITY OR LOADING			QUANTITY OR LOADING				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Volatile fraction organics (EPA 624) Effluent Gross	SAMPLE MEASUREMENT	******	******		**0.0**	******	**0.0**	µg/L		02 / 31	GR
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	******	Req. Mon. DAILY MX	µg/L		Once per month	GRAB
CBOD5/NH3-N Effluent Gross	SAMPLE MEASUREMENT	******	******		**6.5**	**8.3**	**16.2**	mg/L	**0**	01 / 01	24
	PERMIT MEASUREMENT	******	******		25.0 MO AVG	40.0 WKLY AVG	Req. Mon. DAILY MX	mg/L		Daily	COMP24
CBOD5/NH3-N Raw Sewage Influent	SAMPLE MEASUREMENT	******	******		**197.7**	**237.7**	**332.4**	mg/L		01 / 01	24
	PERMIT MEASUREMENT	******	******		Req. Mon. MO AVG	Req. Mon. WKLY AVG	Req. Mon. DAILY MX	mg/L		Daily	COMP24
FLOW,TOTAL EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	**245.0**	**212.9**	mgal/d	******	******	******		**0**	99 / 99	CA
	PERMIT MEASUREMENT	436.0 ANNL AVG	Req. Mon. MO AVG	mgal/d	******	******	******			Continuous	RCOTOT

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE	DATE
Rebecca Weidman, Deputy Chief Operating Officer	See original form for signature	(617)788-4958	10/14/2026

DEER ISLAND TREATMENT PLANT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*

September-2026 DISCHARGE MONITORING REPORT (DMR)

LAST UPDATED **October 14, 2026**

PERMITTEE NAME / ADDRESS
NAME MWRA
ADDRESS DEER ISLAND
33 TAFTS AVENUE
BOSTON MA 02128

FACILITY MWRA
LOCATION BOSTON MA 02129
ATTN: Rebecca Weidman, DCOO

MA0103284	T01 T
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
26	9	1	26	9	30

MAJOR
(SUBR E)
TUNNEL WET DATA

*** NO DISCHARGE ☐ ***

PARAMETER		QUANTITY OR LOADING			QUANTITY OR LOADING				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
LC50 Static 48Hr Acute Mysid. Bahia Effluent Gross	SAMPLE MEASUREMENT	******	******		**78.30**	******	******	%	**0**	01/30	24
	PERMIT MEASUREMENT	******	******		50 DAILY MN	******	******	%		Once per month	COMP24
LC50 48Hr Acute Menidia Effluent Gross	SAMPLE MEASUREMENT	******	******		**64.8**	******	******	%	**0**	01/30	24
	PERMIT MEASUREMENT	******	******		50 DAILY MN	******	******	%		Once per month	COMP24
Noel Static 1Hr Fert. Chronic Arbacia Effluent Gross	SAMPLE MEASUREMENT	******	******		**100.0**	******	******	%	**0**	01/30	24
	PERMIT MEASUREMENT	******	******		1.5 DAILY MN	******	******	%		Once per month	COMP24
Noael Statre 7Day Chronic Menidia Effluent Gross	SAMPLE MEASUREMENT	******	******		**25.0**	******	******	%	**0**	01/30	24
	PERMIT MEASUREMENT	******	******		1.5 DAILY MN	******	******	%		Once per month	COMP24

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE	DATE
Rebecca Weidman, Deputy Chief Operating Officer	See original form for signature	(617)788-4958	10/14/2026

EPA Form 3320-1 (Rev. 1/06) Previous editions may be used.

H - Invalid test

][