

**Table A: Quabbin and Wachusett Reservoir -
Giardia and Cryptosporidium Results**

Location*	Sample Date	Volume Filtered (L)	<i>Crypto</i> Concentration (Oocysts/L)	<i>Giardia</i> Concentration (Cysts/L)
Brutsch Water Treatment Facility	5-Jan-2016	49.96	ND	ND
	19-Jan-2016	52.99	ND	ND
	2-Feb-2016	51.10	ND	ND
	16-Feb-2016	59.05	ND	ND
	1-Mar-2016	51.10	ND	ND
	15-Mar-2016	50.02	ND	ND
	29-Mar-2016	57.00	ND	ND
	12-Apr-2016	51.00	ND	ND
	26-Apr-2016	50.04	ND	ND
	10-May-2016	50.00	ND	ND
	24-May-2016	50.00	ND	ND
	7-Jun-2016	50.00	ND	ND
	21-Jun-2016	50.06	ND	ND
	5-Jul-2016	50.04	ND	ND
	19-Jul-2016	50.00	ND	ND
	2-Aug-2016	52.10	ND	ND
	16-Aug-2016	51.90	ND	ND
	30-Aug-2016	55.00	ND	ND
	13-Sep-2016	50.00	ND	ND
	27-Sep-2016	53.00	ND	ND
	11-Oct-2016	50.13	ND	ND
	25-Oct-2016	50.11	ND	ND
	8-Nov-2016	52.00	ND	ND
	21-Nov-2016	50.00	ND	ND
	6-Dec-2016	50.78	ND	ND
	20-Dec-2016	50.00	ND	ND

**Table A: Quabbin and Wachusett Reservoir -
Giardia and Cryptosporidium Results**

Location*	Sample Date	Volume Filtered (L)	Crypto Concentration (Oocysts/L)	Giardia Concentration (Cysts/L)
Carroll Water Treatment Plant	05-Jan-2016	52.78	ND	ND
	12-Jan-2016	50.20	ND	ND
	19-Jan-2016	53.84	ND	ND
	26-Jan-2016	50.00	ND	ND
	02-Feb-2016	50.00	ND	ND
	09-Feb-2016	52.52	ND	ND
	16-Feb-2016	50.00	ND	ND
	23-Feb-2016	52.15	ND	ND
	01-Mar-2016	50.07	ND	ND
	08-Mar-2016	50.10	ND	ND
	15-Mar-2016	50.00	ND	ND
	22-Mar-2016	52.19	ND	ND
	29-Mar-2016	53.68	ND	ND
	05-Apr-2016	52.03	ND	ND
	12-Apr-2016	51.12	ND	ND
	19-Apr-2016	50.60	ND	ND
	26-Apr-2016	55.08	ND	0.04
	03-May-2016	50.12	ND	ND
	10-May-2016	53.94	ND	ND
	17-May-2016	50.00	ND	ND
	24-May-2016	50.03	ND	0.02
	31-May-2016	50.60	ND	ND
	07-Jun-2016	50.12	ND	ND
	14-Jun-2016	51.40	ND	ND
	21-Jun-2016	50.00	ND	0.04
	28-Jun-2016	52.22	ND	ND
	05-Jul-2016	52.00	ND	ND
	12-Jul-2016	50.10	ND	ND
	19-Jul-2016	51.15	ND	ND
	26-Jul-2016	50.00	ND	ND
	02-Aug-2016	50.04	ND	ND
	09-Aug-2016	50.26	ND	ND
	16-Aug-2016	50.00	ND	0.02
	23-Aug-2016	50.08	ND	ND
	30-Aug-2016	50.00	ND	ND
	06-Sep-2016	50.00	ND	ND
	13-Sep-2016	50.11	ND	ND
	20-Sep-2016	52.11	ND	ND
	27-Sep-2016	50.13	ND	ND
	04-Oct-2016	50.22	ND	0.02
	11-Oct-2016	52.00	ND	0.02
	18-Oct-2016	50.06	ND	ND
	25-Oct-2016	51.00	ND	ND
	01-Nov-2016	50.21	ND	ND
	08-Nov-2016	50.00	ND	ND
	15-Nov-2016	50.00	ND	ND
	21-Nov-2016	50.16	ND	ND
	29-Nov-2016	52.30	ND	ND
	06-Dec-2016	50.14	ND	ND
	13-Dec-2016	52.59	ND	ND
	20-Dec-2016	51.00	ND	ND
	27-Dec-2016	50.00	ND	ND

Reported concentrations are in oocysts/L for Cryptosporidium and cysts/L for Giardia.

Testing Lab: Analytical Services Inc

ND = Below Detection Limit if <0.02 Oocysts/L or <0.02 Cysts/L

EPA Method 1623.1