

**Table A: Quabbin and Wachusett Reservoir -
Giardia and Cryptosporidium Results**

Location*	Sample Date	Volume Filtered (L)	<i>Crypto</i> Concentration (Oocysts/L)	<i>Giardia</i> Concentration (Cysts/L)
Brutsch Water Treatment Facility	3-Jan-2017	50.00	ND	ND
	17-Jan-2017	52.00	ND	ND
	31-Jan-2017	53.00	ND	ND
	14-Feb-2017	50.00	ND	ND
	28-Feb-2017	53.74	ND	ND
	13-Mar-2017	53.30	ND	ND
	28-Mar-2017	55.24	ND	ND
	11-Apr-2017	50.00	ND	ND
	25-Apr-2017	50.00	ND	ND
	9-May-2017	50.00	ND	ND
	23-May-2017	50.08	ND	ND
	6-Jun-2017	51.00	ND	ND
	20-Jun-2017	50.28	ND	ND
	5-Jul-2017	53.72	ND	ND
	18-Jul-2017	52.00	ND	ND
	1-Aug-2017	50.50	ND	ND
	15-Aug-2017	50.06	ND	ND
	29-Aug-2017	50.92	ND	ND
	12-Sep-2017	50.22	ND	ND
	26-Sep-2017	50.10	ND	ND
	10-Oct-2017	50.04	ND	ND
	24-Oct-2017	50.06	ND	ND
	7-Nov-2017	50.00	ND	ND
	20-Nov-2017	50.02	ND	ND
	5-Dec-2017	58.28	ND	ND
	19-Dec-2017	50.14	ND	ND

**Table A: Quabbin and Wachusett Reservoir -
Giardia and Cryptosporidium Results**

Location*	Sample Date	Volume Filtered (L)	Crypto Concentration (Oocysts/L)	Giardia Concentration (Cysts/L)
Carroll Water Treatment Plant	03-Jan-2017	54.00	ND	ND
	10-Jan-2017	50.00	ND	ND
	17-Jan-2017	50.00	ND	ND
	24-Jan-2017	50.10	ND	ND
	31-Jan-2017	50.00	ND	0.02
	07-Feb-2017	52.64	ND	0.11
	14-Feb-2017	51.26	ND	0.04
	21-Feb-2017	51.88	ND	ND
	28-Feb-2017	50.00	ND	ND
	07-Mar-2017	50.00	ND	0.02
	13-Mar-2017	40.07	ND	0.02
	21-Mar-2017	52.96	ND	0.06
	28-Mar-2017	50.04	ND	ND
	04-Apr-2017	52.00	ND	ND
	11-Apr-2017	50.25	ND	ND
	18-Apr-2017	53.04	ND	0.02
	25-Apr-2017	50.00	ND	ND
	02-May-2017	50.00	ND	0.04
	09-May-2017	50.12	ND	0.02
	16-May-2017	50.10	ND	ND
	23-May-2017	50.06	ND	ND
	30-May-2017	53.50	ND	ND
	06-Jun-2017	50.00	ND	ND
	13-Jun-2017	50.03	ND	ND
	20-Jun-2017	50.00	ND	ND
	27-Jun-2017	50.20	ND	ND
	05-Jul-2017	50.00	ND	ND
	10-Jul-2017	51.06	ND	ND
	18-Jul-2017	50.00	ND	ND
	25-Jul-2017	52.12	ND	ND
	01-Aug-2017	50.00	ND	ND
	08-Aug-2017	50.84	ND	ND
	15-Aug-2017	59.11	ND	ND
	22-Aug-2017	50.06	ND	0.02
	29-Aug-2017	50.06	ND	ND
	05-Sep-2017	50.12	ND	ND
	12-Sep-2017	50.00	ND	ND
	19-Sep-2017	50.08	ND	ND
	26-Sep-2017	50.00	ND	ND
	03-Oct-2017	50.09	ND	ND
	10-Oct-2017	50.00	ND	ND
	17-Oct-2017	50.00	ND	ND
	24-Oct-2017	50.05	ND	ND
	31-Oct-2017	50.00	ND	ND
	07-Nov-2017	50.11	ND	ND
	14-Nov-2017	50.07	ND	ND
	20-Nov-2017	50.60	ND	ND
	28-Nov-2017	50.04	ND	ND
	05-Dec-2017	50.00	ND	ND
	12-Dec-2017	50.00	ND	ND
	19-Dec-2017	50.03	ND	ND
	26-Dec-2017	50.00	ND	0.02

Reported concentrations are in oocysts/L for Cryptosporidium and cysts/L for Giardia.

Testing Lab: Analytical Services Inc

ND = Below Detection Limit if <0.02 Oocysts/L or <0.02 Cysts/L

EPA Method 1623.1