

**Table A: Quabbin and Wachusett Reservoir -
Giardia and Cryptosporidium Results**

Location*	Sample Date	Volume Filtered (L)	Crypto Concentration (Oocysts/L)	Giardia Concentration (Cysts/L)
Brutsch Water Treatment Facility	07-Jan-2025	50.00	ND	ND
	21-Jan-2025	50.02	0.02	ND
	04-Feb-2025	50.00	ND	ND
	18-Feb-2025	50.02	ND	ND
	04-Mar-2025	50.01	ND	ND
	18-Mar-2025	50.00	ND	ND
	01-Apr-2025	50.00	ND	ND
	15-Apr-2025	49.98	0.02	ND
	29-Apr-2025	50.00	ND	ND
	13-May-2025	50.00	ND	ND
	27-May-2025	50.02	ND	ND
	17-Jun-2025	50.02	ND	ND
	24-Jun-2025	50.06	ND	ND
	08-Jul-2025	49.99	ND	ND
	22-Jul-2025	50.00	ND	ND
	05-Aug-2025	50.02	ND	ND
	19-Aug-2025	50.00	ND	ND
	02-Sep-2025	50.34	ND	ND
	16-Sep-2025	50.00	ND	ND
	30-Sep-2025	50.04	ND	ND
14-Oct-2025	50.00	ND	ND	
28-Oct-2025	49.98	ND	ND	
12-Nov-2025	50.02	ND	ND	
24-Nov-2025	50.00	ND	ND	
09-Dec-2025	50.07	ND	ND	

**Table A: Quabbin and Wachusett Reservoir -
Giardia and Cryptosporidium Results**

Location*	Sample Date	Volume Filtered (L)	Crypto Concentration (Oocysts/L)	Giardia Concentration (Cysts/L)
Carroll Water Treatment Plant	07-Jan-2025	50.00	ND	ND
	14-Jan-2025	50.00	ND	0.02
	21-Jan-2025	50.00	ND	ND
	29-Jan-2025	50.02	0.02	ND
	04-Feb-2025	50.00	ND	ND
	11-Feb-2025	50.00	ND	ND
	18-Feb-2025	50.02	ND	ND
	25-Feb-2025	50.00	0.02	ND
	04-Mar-2025	49.98	ND	ND
	11-Mar-2025	50.00	ND	ND
	18-Mar-2025	50.00	ND	ND
	25-Mar-2025	50.00	ND	ND
	01-Apr-2025	49.99	ND	ND
	08-Apr-2025	50.00	ND	ND
	15-Apr-2025	50.00	ND	ND
	23-Apr-2025	50.06	ND	ND
	29-Apr-2025	50.00	ND	ND
	06-May-2025	50.00	ND	0.02
	13-May-2025	50.02	ND	0.02
	20-May-2025	50.02	ND	ND
	27-May-2025	49.99	ND	ND
	03-Jun-2025	49.99	ND	ND
	17-Jun-2025	50.00	ND	ND
	24-Jun-2025	50.10	ND	ND
	01-Jul-2025	50.06	ND	ND
	08-Jul-2025	50.00	ND	ND
	16-Jul-2025	50.00	ND	ND
	22-Jul-2025	50.00	ND	ND
	05-Aug-2025	50.04	ND	ND
	12-Aug-2025	50.00	ND	ND
19-Aug-2025	50.00	ND	ND	
26-Aug-2025	50.02	ND	ND	
02-Sep-2025	50.00	ND	ND	
09-Sep-2025	50.02	ND	ND	
16-Sep-2025	50.00	ND	ND	
23-Sep-2025	50.00	ND	ND	
30-Sep-2025	49.98	ND	ND	
07-Oct-2025	50.02	ND	ND	
14-Oct-2025	50.00	ND	ND	
21-Oct-2025	50.02	ND	ND	
28-Oct-2025	50.00	ND	ND	
03-Nov-2025	50.00	ND	ND	
13-Nov-2025	50.04	ND	0.02	
18-Nov-2025	49.97	ND	ND	
24-Nov-2025	49.98	ND	ND	
02-Dec-2025	50.00	ND	ND	
09-Dec-2025	50.02	ND	ND	
16-Dec-2025	50.00	ND	ND	
29-Dec-2025	50.00	ND	ND	

Reported concentrations are in oocysts/L for Cryptosporidium and cysts/L for Giardia.

Testing Lab: Analytical Services Inc

ND = Below Detection Limit if <0.02 Oocysts/L or <0.02 Cysts/L

EPA Method 1623.1