

## Lead Service Line Sample Results: 2018 Q3 (July - September)

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
3947142	Medford	1	7/4/18	2.51	ppb
3947144	Medford	1A	7/4/18		ppb
3948988	Medford	2	7/11/18	1.19	ppb
3948989	Medford	2A	7/11/18	0.594	ppb
3958251	Melrose	3	7/25/18	12.3	ppb
3958252	Melrose	3A	7/25/18	10.9	ppb
3958253	Melrose	4	7/25/18	10.7	ppb
3958254	Melrose	4A	7/25/18	11.0	ppb
3958249	Melrose	5	7/25/18	1.41	ppb
3958250	Melrose	5A	7/25/18	0.491	ppb
3961425	Medford	6	7/27/18	0.364	ppb
3961426	Medford	6A	7/27/18		ppb
3959016	Melrose	7	7/30/18	45.3	ppb
3959017	Melrose	7A	7/30/18	59.0	ppb
3961421	Medford	8	7/31/18	4.63	ppb
3961422	Medford	8A	7/31/18	0.721	ppb
3959745	Melrose	9	7/31/18	624	ppb
3959746	Melrose	9A	7/31/18	682	ppb
3961423	Medford	10	7/31/18	10.9	ppb
3961424	Medford	10A	7/31/18	2.31	ppb
3961427	Medford	11	8/2/18	128	ppb
3961428	Medford	11A	8/2/18	3.46	ppb
3969053	Medford	12	8/7/18	0.700	ppb
3969054	Medford	12A	8/7/18	0.939	ppb
3969057	Medford	13	8/9/18	9.27	ppb
3969058	Medford	13A	8/9/18	12.3	ppb
3969051	Medford	14	8/15/18	1.42	ppb
3969052	Medford	14A	8/15/18	0.272	ppb
3969055	Medford	15	8/16/18	71.0	ppb
3969056	Medford	15A	8/16/18	16.0	ppb

## **Lead Service Line Sample Results: 2018 Q3 (July - September)**

3973737	Medford	16	8/17/18	5.37	ppb
3973738	Medford	16A	8/17/18	1.09	ppb
3973727	Medford	17	8/19/18	5.03	ppb
3973728	Medford	17A	8/19/18	1.88	ppb
3973731	Medford	18	8/20/18	7.64	ppb
3973732	Medford	18A	8/20/18	9.35	ppb
3973729	Medford	19	8/22/18	65.6	ppb
3973730	Medford	19A	8/22/18	10.2	ppb
3973725	Medford	20	8/22/18	12.5	ppb
3973726	Medford	20A	8/22/18	6.27	ppb
3973735	Medford	21	8/23/18	12.7	ppb
3973736	Medford	21A	8/24/18	2.57	ppb
3973739	Medford	22	8/23/18	21.4	ppb
3973740	Medford	22A	8/23/18	18.1	ppb
3973733	Medford	23	8/23/18	5.71	ppb
3973734	Medford	23A	8/23/18	5.43	ppb
3976453	Medford	24	8/28/18	2.28	ppb
3976454	Medford	24A	8/28/18		ppb
3974578	Malden	25	8/29/18	11.4	ppb
3976455	Medford	26	8/30/18	6.52	ppb
3976456	Medford	26A	8/30/18		ppb
3981977	Melrose	27	8/31/18	11.3	ppb
3981978	Melrose	27A	8/31/18	11.4	ppb
3981985	Medford	28	9/3/18	3.03	ppb
3981986	Medford	28A	9/3/18	2.52	ppb
3981981	Medford	29	9/3/18	19.3	ppb
3981982	Medford	29A	9/3/18	24.6	ppb
3981983	Medford	30	9/4/18	6.57	ppb
3981984	Medford	30A	9/4/18	3.48	ppb
3981979	Medford	31	9/6/18	7.92	ppb
3981980	Medford	31A	9/6/18	6.82	ppb

## **Lead Service Line Sample Results: 2018 Q3 (July - September)**

3983670	Medford	32	9/10/18	2.35	ppb
3983671	Medford	32A	9/10/18	1.87	ppb
3983668	Medford	33	9/11/18	1.95	ppb
3983669	Medford	33A	9/11/18	1.67	ppb
3995092	Medford	34	9/25/18	4.47	ppb
3995093	Medford	34A	9/25/18	1.56	ppb

- **ppb = parts per billion or  $\mu\text{g/L}$**
- **“<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”**
- **Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of 15 ppb.**