

## MPDH Sample Results: 2018 Q4 (October - December)

<u>Case/Sample ID</u>	<u>Project Name</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
431044	DPH-PB	1	10/1/18	< 1.00	ppb
431044	DPH-PB	1A	10/1/18		ppb
429582	DPH-PB	2	10/3/18	< 1.00	ppb
429582	DPH-PB	2A	10/3/18	< 1.00	ppb
431044	DPH-PB	3	10/4/18		ppb
431044	DPH-PB	3A	10/4/18	< 1.00	ppb
431575	DPH-PB	4	10/17/18	< 1.00	ppb
431575	DPH-PB	4A	10/17/18	2.53	ppb
431863	DPH-PB	5	10/25/18	< 1.00	ppb
431863	DPH-PB	5A	10/25/18	< 1.00	ppb
431755	DPH-PB	6	11/8/18	< 1.00	ppb
431755	DPH-PB	6A	11/8/18	< 1.00	ppb
430118	DPH-PB	7	11/8/18	< 1.00	ppb
430118	DPH-PB	7A	11/8/18	< 1.00	ppb
432524	DPH-PB	8	11/9/18	2.35	ppb
432524	DPH-PB	8A	11/9/18	1.61	ppb
431824	DPH-PB	9	11/9/18	< 1.00	ppb
431824	DPH-PB	9A	11/9/18	< 1.00	ppb
432527	DPH-PB	10	11/9/18	< 1.00	ppb
432527	DPH-PB	10A	11/9/18	< 1.00	ppb
C-432302	DPH-PB	11	11/14/18	3.48	ppb
C-432302	DPH-PB	11A	11/14/18	2.40	ppb
432298	DPH-PB	12	11/26/18	6.18	ppb
432298	DPH-PB	12A	11/26/18	2.24	ppb
431210	DPH-PB	13	11/27/18	1.24	ppb
431210	DPH-PB	13A	11/27/18	1.10	ppb
432645	DPH-PB	14	12/3/18	2.83	ppb
432645	DPH-PB	14A	12/3/18	20.90*	ppb
432564	DPH-PB	15	12/12/18	< 1.00	ppb
432564	DPH-PB	15A	12/12/18	< 1.00	ppb
433150	DPH-PB	16	12/12/18	< 1.00	ppb
433150	DPH-PB	16A	12/12/18	< 1.00	ppb
430907	DPH-PB	17	12/18/18	< 1.00	ppb
430907	DPH-PB	17A	12/18/18	< 1.00	ppb
C-433242	DPH-PB	18	12/18/18		ppb
C-433242	DPH-PB	18A	12/18/18	< 1.00	ppb

- **ppb** = parts per billion or µg/L

- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”