

## Lead Service Line Sample Results: 2022 Q4 (October - December)

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
4743750	Boston	1	11/9/22	29.0	ppb
4745908	Boston	2	11/11/22	4.27	ppb

- **ppb** = parts per billion or µg/L
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”
- Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of **15 ppb**.